

**CITY OF LINWOOD
CITY HALL
ENERGY ASSESSMENT**

for

**NEW JERSEY
BOARD OF PUBLIC UTILITIES**

CHA PROJECT NO. 22215

December 2010

Prepared by:

CLOUGH HARBOUR & ASSOCIATES LLP

6 Campus Drive
Parsippany, NJ 07054

(973) 538-2120

TABLE OF CONTENTS

| | <u>Page</u> |
|---|-------------|
| 1.0 INTRODUCTION & BACKGROUND..... | 1 |
| 2.0 EXECUTIVE SUMMARY..... | 2 |
| 3.0 EXISTING CONDITIONS..... | 3 |
| 3.1 Building General | |
| 3.2 Utility Usage | |
| 3.3 HVAC Systems | |
| 3.4 Lighting/Electrical Systems | |
| 3.5 Control Systems | |
| 3.6 Plumbing Systems | |
| 4.0 ENERGY CONSERVATION MEASURES..... | 6 |
| 4.1 ECM-1 Insulate Ceiling over Police Wing | |
| 4.2 ECM-2 Boiler Replacement | |
| 4.3 ECM-3 Night Setback | |
| 4.4 ECM-4 Lighting Replacements | |
| 5.0 INCENTIVES OVERVIEW..... | 9 |
| 5.1 Incentives Overview | |
| 5.2 Building Incentives | |
| 6.0 ALTERNATIVE ENERGY EVALUATION..... | 13 |
| 6.1 Geothermal | |
| 6.2 Solar | |
| 6.3 Wind | |
| 6.4 Combined Heat and Power Generation (CHP) | |
| 6.5 Biomass Power Generation | |
| 6.6 Demand Response Curtailment | |
| 7.0 EPA PORTFOLIO MANAGER..... | 17 |
| 8.0 CONCLUSIONS & RECOMMENDATIONS..... | 18 |

APPENDICES

- A Utility Usage Analysis
 - B ECM-1 Increase Ceiling Insulation
 - C ECM-2 Replace Boilers
 - D ECM-3 Night Setback
 - E ECM-4 Lighting Replacement
 - F New Jersey Pay For Performance Incentive Program
 - G Photovoltaic (PV) Rooftop Solar Power Generation
 - H Solar Thermal Domestic Hot Water Plant
 - I Wind
 - J EPA Portfolio Manager
 - K Equipment Inventory
 - L Block Load Models
-

1.0 INTRODUCTION AND BACKGROUND

The Linwood Municipal Building is a 13,000 square foot structure located at 400 Poplar Avenue, Linwood, NJ. The building is comprised of municipal offices and courtroom, and police wing. The municipal sector operates from 9:00 AM to 4:30 PM, Monday through Friday. The police wing is operated 24 hours per day with a separate entrance. Approximately 15 employees occupy the complex daily.

New Jersey's Clean Energy Program, funded by the New Jersey Board of Public Utilities, supports energy efficiency and sustainability for Municipal and Local Government Energy Audits. Through the support of a utility trust fund, New Jersey is able to assist state and local authorities in reducing energy consumption while increasing comfort.

2.0 EXECUTIVE SUMMARY

This report details the results of the Linwood Municipal Building, a 13,000 square foot structure in Linwood, NJ. The building is comprised of municipal offices and courtroom, and police wing. Approximately 15 employees occupy the complex daily. The following areas were evaluated for energy conservation measures:

- Night setback
- Lighting replacement
- Boiler replacement
- Insulation upgrades

Various potential Energy Conservation Measures (ECMs) were identified for the above categories. Potential annual savings of \$4,500 for the recommended ECMs may be realized with a payback of 0.7 years.

The ECMs identified in this report will allow for the building to reduce its energy usage and if pursued has the opportunity to qualify for the New Jersey SmartStart Buildings Program. A summary of the costs, savings, and paybacks for the recommended ECMs follows:

ECM-3 Night Setback

| Budgetary Cost | Annual Utility Savings | | | | | Estimated Maintenance Savings | Total Savings | ROI | Potential Incentive* | Payback (without Incentive) | Payback (with Incentive) |
|----------------|------------------------|-------|-------------|-------|-------|-------------------------------|---------------|-----|----------------------|-----------------------------|--------------------------|
| | Electricity | | Natural Gas | Water | Total | | | | | | |
| \$ | kW | kWh | Therms | kGals | \$ | \$ | \$ | | \$ | Years | Years |
| 1,000 | 0 | 7,000 | 2,570 | 0 | 4,200 | 0 | 4,200 | 65 | NA | 0.2 | NA |

*There is no current incentive available through the NJ Smart Start Program. See section 5.0 for other incentive opportunities.

ECM-4 Lighting Replacements

| Budgetary Cost | Annual Utility Savings | | | | | Estimated Maintenance Savings | Total Savings | ROI | Potential Incentive* | Payback (without Incentive) | Payback (with Incentive) |
|----------------|------------------------|-------|-------------|-------|-------|-------------------------------|---------------|-----|----------------------|-----------------------------|--------------------------|
| | Electricity | | Natural Gas | Water | Total | | | | | | |
| \$ | kW | kWh | Therms | kGals | \$ | \$ | \$ | | \$ | Years | Years |
| 2,900 | 0 | 2,200 | 0 | 0 | 300 | 0 | 300 | 0.8 | 600 | 9.7 | 7.7 |

*Incentive shown is per the New Jersey Smart Start Program, 2010 Prescriptive Lighting Application. See section 5.0 for other incentive opportunities.

In addition, the following measure is recommended if it qualifies for funding through the Direct Install Program (see section 5.2.4). Under this program, incentives can be potentially awarded for up to 60% of a project's budgetary cost with a maximum incentive of \$50,000, when the work is performed by a participating Direct Install contractor.

- ECM-2 Boiler Replacement

3.0 EXISTING CONDITIONS

3.1 Building – General

The Linwood Municipal Building is a 13,000 square foot building which was renovated in 2006, including the building envelope and HVAC systems. The building has two main areas, the office areas and police wing. The municipal area is composed of office space, storage area, courtroom, and restrooms. The public area is open from 9:00 AM to 4:30 PM Monday through Friday and is occupied by about 15 people. The police wing has a separate entrance which is accessed 24 hours per day, and is occupied by about four people.

The exterior is finished with brick and siding; the police wing is mainly brick finish. All the walls have insulation, and building interior walls are finished with sheetrock and painted. There is a suspended ceiling in both the municipal and police areas. The main entrance to the building has new double pane vinyl windows; the remainder has wood framed windows. The entire building has a pitched roof with asphalt shingles.

3.2 Utility Usage

Utilities include electricity, natural gas, and water. Electricity is purchased from Atlantic City Electric with supply provided from New Energy, Inc. Natural gas supply and delivery is provided by South Jersey Gas Company, and potable water is provided by New Jersey American Water.

From June 2009 through April 2010, electric usage was approximately 294,280 kWh at a cost of about \$46,100. The May 2010 utility bills were not available. Analyzing electricity bills during this period showed that the building was charged at a blended unit cost of \$0.16 per kWh. Electricity usage was generally higher in the summer months due to air conditioning. During the timeframe of June 2009 through April 2010, the building heating and domestic hot water produced by natural gas-fired equipment required about 14,020 therms. Based on the annual cost of about \$16,800, the blended price for natural gas was \$1.20 per therm. Natural gas consumption is highest in the winter months when the building is in heating mode.

Review of potable water utility bills from October 2009 through September 2010 determined the facility used a total of 130,000 gallons of water over the course of a year. At a total cost of about \$1,300, the unit cost for water was \$9.90 per kGal. Utility data can be found in Appendix A.

Electricity supply and delivery are presently purchased from Atlantic City Electric and natural gas from South Jersey Gas Company. The delivery component will always be the responsibility of the utility that connects the facility to the power grid or gas line; however, the supply can be purchased from a third party. The electricity or natural gas commodity supply entity will require submission of one to three years of past energy bills. Contract terms can vary among suppliers. A list of approved electrical and natural gas energy commodity suppliers can be found in Appendix A. According to the U.S. Energy Information Administration, the average commercial unit costs of electricity and natural gas in New Jersey during July 2010 were \$0.152 per kWh and \$1.09 per therm. The building is currently paying above the state average for natural gas; therefore, it is recommended that a third party supplier be pursued. Electricity unit cost is on par with the state average.

3.3 HVAC Systems

3.3.1 Space Heating and Air Conditioning System

The municipal section has two approximately 75% efficient Burnham gas fired natural draft boilers, with gas inputs of 462 BMH each. Hot water is circulated throughout the municipal section by two 3 HP base mounted pumps. Finned tube radiators in the perimeter offices provide space heating. There are three Carrier air handling units (AHUs) with DX and heating coils. One AHU serves the courtroom, the other two serve the remainder of the building.

The police wing has a single Weil McLain boiler with input of 175 BMH, and is about 80% efficient. The hot water is circulated to an AHU with heating coil manufactured by Trane. The Trane unit is a Climate Changer with a 5 HP fan motor and DX cooling coil. The wing has no radiators.

The municipal section utilizes three AHUs with DX coils to supply conditioned air. These units and condensers are less than three years' old. The police wing uses the single Trane Climate Changer which is a constant volume system with a cooling coil. The condenser is outside and is in average condition. Each cooling coil for the entire building has a separate condenser located outside on grade.

3.3.2 Building Ventilation and Exhaust Systems

The building has ducts that supply fresh air to the AHUs. There is an exhaust fan for the municipal area restrooms. The police area has a separate restroom exhaust fan.

3.4 Lighting/Electrical Systems

Most of the fixtures in the municipal sector use two T-8 lamps with electronic ballasts. Several fixtures in the corridor had compact fluorescent bulbs. The police wing has four lamp T-12 fixtures and magnetic ballasts. Exterior lighting consists of five fixtures mounted to the sides of the building. The police area has a backup generator.

3.5 Control Systems

3.5.1 HVAC Controls

HVAC controls in the municipal portion consist of wall mounted thermostats in various rooms and a master thermostat in the hallway. Temperature setpoints vary throughout the main building area; on average, these are 70°F for heating and 72°F for cooling during occupied times. All the controls were programmable and connected to a master control panel on each AHU. The system uses a variable volume temperature (VVT) controls sequence which varies the supply temperature in the AHU.

The controls for the police wing consist of a single programmable thermostat located in the hallway; however, limited setback is performed because the wing is occupied continuously. The setpoints are 72°F cooling and 70°F heating.

3.5.2 Lighting/Electrical Controls

Lighting controls are manual switches located within each space. The exterior lights are on a timer.

3.6 Plumbing Systems

Domestic hot water is generated by a 40 gallon, AO Smith gas-fired water heater with an input of 40,000 Btuh. It is in fair condition. The plumbing fixtures in the municipal sector are low flow type, and fixtures in the police wing are standard flow.

4.0 ENERGY CONSERVATION MEASURES

4.1 ECM-1 Insulate Ceiling over Police Wing

The area above the ceiling of the police wing has minimal insulation and allows conditioned air to escape. The existing insulation in this area is insufficient and this ECM assessed adding about nine inches of batt insulation. This would raise the thermal resistance, or R-value, from about R-17 to R-36.

To calculate the savings associated with adding insulation, the existing thermal losses through the roof were calculated with the existing insulation and compared with the thermal losses with the added batt insulation. The difference between the existing conditions and proposed conditions was taken and compared with yearly temperature bin data. The calculated savings associated with adding additional insulation would be approximately 300 therms of natural gas per year. There would also be cooling savings of 320 kWh since the space is air conditioned during the summer months.

Insulation has a life expectancy of about 20 years according to ASHRAE and the total energy savings over the life of the project would be about 6,000 therms and 6,400 kWh and \$8,000.

The implementation cost and savings related to this ECM are presented in Appendix B and summarized below:

ECM-1 Insulate Ceiling Over Police Wing

| Budgetary Cost | Annual Utility Savings | | | ROI | Potential Incentive* | Payback (without incentive) | Payback (with incentive) | |
|----------------|------------------------|-----|-------------|-----|----------------------|-----------------------------|--------------------------|-------|
| | Electricity | | Therms | | | | | Total |
| \$ | kW | kWh | Natural Gas | \$ | \$ | Years | Years | |
| 5,500 | 0 | 320 | 300 | 400 | 0.43 | NA | 14 | NA |

* There is no incentive available through the New Jersey Smart Start program for this ECM. See section 5.0 for other incentive opportunities.

This measure is not recommended.

4.2 ECM-2 Boiler Replacement

The municipal section has two Burnham boilers with 462 MBH input while the police wing has a single Weil McLain boiler with 175 MBH input. Although the municipal area was recently renovated, the existing boilers were not replaced.

All three boilers are beyond their useful life and should be replaced. The average existing heating efficiency is estimated to be around 68%. This ECM evaluated replacing all the boilers with newer high efficiency, condensing boilers. Based on the utility bills, gas usage was over 14,000 therms. With the improved efficiency of new condensing boilers of approximately 92%, the natural gas savings is expected to be 3,000 therms.

For implementation of this measure, one new gas-fired, condensing, hot water boiler would be installed for the police wing and two new condensing boilers for the municipal wing. A new exhaust flue system will be required for each boiler.

Condensing boilers have an expected life of 20 years, according to ASHRAE, and total energy savings over the life of the project are estimated at 60,000 therms totaling \$70,000.

The implementation cost and savings related to this ECM are presented in Appendix C and summarized below:

ECM-2 Boiler Replacement

| Budgetary Cost | Annual Utility Savings | | | | Estimated Maintenance Savings | Total Savings | ROI | Potential Incentive* | Payback (without Incentive) | Payback (with Incentive) | |
|----------------|------------------------|-----|-------------|-------|-------------------------------|---------------|-------|----------------------|-----------------------------|--------------------------|-------|
| | Electricity | | Natural Gas | Water | | | | | | | Total |
| \$ | kW | kWh | Therms | kGals | \$ | \$ | | \$ | Years | Years | |
| 181,000 | 0 | 0 | 3,000 | 0 | 3,500 | 0 | 3,500 | (0.6) | 1,500 | >25 | >25 |

* Incentive shown is per the New Jersey Smart Start Program, Gas Heating Application. Also, this measure is potentially eligible for Direct Install funding. See section 5.0 for other incentive opportunities.

This measure is not recommended.

4.3 ECM-3 Night Setback

Heating and cooling is provided by the boilers and AHUs in the municipal section of the building. The existing controls use a constant temperature setpoint during unoccupied and occupied hours. The typical settings are 70°F in heating and 72°F in cooling mode.

To calculate the benefits of night setback, a block load building model was created to approximate the existing energy load. The block load, provided in Appendix L, models the maximum overall cooling and heating load for each space, taking into account various parameters such as roof, wall, and window construction; total envelope surface area; ventilation and infiltration loads; building occupancy; internal heat generation; and other sources of heat gains and losses. By entering this calculated maximum load into a spreadsheet containing bin temperature data, the total accumulated year-round cooling and heating energy requirements were determined. The heating and cooling loads were then combined and reconciled to building utility data and HVAC equipment energy requirements to confirm the model's accuracy. Bin data for Atlantic City, NJ was used. The bin temperature spreadsheets are included in Appendix L.

This measure will save energy by modifying the heating and cooling setpoints during the unoccupied times. It is intended to lower the heating set point to 60°F and cooling set point to 78°F during the unoccupied times.

For implementation of this measure, the existing controls will need to be reprogrammed to achieve the new schedule.

Controls equipment has an expected life of 15 years, according to ASHRAE, and total energy savings over the life of the project are estimated at 105,000 kWh, 38,550 therms, totaling \$63,000.

The implementation cost and savings related to this ECM are presented in Appendix D and summarized as follows:

ECM-3 Night Setback

| Budgetary Cost | Annual Utility Savings | | | | | Estimated Maintenance Savings | Total Savings | ROI | Potential Incentive* | Payback (without Incentive) | Payback (with Incentive) |
|----------------|------------------------|-------|-------------|-------|-------|-------------------------------|---------------|-----|----------------------|-----------------------------|--------------------------|
| | Electricity | | Natural Gas | Water | Total | | | | | | |
| \$ | kW | kWh | Therms | kGals | \$ | \$ | \$ | | \$ | Years | Years |
| 1,000 | 0 | 7,000 | 2,570 | 0 | 4,200 | 0 | 4,200 | 65 | NA | 0.2 | NA |

*There is no current incentive available through the NJ Smart Start Program. See section 5.0 for other incentive opportunities.

This measure is recommended.

4.4 ECM-4 Lighting Replacements

During the site visit, a comprehensive fixture survey was conducted of the entire building. Each switch and circuit was identified, as well as the number of fixtures, locations, approximate operating times, and existing wattage consumption. There are a series of T-12 lamps and magnetic ballasts in the police wing which should be replaced to newer technology T-8 lamps and electronic ballasts.

Energy savings for this measure were calculated by applying the existing and proposed fixture wattages to the estimated time of operation to determine annual electricity consumptions. The difference resulted in an annual savings of about 2,200 kWh per year. Supporting calculations, including all assumptions for lighting hours and the annual energy usage for each fixture is provided in Appendix E.

Lighting has an expected life of 15 years, according to the manufacturer, and total energy savings over the life of the project are estimated at 33,000 kWh, totaling \$4,500.

The implementation cost and savings related to this ECM are presented in Appendix E and summarized below:

ECM-4 Lighting Replacements

| Budgetary Cost | Annual Utility Savings | | | | | Estimated Maintenance Savings | Total Savings | ROI | Potential Incentive* | Payback (without Incentive) | Payback (with Incentive) |
|----------------|------------------------|-------|-------------|-------|-------|-------------------------------|---------------|-----|----------------------|-----------------------------|--------------------------|
| | Electricity | | Natural Gas | Water | Total | | | | | | |
| \$ | kW | kWh | Therms | kGals | \$ | \$ | \$ | | \$ | Years | Years |
| 2,900 | 0 | 2,200 | 0 | 0 | 300 | 0 | 300 | 0.8 | 600 | 9.7 | 7.7 |

*Incentive shown is per the New Jersey Smart Start Program, 2010 Prescriptive Lighting Application. See section 5.0 for other incentive opportunities.

This measure is recommended.

5.0 PROJECT INCENTIVES

5.1 Incentives Overview

5.1.1 New Jersey Pay For Performance Program

The building will be eligible for incentives from the New Jersey Office of Clean Energy. The most significant incentives will be from the New Jersey Pay for Performance (P4P) Program. The P4P program is designed for qualified energy conservation projects in facilities whose demand in any of the preceding 12 months exceeds 200 kW. However, the 200 kW/month average minimum has been waived for buildings owned by local governments or municipalities and non-profit organizations. Facilities that meet this criterion must also achieve a minimum performance target of 15% energy reduction by using the EPA Portfolio Manager benchmarking tool before and after implementation of the measure(s). If the participant is a municipal electric company customer, and a customer of a regulated gas New Jersey Utility, only gas measures will be eligible under the Program. American Recovery and Reinvestment Act (ARRA) funding, when available, may allow oil, propane and municipal electric customers to be eligible for the P4P Program. Available incentives are as follows:

Incentive #1: Energy Reduction Plan – This incentive is designed to offset the cost of services associated with the development of the Energy Reduction Plan (ERP). The standard incentive pays \$0.10 per square foot, up to a maximum of \$50,000, not to exceed 50% of facility annual energy cost, paid after approval of application. For building audits funded by the New Jersey Board of Public Utilities, which receive an initial 75% incentive toward performance of the energy audit, facilities are only eligible for an additional \$0.05 per square foot, up to a maximum of \$25,000, rather than the standard incentive noted above.

Incentive #2: Installation of Recommended Measures – This incentive is based on projected energy saving and designed to pay approximately 60% of the total performance-based incentive. Base incentives deliver \$0.11/kWh and \$1.10/therm not to exceed 30% of total project cost.

Incentive #3: Post-Construction Benchmarking Report – This incentive is paid after acceptance of a report proving energy savings over one year utilizing the Environmental Protection Agency (EPA) Portfolio Manager benchmarking tool. Incentive #3 base incentives deliver \$0.07/kWh and \$0.70/therm not to exceed 20% of total project cost.

Combining incentives #2 and #3 will provide a total of \$0.18/ kWh and \$1.8/therm not to exceed 50% of total project cost. Additional incentives for #2 and #3 are increased by \$0.005/kWh and \$0.05/therm for each percentage increase above the 15% minimum target to 20%, calculated with the EPA Portfolio Manager benchmarking tool, not to exceed 50% of total project cost.

5.1.2 New Jersey Smart Start Program

For this program, specific incentives for energy conservation measures are calculated on an individual basis utilizing the 2010 New Jersey Smart Start incentive program. This program provides incentives dependent upon mechanical and electrical equipment. If applicable, incentives from this program are reflected in the ECM summaries and attached appendices.

If the building qualifies and enters into the New Jersey Pay for Performance Program, all energy savings will be included in the total building energy reduction, and savings will be applied towards the Pay for Performance incentive. A project is not applicable for both New Jersey incentive programs.

5.1.3 Energy Efficient and Conservation Block Grant

Following is a brief summary of the Energy Efficient and Conservation Block Grant (EECBG) program. The Energy Efficiency and Conservation Block Grant Complete Program Application Package should be consulted for rules and regulations.

Additional funding is available to local government entities through the EECBG, a part of New Jersey's Clean Energy program (NJCEP). The grant is for local government entities only, and can offset the cost of energy reduction implementation to a maximum of \$20,000 per building.

This program is provided in conjunction with NJCEP funding and any utility incentive programs; the total amount of the three incentives combined cannot exceed 100% of project cost. Funds shall first be provided by NJCEP, followed by the EECBG and any utility incentives available to the customer. The total amount of the incentive shall be determined TRC Solutions, a third party technical consulting firm for the NJCEP.

In order to receive EECBG incentives, local governments must not have received a Direct Block Grant from the US Department of Energy. A list of the 512 qualifying municipalities and counties is provided on the NJCEP website. Qualifying municipalities must participate in at least one eligible Commercial & Industrial component of the NJCEP, utility incentive programs, or install building shell measures recommended by the Local Government Energy Audit Program. Eligible conservation programs through NJCEP include:

- Direct Install
- Pay for Performance
- NJ SmartStart Buildings for measures recommended by a Local Government Energy Audit (LGEA) or an equivalent audit completed within the last 12 months
- Applicants may propose to independently install building shell measures recommended by a LGEA or an equivalent audit. The audit must have been completed within the past 12 months.
- Any eligible utility energy efficiency incentive program

Most facilities owned or leased by an eligible local government within the State of New Jersey are eligible for this grant. Ineligible facilities include casinos or other gambling establishments, aquariums, zoos, golf courses, swimming pools, and any building owned or leased by the United States Federal Government. New construction is also ineligible.

5.1.4 ARRA Initiative "Energy Efficiency Programs through the Clean Energy Program"

The American Recovery and Reinvestment Act (ARRA) Initiative is available to New Jersey oil, propane, cooperative and municipal electric customers who do not pay the Societal Benefits Charge. This charge can be seen on any electric bill as the line item "SBC Charge." Applicants can participate in this program in conjunction with other New Jersey Clean Energy Program initiatives including Pay for Performance, Local Government Energy Audits, and Direct Install programs.

Funding for this program is dispersed on a first come, first serve basis until all funds are exhausted. The program does not limit the municipality to a minimum or maximum incentive, and the availability of funding cannot be determined prior to application. If the municipality meets all qualifications, the application must be submitted to TRC Energy Solutions for review. TRC will then determine the amount

of the incentive based on projected energy savings of the project. It is important to note that all applications for this incentive must be submitted before implementation of energy conservation measures.

Additional information is available on New Jersey's Clean Energy Program website.

5.1.5 Direct Install Program

The Direct Install Program targets small and medium sized facilities where the peak electrical demand does not exceed 200 kW in any of the previous 12 months. Buildings must be located in New Jersey and served by one of the state's public, regulated electric or natural gas utility companies. On a case-by-case basis, the program manager may accept a project for a customer that is within 10% of the 200 kW peak demand threshold.

The 200 kW peak demand threshold has been waived for local government entities that receive and utilize their Energy Efficiency and Conservation Block Grant as discussed in section 5.1.3 in conjunction with Direct Install.

Direct Install is funded through New Jersey's Clean Energy Program and is designed to provide capital for building energy upgrade projects to fast track implementation. The program will pay up to 60% of the costs for lighting, HVAC, motors, natural gas, refrigeration, and other equipment upgrades with higher efficiency alternatives. If a building is eligible for this funding, the Direct Install Program can significantly reduce the implementation cost of energy conservation projects.

The program pays a maximum amount of \$50,000 per building, and up to \$250,000 per customer per year. Installations must be completed by a Direct Install participating contractor, a list of which can be found on the New Jersey Clean Energy Website at <http://www.njcleanenergy.com>. Contractors will coordinate with the applicant to arrange installation of recommended measures identified in a previous energy assessment, such as this document.

5.2 Building Incentives

5.2.1 New Jersey Pay For Performance Program

Under Incentive #1 of the New Jersey Pay for Performance Program, the Municipal Building is eligible for about \$700 toward development of an Energy Reduction Plan. When calculating the total amount under Incentives #2 and #3, all energy conservation measures are applicable as the amount received is based on building wide energy improvements. Since the overall energy reduction for the building is estimated to exceed the 15% minimum, the building is eligible to receive \$15,700 based as discussed above in section 5.1.1. See Appendix F for further calculation.

5.2.2 New Jersey Smart Start Program

The building is eligible for several incentives available under New Jersey Smart Start Programs. The total amount of all qualified incentives is about \$2,100 and includes new lighting and boilers.

5.2.3 Energy Efficient and Conservation Block Grant

The building is owned by local government which makes it eligible for this incentive. The incentive amount is determined by TRC Solutions and is not calculable at this time. Further information about this incentive, including the application, can be found at:

<http://www.njcleanenergy.com/commercial-industrial/programs/energy-efficiency-and-conservation-block-grants>

5.2.4 ARRA Initiative “Energy Efficiency Programs through the Clean Energy Program”

The Municipal Building pays the Societal Benefits charge on their monthly utility bill and therefore is not eligible for this incentive.

5.2.5 Direct Install Program

The building is potentially eligible to receive funding from the Direct Install Program. This money can be in conjunction with the Energy Efficiency and Conservation Block Grant. The total implementation cost for the eligible ECMs for Direct Install funding is about \$190,100. This includes new boilers and lighting fixtures. This program would pay 60% of these initial costs or \$114,100. This funding has the potential to significantly affect the payback periods of Energy Conservation Measures. For the Municipal Building, the Direct Install Program brings the simple payback to approximately 18 years.

6.0 ALTERNATIVE ENERGY SCREENING EVALUATION

6.1 Geothermal

Geothermal heat pumps (GHP) transfer heat between the constant temperature of the earth and the building to maintain the building's interior space conditions. Below the surface of the earth throughout New Jersey the temperature remains in the low 50°F range throughout the year. This stable temperature provides a source for heat in the winter and a means to reject excess heat in the summer. With GHP systems, water is circulated between the building and the piping buried in the ground. The ground heat exchanger in a GHP system is made up of a closed or open loop pipe system. Most common is the closed loop in which high density polyethylene pipe is buried horizontally at 4-6 feet deep or vertically at 100 to 400 feet deep. These pipes are filled with an environmentally friendly antifreeze/water solution that acts as a heat exchanger. In the summer, the water picks up heat from the building and moves it to the ground. In the winter the system reverses and fluid picks up heat from the ground and moves it to the building. Heat pumps make collection and transfer of this heat to and from the building possible.

The building uses 3 gas-fired, hot water boilers and split system AHUs with DX cooling to meet the HVAC requirements. The air handlers would have to be replaced and significant piping changes would need to occur so this measure is not recommended.

6.2 Solar

6.2.1 Photovoltaic Rooftop Solar Power Generation

The facility was evaluated for the potential to install rooftop photovoltaic (PV) solar panels for power generation. Present technology incorporates the use of solar cell arrays that produce direct current (DC) electricity. This DC current is converted to alternating current (AC) with the use of an electrical device known as an inverter. The building's roof has sufficient room to install a solar cell array. A structural analysis would be required to determine if the roof framing could support a cell array.

The PVWATTS solar power generation model was utilized to calculate PV power generation. The New Jersey Clean Power Estimator provided by the New Jersey Clean Energy Program is presently being updated; therefore, the site recommended use of the PVWATT solar grid analyzer version 1. The closest city available in the model is Atlantic City, New Jersey and a fixed tilt array type was utilized to calculate energy production. The PVWATT solar power generation model is provided in Appendix G.

The State of New Jersey incentives for non-residential PV applications is \$0.75/watt up to 30 kW of installed PV array with a maximum system capacity of 50 kW. Federal tax credits are also available for renewable energy projects up to 30% of installation cost. Municipalities do not pay federal taxes; therefore, would not be able to utilize the federal tax credit incentive.

Installation of (PV) arrays in the state New Jersey will allow the owner to participate in the New Jersey solar renewable energy certificates program (SREC). This is a program that has been set up to allow entities with large amounts of environmentally unfriendly emissions to purchase credits from zero emission (PV) solar-producers. An alternative compliance penalty (ACP) is paid for by the high emission producers and is set each year on a declining scale of 3% per year. One SREC credit is equivalent to 1000 kilowatt hours of PV electrical production; these credits can be traded for period of 15 years from the date of installation. The cost of the ACP penalty for 2009 is \$700; this is the amount that must be paid per SREC by the high emission producers. The expected dollar amount that will be paid to the PV producer for 2010 is expected to be \$600/SREC credit. Payments that will be received from the PV

producer will change from year to year dependent upon supply and demand. Renewable Energy Consultants is a third party SREC broker that has been approved by the New Jersey Clean Energy Program. As stated above there is no definitive way to calculate an exact price that will be received by the PV producer per SREC over the next 15 years. Renewable Energy Consultants estimated an average of \$487/ SREC per year and this number was utilized in the cash flow for this report.

The building roof size justifies the use of a 10kW solar array. The system costs for PV installations were estimated as \$7 per watt or \$7,000 per kW of installed system. This has increased in the past few years due to the rise in national demand for PV power generator systems. Other cost considerations will also need to be considered. PV panels have an approximate 20 year life span; however, the inverter device that converts DC electricity to AC has a life span of 10 to 12 years and will need to be replaced multiple times during the useful life of the PV system.

The implementation cost and savings related to this ECM are presented in Appendix G and summarized as follows:

Photovoltaic (PV) Rooftop Solar Power Generation – 10 kW System

| Budgetary Cost | Annual Utility Savings | | | | Total Savings | New Jersey Renewable Energy Incentive* | New Jersey Renewable SREC** | Payback (without incentive) | Payback (with incentives) |
|-------------------|------------------------|--------|-------------|-------|------------------|--|--------------------------------------|-----------------------------------|---------------------------------|
| | Electricity | | Natural Gas | Total | | | | | |
| | kW | kWh | Therms | \$ | | | | | |
| \$ | | | | \$ | \$ | \$ | \$ | Years | Years |
| 70,000 | 0 | 12,503 | 0 | 1,800 | 1,800 | 10,000 | 6,100 | >25 | 7.6 |

*Incentive based on New Jersey Renewable Energy Program for non-residential applications of \$0.75 per Watt of installed capacity

** Estimated Solar Renewable Energy Certificate Program (SREC) for 15 years at \$487/1000 kWh

While the payback period is within the parameters for recommended measures, further investigation of possible installation locations, required system maintenance, and local installation costs are suggested prior to consideration for implementation.

6.2.2 Solar Thermal Hot Water Plant

Active solar thermal systems use solar collectors to gather the sun’s energy to heat water, another fluid, or air. An absorber in the collector converts the sun’s energy into heat. The heat is then transferred by circulating water, antifreeze, or sometimes air to another location for immediate use or storage for later utilization. Applications for active solar thermal energy include providing hot water, heating swimming pools, space heating, and preheating air in residential and commercial buildings.

A standard solar hot water system is typically composed of solar collectors, heat storage vessel, piping, circulators, and controls. Systems are typically integrated to work alongside a conventional heating system that provides heat when solar resources are not sufficient. The solar collectors are usually placed on the roof of the building, oriented south, and tilted around the site’s latitude, to maximize the amount of radiation collected on a yearly basis.

Several options exist for using active solar thermal systems for space heating. The most common method involves using glazed collectors to heat a liquid held in a storage tank (similar to an active solar hot water system). The most practical system would transfer the heat from the panels to thermal storage tanks and transfer solar produced thermal energy to use for domestic hot water production. DHW is presently produced by a gas fired water heater and, therefore, this measure would offer natural gas savings.

Currently, an incentive is not available for installation of thermal solar systems. A Federal tax credit of 30% of installation cost for the thermal applications is available; however, the City of Linwood does not pay Federal taxes and, therefore, would not benefit from this program.

The implementation cost and savings related to this ECM are presented in Appendix H and summarized as follows:

Solar Thermal Domestic Hot Water Plant

| Budgetary Cost | Annual Utility Savings | | | Total Savings | New Jersey Renewable Energy Incentive | Payback (without incentive) | Payback (with incentive) |
|-------------------|------------------------|-----|-------------|------------------|--|-----------------------------------|-----------------------------|
| | Electricity | | Natural Gas | | | | |
| \$ | kW | kWh | Therms | \$ | \$ | Years | Years |
| 27,100 | 0 | 0 | 170 | 200 | 200 | NA | >25 |

* No incentive is available in New Jersey at this time.

This measure is not recommended.

6.3 Wind

Small wind turbines use a horizontal axis propeller, or rotor, to capture the kinetic energy of the wind and convert it into rotary motion to drive a generator which usually is designed specifically for the wind turbine. The rotor consists of two or three blades, usually made from wood or fiberglass. These materials give the turbine the needed strength and flexibility, and have the added advantage of not interfering with television signals. The structural backbone of the wind turbine is the mainframe, and includes the slip-rings that connect the wind turbine, which rotates as it points into changing wind directions, and the fixed tower wiring. The tail aligns the rotor into the wind.

To avoid turbulence and capture greater wind energy, turbines are mounted on towers. Turbines should be mounted at least 30 feet above any structure or natural feature within 300 feet of the installation. Smaller turbines can utilize shorter towers. For example, a 250-watt turbine may be mounted on a 30-50 foot tower, while a 10 kW turbine will usually need a tower of 80-120 feet. Tower designs include tubular or latticed, guyed or self-supporting. Wind turbine manufacturers also provide towers.

The New Jersey Clean Energy Program for small wind installations has designated numerous pre-approved wind turbines for installation in the State of New Jersey. Incentives for wind turbine installations are based on kilowatt hours saved in the first year. Systems sized under 16,000 kWh per year of production will receive a \$3.20 per kWh incentive. Systems producing over 16,000 kWh will receive \$51,200 for the first 16,000 kWh of production with an additional \$0.50 per kWh up to a maximum cap of 750,000 kWh per year. Federal tax credits are also available for renewable energy projects up to 30% of installation cost for systems less than 100 kW. However, as noted previously, municipalities do not pay federal taxes and is, therefore, not eligible for the tax credit incentive.

The most important part of any small wind generation project is the mean annual wind speed at the height of which the turbine will be installed. The building may have enough wind speed to support a wind turbine. A wind speed map and aerial site photo are included in Appendix I. The location of the building outside of a dense residential area and good potential for wind speed make this an option to explore further with vendors.

6.4 Combined Heat and Power Generation (CHP)

Combined heat and power, cogeneration, is self-production of electricity on-site with beneficial recovery of the heat byproduct from the electrical generator. Common CHP equipment includes reciprocating engine-driven, micro turbines, steam turbines, and fuel cells. Typical CHP customers include industrial, commercial, institutional, educational institutions, and multifamily residential facilities. CHP systems that are commercially viable at the present time are sized approximately 50 kW and above, with numerous options in blocks grouped around 300 kW, 800 kW, 1,200 kW and larger. Typically, CHP systems are used to produce a portion of the electricity needed by a facility some or all of the time, with the balance of electric needs satisfied by purchase from the grid.

This measure is not recommended since the facility cannot use the waste heat in the summer months.

6.5 Biomass Power Generation

Biomass power generation is a process in which waste organic materials are used to produce electricity or thermal energy. These materials would otherwise be sent to the landfill or expelled to the atmosphere. To participate in NJCEP's Customer On-Site Renewable Energy program, participants must install an on-site sustainable biomass or fuel cell energy generation system. Incentives for bio-power installations are available to support up to 1MW-dc of rated capacity.

*Class I organic residues are eligible for funding through the NJCEP CORE program. Class I wastes include the following renewable supply of organic material:

- Wood wastes not adulterated with chemicals, glues or adhesives
- Agricultural residues (corn stover, rice hulls or nut shells, manures, poultry litter, horse manure, etc) and/or methane gases from landfills
- Food wastes
- Municipal tree trimming and grass clipping wastes
- Paper and cardboard wastes
- Non adulterated construction wood wastes, pallets

The NJDEP evaluates biomass resources not identified in the RPS.

Examples of eligible facilities for a CORE incentive include:

- Digestion of sewage sludge
- Landfill gas facilities
- Combustion of wood wastes to steam turbine
- Gasification of wood wastes to reciprocating engine
- Gasification or pyrolysis of bio-solid wastes to generation equipment

* from NJOCE Website

This measure is not recommended due to of noise issues and because the building does not have a steady waste stream to fuel the power generation system

7.0 EPA PORTFOLIO MANAGER

The United States Environmental Protection Agency (EPA) is a federal agency in charge of regulating environment waste and policy in the United States. The EPA has released the EPA Portfolio Manager for public use. The program is designed to allow property owners and managers to share, compare and improve upon their facility's energy consumption. Inputting such parameters as electricity, heating fuel, building characteristics and location into the website based program generates a naturalized energy rating score out of 100. Once an account is registered, monthly utility data can be entered to track the savings progress and retrieve an updated energy rating score on a monthly basis.

The building has one gas meter and one electric meter for both the municipal section and police section. Since the police area is over 10% of the total size of the building, the EPA Portfolio Manager software cannot provide a score.

A full EPA Energy Star Portfolio Manager Report is located in Appendix J.

The user name and password for the building's EPA Portfolio Manager Account has been provided to Hank Kolakowski.

8.0 CONCLUSIONS & RECOMMENDATIONS

The energy audit conducted by CHA at the Linwood Municipal Building in Linwood, New Jersey identified potential ECMs for night setback and lighting replacement. Potential annual savings of \$4,500 may be realized for the recommended ECMs, with a summary of the costs, savings, and paybacks as follows:

ECM-3 Night Setback

| Budgetary Cost | Annual Utility Savings | | | | | Estimated Maintenance Savings | Total Savings | ROI | Potential Incentive* | Payback (without Incentive) | Payback (with Incentive) |
|-------------------|------------------------|-------|-------------|--------|-------|-------------------------------------|------------------|-----|-------------------------|-----------------------------------|--------------------------------|
| | Electricity | | Natural Gas | Water | Total | | | | | | |
| | \$ | kW | kWh | Therms | kGals | | | | | | |
| 1,000 | 0 | 7,000 | 2,570 | 0 | 4,200 | 0 | 4,200 | 65 | NA | 0.2 | NA |

*There is no current incentive available through the NJ Smart Start Program. See section 5.0 for other incentive opportunities.

ECM-4 Lighting Replacements

| Budgetary Cost | Annual Utility Savings | | | | | Estimated Maintenance Savings | Total Savings | ROI | Potential Incentive* | Payback (without Incentive) | Payback (with Incentive) |
|-------------------|------------------------|-------|-------------|--------|-------|-------------------------------------|------------------|-----|-------------------------|-----------------------------------|--------------------------------|
| | Electricity | | Natural Gas | Water | Total | | | | | | |
| | \$ | kW | kWh | Therms | kGals | | | | | | |
| 2,900 | 0 | 2,200 | 0 | 0 | 300 | 0 | 300 | 0.8 | 600 | 9.7 | 7.7 |

*Incentive shown is per the New Jersey Smart Start Program, 2010 Prescriptive Lighting Application. See section 5.0 for other incentive opportunities.

APPENDICES

- A Utility Usage Analysis
 - B ECM-1 Increase Ceiling Insulation
 - C ECM-2 Replace Boilers
 - D ECM-3 Night Setback
 - E ECM-4 Lighting Replacement
 - F New Jersey Pay For Performance Incentive Program
 - G Photovoltaic (PV) Rooftop Solar Power Generation
 - H Solar Thermal Domestic Hot Water Plant
 - I Wind
 - J EPA Portfolio Manager
 - K Equipment Inventory
 - L Block Load Models
-

APPENDIX A

Utility Usage Analysis



City of Linwood
 CHA Project Number: 22215
 City Hall

Oak & Poplar Ave
 Account Number: 0100 5739 9999
 Meter Number: 8084459

| Month | Consumption | | Charges | | | | Unit Costs | | | |
|----------------|-------------|------|-------------|-------------|---------------|-------------|------------------|-----------------------|----------------------|----------------|
| | (kWh) | (kW) | Total (\$) | Supply (\$) | Delivery (\$) | Demand (\$) | Consumption (\$) | Blended Rate (\$/kWh) | Consumption (\$/kWh) | Demand (\$/kW) |
| June-09 | 26,320 | 73.2 | \$4,389.18 | \$3,522.71 | \$866.47 | \$0.00 | \$4,389.18 | 0.1668 | 0.1668 | - |
| July-09 | 34,080 | 72.4 | \$5,503.08 | \$4,521.71 | \$981.37 | \$0.00 | \$5,503.08 | 0.1615 | 0.1615 | - |
| August-09 | 34,080 | 72.4 | \$5,503.08 | \$3,469.02 | \$844.23 | \$0.00 | \$5,503.08 | 0.1615 | 0.1615 | - |
| September-09 | 26,120 | 66.4 | \$4,313.25 | \$2,838.92 | \$852.28 | \$0.00 | \$4,313.25 | 0.1651 | 0.1651 | - |
| October-09 | 25,560 | 66.4 | \$3,691.20 | \$2,943.14 | \$796.35 | \$0.00 | \$3,691.20 | 0.1444 | 0.1444 | - |
| November-09 | 26,720 | 57.2 | \$3,739.49 | \$2,947.03 | \$850.20 | \$0.00 | \$3,739.49 | 0.1400 | 0.1400 | - |
| December-09 | 26,640 | 57.2 | \$3,797.23 | \$2,690.54 | \$727.22 | \$0.00 | \$3,797.23 | 0.1425 | 0.1425 | - |
| January-10 | 24,440 | 48.8 | \$3,417.76 | \$2,748.31 | \$774.98 | \$0.00 | \$3,417.76 | 0.1398 | 0.1398 | - |
| February-10 | 24,920 | 46.0 | \$3,098.97 | \$2,387.20 | \$711.77 | \$0.00 | \$3,098.97 | 0.1244 | 0.1244 | - |
| March-10 | 21,560 | 47.2 | \$4,288.27 | \$3,468.81 | \$819.46 | \$0.00 | \$4,288.27 | 0.1989 | 0.1989 | - |
| April-10 | 23,840 | 64.4 | \$4,394.46 | \$3,468.81 | \$925.65 | \$0.00 | \$4,394.46 | 0.1843 | 0.1843 | - |
| Total | 294,280 | | \$46,135.97 | \$35,006.20 | \$9,149.98 | \$0.00 | \$46,135.97 | 0.1568 | 0.1568 | - |
| Most Recent Yr | | | \$46,135.97 | \$35,006.20 | \$9,149.98 | \$0.00 | \$46,135.97 | 0.1568 | 0.1568 | - |

| | | | | |
|-------|----|----|---|------------|
| 40 | 60 | 15 | 1 | 36,000 |
| 30 | 60 | 15 | 1 | 27,000 |
| 50 | 70 | 15 | 1 | 52,500 |
| Total | | | | 151,500 CF |

"% of 180
"% of 90

120.0

Walls

| | Width (ft) | Height (ft) | Quantity | Area (SF) | Lineal Feet |
|-------|------------|-------------|----------|-----------|-------------|
| North | 40.0 | 25.0 | 2 | 2000.0 | 260.0 |
| | 40.0 | 9.0 | 1 | 360.0 | 98.0 |
| | | | | 0.0 | 0.0 |
| | | | | 0.0 | 0.0 |
| | | | | 0.0 | 0.0 |
| | 80.0 | | | 2360.0 | 358.0 |

All wall quantities must remain equal to 1

Ave. height
29.5

Average height wall automatically linked

| | | | | | |
|------|-------|------|---|--------|-------|
| East | 115.0 | 25.0 | 1 | 2875.0 | 280.0 |
| | 110.0 | 9.0 | 1 | 990.0 | 238.0 |
| | | | | 0.0 | 0.0 |
| | | | | 0.0 | 0.0 |
| | | | | 0.0 | 0.0 |
| | 225.0 | | | 3865.0 | 518.0 |

Ave. height
17.2

Average height wall automatically linked

| | | | | | |
|-------|-------|------|---|--------|-------|
| South | 120.0 | 25.0 | 1 | 3000.0 | 290.0 |
| | | | 1 | 0.0 | 0.0 |
| | | | | 0.0 | 0.0 |
| | | | | 0.0 | 0.0 |
| | | | | 0.0 | 0.0 |
| | 120.0 | | | 3000.0 | 290.0 |

Ave. height
25.0

Average height wall automatically linked

| | | | | | |
|------|-------|------|---|--------|-------|
| West | 100.0 | 25.0 | 1 | 2500.0 | 250.0 |
| | 110.0 | 9.0 | 1 | 990.0 | 238.0 |
| | | | | 0.0 | 0.0 |
| | | | | 0.0 | 0.0 |
| | | | | 0.0 | 0.0 |
| | 210.0 | | | 3490.0 | 488.0 |

Ave. height
16.6

Average height auto linked to block load sheet

Windows

| | Width (ft) | Height (ft) | Quantity | Area (SF) | Lineal Feet |
|-------|------------|-------------|-----------|-----------|-------------|
| North | 3.0 | 5.0 | 2 | 30.0 | 32.0 |
| | | | | 0.0 | 0.0 |
| | | | | 0.0 | 0.0 |
| | | | | 0.0 | 0.0 |
| | | | | 0.0 | 0.0 |
| | | | Sub-total | 30.0 | 32.0 |

| | | | | | |
|------|-----|-----|-----------|-------|-------|
| East | 4.0 | 7.0 | 5 | 140.0 | 110.0 |
| | 3.0 | 5.0 | 5 | 75.0 | 80.0 |
| | | | | 0.0 | 0.0 |
| | | | | 0.0 | 0.0 |
| | | | | 0.0 | 0.0 |
| | | | Sub-total | 215.0 | 190.0 |

| | | | | | |
|-------|-----|-----|-----------|-------|------|
| South | 6.0 | 6.0 | 4 | 144.0 | 96.0 |
| | | | | 0.0 | 0.0 |
| | | | | 0.0 | 0.0 |
| | | | | 0.0 | 0.0 |
| | | | | 0.0 | 0.0 |
| | | | Sub-total | 144.0 | 96.0 |

| | | | | | |
|------|-----|-----|-----------|-------|-------|
| West | 4.0 | 7.0 | 5 | 140.0 | 110.0 |
| | 3.0 | 5.0 | 6 | 90.0 | 96.0 |
| | | | | 0.0 | 0.0 |
| | | | | 0.0 | 0.0 |
| | | | | 0.0 | 0.0 |
| | | | Sub-total | 230.0 | 206.0 |

Total 619.0 524.0

LF/SF
0.85

Building Volume Calculator

| Width(ft) | Length (ft) | Height(ft) | Count | Volume (cf) |
|-----------|-------------|------------|-------|-------------|
| 100 | 40 | 9 | 1 | 36,000 |

City of Linwood, NJ
 CHA #22215
 Building: City Hall

Doors

| | Width (ft) | Height (ft) | Quantity | Area (SF) | Lineal Feet |
|-------|------------|-------------|-----------|-----------|-------------|
| North | | | | 0.0 | 0.0 |
| | | | | 0.0 | 0.0 |
| | | | | 0.0 | 0.0 |
| | | | | 0.0 | 0.0 |
| | | | | 0.0 | 0.0 |
| | | | | 0.0 | 0.0 |
| | | | Sub-total | 0.0 | 0.0 |
| East | 3.0 | 5.0 | 3 | 45.0 | 48.0 |
| | | | | 0.0 | 0.0 |
| | | | | 0.0 | 0.0 |
| | | | Sub-total | 45.0 | 48.0 |
| South | 7.0 | 6.0 | 1 | 42.0 | 26.0 |
| | | | | 0.0 | 0.0 |
| | | | | 0.0 | 0.0 |
| | | | | 0.0 | 0.0 |
| | | | Sub-total | 42.0 | 26.0 |
| West | | | | 0.0 | 0.0 |
| | | | | 0.0 | 0.0 |
| | | | | 0.0 | 0.0 |
| | | | Sub-total | 0.0 | 0.0 |

Total 87.0 74.0

| |
|---------------|
| LF/SF 0.85 |
|---------------|

HEAT GAIN/LOSS WORKSHEET

Project Name: City of Unwood, NJ
 Location: Unwood, NJ
 Building Name: City Hall
 Engineer: Frank Cutitta

Project No.: GHA #22215
 Site Elevation: 17 Feet
 Date: 12/01/10

Specific Volume: 14.00 CF#

Building/Facility Designation: City Hall

LATENT COOLING LOADS

Infiltration

| | | Infiltration Factor | Air Density | Humidity Ratio Dif. |
|-------------|-----------|---------------------|-------------|---------------------|
| Walls | 20,285 SF | 0.15 CFM/SF | 4.629 | 0.0042 #/h |
| Doors | 87 SF | 0.20 CFM/LF | 4.629 | 0.0042 #/h |
| Windows | 619 SF | 0.20 CFM/LF | 4.629 | 0.0042 #/h |
| Ventilation | 2,000 cfm | | 4.629 | 0.0042 #/h |
| People | 20 people | 1.00 time in space | | 250 Btu/hr/person |

| Room Heat Gain | |
|----------------|-------|
| 59,755 | Btu/h |
| 291 | Btu/h |
| 2,058 | Btu/h |
| 39,277 | Btu/h |
| 5,000 | Btu/h |

106,380 Btu/h

Cooling Load Summary

| | Sensible | Latent | Total | SHR= |
|-----------------------------|----------------|----------------|----------------|------|
| Temperature Dependent Gains | 208,448 | 106,380 | 314,828 | |
| Temperature Indep. Gains | 81,304 | 0 | 81,304 | 0.73 |
| Total | 289,752 | 106,380 | 396,132 | |

Building Cooling Load: 33.0 Tons at 402 SF/Ton

Building Air Flow to Condition Space based on a 12°F Temp Rise is

22,127 CFM
1.67 CFM/sf

HEATING CALCULATION

CONDUCTION

| | NET AREA (SF) | U-VALUE | Heating Load Temp. Dif. |
|----------------|---------------|---------|-------------------------|
| North Exposure | 2,330 | 0.07 | 58 |
| East Exposure | 3,605 | 0.07 | 58 |
| South Exposure | 2,814 | 0.07 | 58 |
| West Exposure | 3,260 | 0.07 | 58 |
| Fenestration | 619 | 0.50 | 58 |
| Roof | 13,285 | 0.06 | 58 |
| Doors | 87 | 0.14 | 58 |
| Ceiling | 13,285 | 0.14 | 0 |
| Partition | 0 | 0.05 | 0 |
| Floor | 13,285 | 0.04 | 10 |

Room Heat Gain

| | |
|--------|-------|
| 8,888 | Btu/h |
| 13,752 | Btu/h |
| 10,735 | Btu/h |
| 12,436 | Btu/h |
| 17,951 | Btu/h |
| 43,808 | Btu/h |
| 705 | Btu/h |
| 0 | Btu/h |
| 0 | Btu/h |
| 5,314 | Btu/h |

Ventilation and Infiltration

| | NET AREA (SF) | Infiltration Factor | Coef | Temp. Difference | Air Flow |
|--|---------------|---------------------|------|------------------|------------------|
| Walls | 12,009 SF | 0.15 CFM/SF | 1.04 | 58 | 1,801 cfm |
| Doors | 87 SF | 0.20 CFM/LF | 1.04 | 58 | 15 cfm |
| Windows | 619 SF | 0.20 CFM/LF | 1.04 | 58 | 105 cfm |
| Ventilation Load | 2,000 cfm | | 1.04 | 58 | 2,000 cfm |
| Total Ventilation & Infiltration Load | | | | | 3,921 cfm |

Room Heat Gain

| | |
|---------|-------|
| 109,055 | Btu/h |
| 896 | Btu/h |
| 8,345 | Btu/h |
| 130,766 | Btu/h |
| 247,064 | Btu/h |

Building Heating Load: 360,654 btu/h
27.1 btu/sf

HEAT GAIN/LOSS WORKSHEET

Project Name: City of Linwood, NJ
 Location: Linwood, NJ
 Building Name: City Hall
 Engineer: Frank Cutina

Project No.: CHA#22215
 Site Elevation: 17 Feet
 Date: 12/01/10

Specific Volume: 14.00 CF/#

Building/Facility Designation: City Hall

COOLING HEAT GAINS TO THE ROOM - SENSIBLE

SOLAR GAINS

| WINDOWS | AREA (SF) | SHGF | Shade Coef | Cooling Load Factor | Glass Type | Solar Heat Gain |
|----------------|-----------|--------------|------------|---------------------|--------------|---------------------|
| North Exposure | 30 | 38 btu/h/sf | 0.8 | 0.75 | Glass Type C | 684 Btu/hr |
| East Exposure | 215 | 216 btu/h/sf | 0.8 | 0.31 | Glass Type C | 11,517 Btu/hr |
| South Exposure | 144 | 225 btu/h/sf | 0.8 | 0.58 | Glass Type C | 15,034 Btu/hr |
| West Exposure | 230 | 216 btu/h/sf | 0.8 | 0.29 | Glass Type C | 11,526 Btu/hr |
| | | | | | | 36,760 Btu/h |

CONDUCTION

| | NET AREA (SF) | U-VALUE | Cooling Load Temp. Dif. | Return Air Factor | Room Heat Gain |
|---------------------|---------------|---------|-------------------------|-------------------|----------------|
| North Exposure | 690 | 0.07 | 20 °F | 1.0 | 908 Btu/hr |
| East Exposure | 1,765 | 0.07 | 39 °F | 1.0 | 4,527 Btu/hr |
| South Exposure | 894 | 0.07 | 27 °F | 1.0 | 1,588 Btu/hr |
| West Exposure | 1,660 | 0.07 | 22 °F | 1.0 | 2,402 Btu/hr |
| Roof | 13,285 | 0.06 | 73 °F | 1.0 | 55,138 Btu/hr |
| Fenestration | 619 | 0.50 | 26 °F | | 8,047 Btu/hr |
| Doors | 87 | 0.14 | 27 °F | | 328 Btu/hr |
| Ceiling | 13,285 | 0.14 | 0 °F | | 0 Btu/hr |
| Partition | 0 | 0.05 | 0 °F | | 0 Btu/hr |
| Floor | 13,285 | 0.04 | 0 °F | | 0 Btu/hr |
| 72,938 Btu/h | | | | | |

INTERNAL HEAT GAINS (all loads below are based on Occupied Periods)

| | | | | |
|------------------------|-------------------------------|----------------------|-----------|---------------------|
| Lights | 1.25 w/sf x 13,285 Occ Area = | 16.6 kW x 3.4x | 1.0 RAF = | 58,677 Btu/h |
| Plug Load | 0.25 w/sf x 13,285 Occ Area = | 3.3 kW x 3.4x | 1.0 RAF = | 11,335 Btu/h |
| People | 20 people x 255 btu/person x | 100% time in space = | | 5,100 Btu/h |
| Computer Work Stations | 20 Units x | 120 W/Unit x 3414 = | | 8,191 Btu/h |
| Equipment | 0.0 kW x 3,413 = | | | 0 Btu/h |
| Misc. | | | | 0 Btu/h |
| | | | | 81,304 Btu/h |

VENTILATION AND INFILTRATION

| | Infiltration Factor | Perimeter Ratio | Coef | Temp. Diff. | Room Heat Gain |
|--------------|---------------------|-----------------|------|-------------|---------------------|
| Walls | 0.15 CFM/SF | | 1.04 | 26 °F | 22,022 Btu/h |
| Doors | 0.20 CFM/LF | 0.85 LF/SF | 1.04 | 26 °F | 434 Btu/h |
| Windows | 0.20 CFM/LF | 0.85 LF/SF | 1.04 | 26 °F | 3,072 Btu/h |
| Ventilation | 2,000 cfm | | 1.04 | 26 °F | 58,620 Btu/h |
| Infiltration | 871 cfm | 0.3 AC/hr | | | 84,148 Btu/h |

COOLING HEAT GAINS TO THE RA PLENUM - SENSIBLE

4,950

CONDUCTION

| | NET AREA (SF) | U-VALUE | Cooling Load Temp. Dif. | Return Air Factor | Room Heat Gain |
|---------------------|---------------|---------|-------------------------|-------------------|----------------|
| North Exposure | 1,640 | 0.07 | 20 | 1.0 | 2,157 Btu/hr |
| East Exposure | 1,840 | 0.07 | 39 | 1.0 | 4,720 Btu/hr |
| South Exposure | 1,920 | 0.07 | 27 | 1.0 | 3,410 Btu/hr |
| West Exposure | 1,500 | 0.07 | 22 | 1.0 | 2,315 Btu/hr |
| Roof | 13,285 | 0.06 | 73 | 0.0 | 0 Btu/hr |
| 12,602 Btu/h | | | | | |

INTERNAL HEAT GAINS

| | | | | |
|--------|-------------------------------|-----------------|------------|----------------|
| Lights | 1.25 w/sf x 13,285 Occ Area = | 16.6 kW x 3413x | 0.00 RAF = | 0 Btu/h |
| Misc. | | | | 0 Btu/h |
| | | | | 0 Btu/h |

SENSIBLE HEAT GAINS - TEMP. DEPENDENT

| | |
|------------------------------|----------------|
| Solar | 38,760 |
| Conduction to Room | 72,938 |
| Conduction to Plenum | 12,602 |
| Ventilation and Infiltration | 84,148 |
| Sub Total | 208,448 |

SENSIBLE HEAT GAINS - TEMP. INDEPENDENT

| | |
|--------------------------|---------------|
| Internal Gains to Room | 81,304 |
| Internal Gains to Plenum | 0 |
| Sub Total | 81,304 |

HEAT GAIN/LOSS WORKSHEET

Project Name: City of Linwood, NJ
 Location: Linwood, NJ
 Building Name: City Hall
 Engineer: Frank Cutitta

Project No.: CHA#22215
 Site Elevation: 8 Feet
 Date: 12/01/10
 Specific Volume: 14.00 CF/#

Building/Facility Designation: City Hall

| | | | |
|--------------------------------------|-----------|-------------------------------------|-----------|
| Outdoor Winter Design DB Temperature | 14 °F | Indoor Winter Design DB Temperature | 72 °F |
| Outdoor Summer Design DB Temperature | 91 °F | Indoor Summer Design DB Temperature | 85 °F |
| Outdoor Summer Design WB Temperature | 73 °F | Indoor Summer Design WB Temperature | 60 °F |
| Outdoor Summer Humidity Ratio | 0.0121 ## | Indoor Air (70°F) Humidity Ratio | 0.0079 ## |

ENVELOPE DESCRIPTIONS (Descriptions are from Interior to Exterior)

Walls (Select One - Type X)

| | R Value | Wall Type |
|--|---------|-----------|
| <input type="checkbox"/> Steel Siding, 4" Insulation, Steel Siding | 15.2 | 1 |
| <input type="checkbox"/> Plaster or Gypsum, frame construction, 5" Insulation, 1" stucco | 18.2 | 1 |
| <input type="checkbox"/> 4" WH CMU, 1" Insulation, Finished Exterior | 5.2 | 2 |
| <input type="checkbox"/> Plaster or Gypsum, frame construction, 3" Insulation, 8" LW CMU | 7.8 | 5 |
| <input type="checkbox"/> 4" Face Brick, 2" Concrete, 1" Insulation, Exterior Finish | 5.1 | 12 |
| <input type="checkbox"/> 4" Face Brick, 4" Concrete, 1" Insulation, Exterior Finish | 4.0 | 11 |
| <input type="checkbox"/> Interior Finish, 2" Insulation, 8" CMU, 4" Face Brick | 10.9 | 16 |
| <input type="checkbox"/> Finished Surface, 8" LW CMU (filled), Air Space, 4" Face Brick | 11.1 | 16 |
| <input type="checkbox"/> Stucco or Gypsum, 2.5" Insul, Face Brick | 14.3 | 10 |
| <input type="checkbox"/> OTHER | 15.0 | 16 |
| <input checked="" type="checkbox"/> U value calculator | 19.2 | |

Roofs (Select One)

| | R Value | Roof Type |
|---|---------|-----------|
| <input type="checkbox"/> OTHER | 25.0 | 1 |
| <input type="checkbox"/> Steel Deck, 5" Insul., BU Roof | 18.2 | 1 |
| <input type="checkbox"/> Attic Roof with 6" Insul. | 25.0 | 4 |
| <input type="checkbox"/> 4" HW Concrete Deck, BU Roof | 2.7 | 2 |
| <input type="checkbox"/> Ceiling, 3" Insulation, 4" Concrete Deck, BU Roof | 14.9 | 4 |
| <input type="checkbox"/> Ceiling, 4" Concrete Deck, 3" Insulation, BU Roof | 18.5 | 13 |
| <input type="checkbox"/> Ceiling, 4" Concrete Deck, 6" Insulation, BU Roof | 21.7 | 14 |
| <input type="checkbox"/> Ceiling, Wood Deck, 6" Insulation, Felt & Membrane | 22.7 | 10 |
| <input type="checkbox"/> Wood Deck, 6" Insulation, Felt & Membrane | 18.0 | |
| <input checked="" type="checkbox"/> U value calculator | 17.6 | |

Windows (Select One)

| | U Value |
|---|---------|
| <input type="checkbox"/> Aluminum Frame, 1/8" SP Glazing | 1.05 |
| <input type="checkbox"/> Aluminum Frame, 1/4" DP Glazing | 0.60 |
| <input type="checkbox"/> Aluminum Frame, 3/16" DP Glazing | 0.62 |
| <input checked="" type="checkbox"/> Aluminum Frame, 1/2" DP Glazing | 0.50 |
| <input type="checkbox"/> Skylights | 0.90 |
| <input type="checkbox"/> Other | |

| | No Storm |
|----------------------------|----------|
| Flat Glass | 1.05 |
| Flat Glass (e=6) | 1.00 |
| Flat Glass (e=0.4) | 0.90 |
| Flat Glass (e=0.2) | 0.77 |
| Double Glaze (3/16 in air) | 0.63 |
| Double Glaze (1/4 in air) | 0.60 |
| Double Glaze (1/2 in air) | 0.53 |
| Double Glaze (e=6) | 0.50 |
| Double Glaze (e=0.4) | 0.42 |
| Double Glaze (e=0.2) | 0.35 |
| Triple Glaze (1/4 in air) | 0.42 |
| Triple Glaze (1/2 in air) | 0.35 |

BUILDING CHARACTERISTICS

Roof Area: 13,285 SF
 Occupied Area: 13,285 SF

Return Plenum? n

| | Gross Wall Length | Average Wall Height | Ceiling Height | Window Area | Door Area | Net Wall Area |
|-------------------------------|-------------------|---------------------|----------------|-------------|-----------|---------------|
| North Exposure | 80 Ft | 29.5 Ft | 9.0 Ft | 30 SF | 0 SF | 2,330 SF |
| East Exposure | 225 Ft | 17.2 Ft | 9.0 Ft | 215 SF | 45 SF | 3,605 SF |
| South Exposure | 120 Ft | 25.0 Ft | 9.0 Ft | 144 SF | 42 SF | 2,814 SF |
| West Exposure | 230 Ft | 16.6 Ft | 9.0 Ft | 230 SF | 0 SF | 3,260 SF |
| Occupied Forced Ventilation | 2,000 cfm | 0.8 AC/hr | | | | |
| Unoccupied Forced Ventilation | 600 cfm | 0.2 AC/hr | | | | |

APPENDIX L

Block Load Models



New Jersey BPU Energy Audit Program
 CHA #22215
 City of Linwood - Municipal Building

| Description | QTY | Manufacturer Name | Model No. | Serial No. | Equipment Type / Utility | Capacity/Size | Location | Areas Served | Date Installed | Remaining Useful Life (years) | Other Info. |
|-----------------------|-----|-------------------|-----------------|----------------|--------------------------|------------------|-------------------|-------------------|----------------|-------------------------------|-----------------------|
| HW Boiler | 2 | Burnham | 808 B-W 1 | 16001706 | | 462MBH/369.5 MBH | Boiler Room | Municipal | | 0 | |
| HW Pump - 1 | 1 | | | | | 3 HP | Boiler Rm | Municipal | | 10 | |
| HW Pump - 2 | 1 | | | | | 3 HP | Boiler Rm | Municipal | | 10 | |
| HW Boiler | 1 | Well McLath | GU-6 Series 4 | | | 175 MBH | MER | Police Wing | | 0 | |
| Air Handling Unit - 1 | 1 | Carrier | 40RM-024-B511YC | 22003F33794 | | | | Municipal Wing | | 15 | |
| Air Handling Unit - 2 | 1 | Carrier | | | | | | Court Room | | 15 | |
| Air Handling Unit - 3 | 1 | Trane | Climate Changer | K90M37381 | | | | Police Department | | 0 | |
| Air Handling Unit - 4 | 1 | | | | | | | | | | |
| Air Handling Unit - 5 | 1 | | | | | | | | | | |
| Condensing Unit - 1 | 1 | Rudd | RAWL-240CAZ | 7931F23100 809 | | | | Municipal Wing | New | 20 | 3 fans @ 1/3HP |
| Condensing Unit - 2 | 1 | Carrier | 35ARZ008-501 | 604050046 | | | | Court Room | | | 1 comp 2fans |
| Condensing Unit - 3 | 1 | Trane | TTA150B300EA | 3335TEKAD | | | | | | 10 | Police Department |
| Condensing Unit - 4 | 1 | Sano CW2432 | | | | | | | | 10 | Police Dispatch |
| Condensing Unit - 5 | 1 | | | | | | | | | | |
| Exhaust Fan - 1 | 2 | Greenheck | CSP-226 | | | 315 CFM | 1st Fir Municipal | M&W Toilet | | | |
| Exhaust Fan - 2 | 2 | Greenheck | CSP-224 | | | 272 CFM | 2nd Fir Municipal | JC & Kitchen | | | |
| Exhaust Fan - 3 | 1 | Tamparack | | | | 115 CFM | 3rd Fir Municipal | | | | |
| Generator | 1 | | | | Fuel Oil | 120 KW | Basement | Basement | | | Comp. 6.8 amps @ 115V |
| Dehumidifier | 2 | Sania Fe | | | Electric | Fan 250 CFM | | | | | |
| Domestic HW Heater | 1 | AO Smith | | | Electric | 1.5 KW | | Police | | | 30 Gallon |
| Domestic HW Heater | 1 | Rheem | | 0295GG03782 | Natural Gas | 75 MBH | | Municipal Wing | | | 75 Gallon |

APPENDIX K

Equipment Inventory

| Item No. | Description | Quantity | Unit Cost | Total Cost |
|----------|-------------|----------|-----------|------------|
| 1 | ... | ... | ... | ... |
| 2 | ... | ... | ... | ... |
| 3 | ... | ... | ... | ... |
| 4 | ... | ... | ... | ... |
| 5 | ... | ... | ... | ... |
| 6 | ... | ... | ... | ... |
| 7 | ... | ... | ... | ... |
| 8 | ... | ... | ... | ... |
| 9 | ... | ... | ... | ... |
| 10 | ... | ... | ... | ... |
| 11 | ... | ... | ... | ... |
| 12 | ... | ... | ... | ... |
| 13 | ... | ... | ... | ... |
| 14 | ... | ... | ... | ... |
| 15 | ... | ... | ... | ... |
| 16 | ... | ... | ... | ... |
| 17 | ... | ... | ... | ... |
| 18 | ... | ... | ... | ... |
| 19 | ... | ... | ... | ... |
| 20 | ... | ... | ... | ... |
| 21 | ... | ... | ... | ... |
| 22 | ... | ... | ... | ... |
| 23 | ... | ... | ... | ... |
| 24 | ... | ... | ... | ... |
| 25 | ... | ... | ... | ... |
| 26 | ... | ... | ... | ... |
| 27 | ... | ... | ... | ... |
| 28 | ... | ... | ... | ... |
| 29 | ... | ... | ... | ... |
| 30 | ... | ... | ... | ... |
| 31 | ... | ... | ... | ... |
| 32 | ... | ... | ... | ... |
| 33 | ... | ... | ... | ... |
| 34 | ... | ... | ... | ... |
| 35 | ... | ... | ... | ... |
| 36 | ... | ... | ... | ... |
| 37 | ... | ... | ... | ... |
| 38 | ... | ... | ... | ... |
| 39 | ... | ... | ... | ... |
| 40 | ... | ... | ... | ... |
| 41 | ... | ... | ... | ... |
| 42 | ... | ... | ... | ... |
| 43 | ... | ... | ... | ... |
| 44 | ... | ... | ... | ... |
| 45 | ... | ... | ... | ... |
| 46 | ... | ... | ... | ... |
| 47 | ... | ... | ... | ... |
| 48 | ... | ... | ... | ... |
| 49 | ... | ... | ... | ... |
| 50 | ... | ... | ... | ... |
| 51 | ... | ... | ... | ... |
| 52 | ... | ... | ... | ... |
| 53 | ... | ... | ... | ... |
| 54 | ... | ... | ... | ... |
| 55 | ... | ... | ... | ... |
| 56 | ... | ... | ... | ... |
| 57 | ... | ... | ... | ... |
| 58 | ... | ... | ... | ... |
| 59 | ... | ... | ... | ... |
| 60 | ... | ... | ... | ... |
| 61 | ... | ... | ... | ... |
| 62 | ... | ... | ... | ... |
| 63 | ... | ... | ... | ... |
| 64 | ... | ... | ... | ... |
| 65 | ... | ... | ... | ... |
| 66 | ... | ... | ... | ... |
| 67 | ... | ... | ... | ... |
| 68 | ... | ... | ... | ... |
| 69 | ... | ... | ... | ... |
| 70 | ... | ... | ... | ... |
| 71 | ... | ... | ... | ... |
| 72 | ... | ... | ... | ... |
| 73 | ... | ... | ... | ... |
| 74 | ... | ... | ... | ... |
| 75 | ... | ... | ... | ... |
| 76 | ... | ... | ... | ... |
| 77 | ... | ... | ... | ... |
| 78 | ... | ... | ... | ... |
| 79 | ... | ... | ... | ... |
| 80 | ... | ... | ... | ... |
| 81 | ... | ... | ... | ... |
| 82 | ... | ... | ... | ... |
| 83 | ... | ... | ... | ... |
| 84 | ... | ... | ... | ... |
| 85 | ... | ... | ... | ... |
| 86 | ... | ... | ... | ... |
| 87 | ... | ... | ... | ... |
| 88 | ... | ... | ... | ... |
| 89 | ... | ... | ... | ... |
| 90 | ... | ... | ... | ... |
| 91 | ... | ... | ... | ... |
| 92 | ... | ... | ... | ... |
| 93 | ... | ... | ... | ... |
| 94 | ... | ... | ... | ... |
| 95 | ... | ... | ... | ... |
| 96 | ... | ... | ... | ... |
| 97 | ... | ... | ... | ... |
| 98 | ... | ... | ... | ... |
| 99 | ... | ... | ... | ... |
| 100 | ... | ... | ... | ... |

Edit Office Space: Main Offices

To edit a space attribute, please select the "Edit" link at the far right of each row.

REQUIRED

Space Name:


| Current Space Attribute Values <small>What's this?</small> | | | | | | |
|--|--|-------------------|---------|--|--------------------------|----------------------|
| Space Attribute | Space Attribute Value <small>(Temporary values should only be used if an Actual value is not currently known)</small> | Use Default Value | Units | Effective Date <small>(When this Attribute Value was first used) (MM/DD/YYYY)</small> | Last Updated | |
| Gross Floor Area <small>(required for benchmarking)</small> | 13285 | N/A | Sq. Ft. | 01/01/2009 | 12/23/2010 by LINWOOD550 | Edit |
| Weekly operating hours <small>(required for benchmarking)</small> | 50 | | Hours | 01/01/2009 | 12/23/2010 by LINWOOD550 | Edit |
| Workers on Main Shift <small>(required for benchmarking)</small> | 20 | | | 01/01/2009 | 12/23/2010 by LINWOOD550 | Edit |
| Number of PCs <small>(required for benchmarking)</small> | 20 | | | 01/01/2009 | 12/23/2010 by LINWOOD550 | Edit |
| What percent of this space is air-conditioned? <small>(required for benchmarking)</small> | 50% or more | | | 01/01/2009 | 12/23/2010 by LINWOOD550 | Edit |
| What percent of this space is heated? <small>(required for benchmarking)</small> | 50% or more | | | 01/01/2009 | 12/23/2010 by LINWOOD550 | Edit |

| Space Revision History | | | | | | |
|------------------------|-------|-------------------|-------|--|---------|--|
| Space Attribute | Value | Use Default Value | Units | Effective Date <small>(When this Attribute Value was first used) (MM/DD/YYYY)</small> | Revised | |
| No Revision History | | | | | | |


APPENDIX J

EPA Portfolio Manager





Wind Resource of New Jersey *Mean Annual Wind Speed at 30 Meters*



AWS Truewind
 Projection: Transverse Mercator,
 UTM Zone 17 WGS84
 Spatial Resolution of Wind Resource Data: 200m
 This map was created by AWS Truewind using the MesoMap system and historical weather data. Although it is believed to represent an accurate overall picture of the wind energy resource, estimates at any location should be confirmed by measurement.
 The transmission line information was obtained by AWS Truewind from the Global Energy Decisions Velocity Suite. AWS does not warrant the accuracy of the transmission line information.

APPENDIX I

Wind



- Home
- What Can I Do?
- Electric Choice
- Home Energy
- FAQs
- LEARN**
- Fact Sheets
- Lesson Plans

Interactive Energy Calculators

RENEWABLE ENERGY
THE INFINITE POWER
OF TEXAS

Our calculators help you understand energy production and consumption in a whole new way. Use them to develop a personal profile of your own energy use.

- [Carbon Pollution Calculator](#)
- [Electric Power Pollution Calculator](#)
- [PV System Economics](#)
- [Solar Water Heating](#)
- [What's a Watt?](#)

PLAY
Calculators

Solar Water Heating Calculator

- NETWORK**
- Organizations
 - Businesses
 - Events Calendar

Water heating is a major energy consumer. Although the energy consumed daily is often less than for air conditioning or heating, it is required year round, making it a good application of solar energy. Use this calculator to explore the energy usage of your water heater, and to estimate whether a solar water heater could save you money.

- BROWSE**
- Resources
 - Solar
 - Wind
 - Biomass
 - Geothermal
 - Water

- Projects
- TX Energy : Past and Present
- Financial Help
- About Us
- About SECO
- RARE

| Water Heater Characteristics | | | |
|--|-------|--|------|
| Physical | | Thermal | |
| <input type="checkbox"/> Diameter (feet) | 1.5 | <input type="checkbox"/> Water Inlet Temperature (Degrees F) | 58 |
| <input type="checkbox"/> Capacity (gallons) | 50 | <input type="checkbox"/> Ambient Temperature (Degrees F) | 70 |
| <input type="checkbox"/> Surface Area (calculated - sq ft) | 21.36 | <input type="checkbox"/> Hot Water Temperature (Degrees F) | 135 |
| <input type="checkbox"/> Effective R-value | NaN | <input type="checkbox"/> Hot Water Usage (Gallons per Day) | 64.3 |
| Energy Use | | | |
| 1694 | | <input type="checkbox"/> Heat Delivered in Hot Water (BTU/hr) | |
| 0 | | <input type="checkbox"/> Heat loss through insulation (BTU/hr) | |

| Gas vs. Electric Water Heating | | |
|--|--|---|
| Gas | | Electric |
| 0.8 | <input type="checkbox"/> Overall Efficiency | 0.98 |
| 0.8 | <input type="checkbox"/> Conversion Efficiency | 0.98 |
| 2118 BTU/hr | <input type="checkbox"/> Power Into Water Heater | 1729 BTU/hr |
| Cost | | |
| \$.98 /Therm | <input type="checkbox"/> Utility Rates | \$.15 /kWh |
| \$ 181.8261 | <input type="checkbox"/> Yearly Water Heating Cost | \$ 665.384 |
| How Does Solar Compare? | | |
| <input type="checkbox"/> Solar Water Heater Cost: \$ 21700 | | <input type="checkbox"/> Percentage Solar: 70 |
| 170.4921 years for gas | <input type="checkbox"/> Payback Time for Solar System | 46.58961 years for electric |

More information on solar water heating:

NJBPU Energy Audits
 CHA #22215
 City of Linwood- City Hall

| Multipliers | |
|-------------|------|
| Material: | 0.98 |
| Labor: | 1.21 |
| Equipment: | 1.09 |

| Description | QTY | UNIT | UNIT COSTS | | | SUBTOTAL COSTS | | | TOTAL COST | REMARKS |
|------------------------------|-----|------|------------|----------|----------|----------------|----------|----------|------------|---------|
| | | | MAT. | LABOR | EQUIP. | MAT. | LABOR | EQUIP. | | |
| Synergy Solar Thermal System | 2 | ea | | | \$ 3,600 | \$ - | \$ - | \$ 7,848 | | |
| Piping modifications | 1 | ls | \$ 2,000 | \$ 3,500 | | \$ 1,960 | \$ 4,235 | \$ 6,195 | | |
| Electrical modifications | 1 | ls | \$ 1,000 | \$ 1,000 | | \$ 980 | \$ 1,210 | \$ 2,190 | | |
| 65 Gallon Storage Tanks | 2 | ea | \$ 200 | \$ 250 | | \$ 400 | \$ 500 | \$ 900 | | |
| 10 Gallon Drip Tank | 2 | ea | \$ 100 | \$ 78 | | \$ 200 | \$ 156 | \$ 356 | | |
| | | | \$ - | \$ - | | \$ - | \$ - | \$ - | | |

| | |
|-----------------|--------------------|
| \$17,489 | Subtotal |
| \$ 2,623 | 15% Contingency |
| \$ 2,623 | 15% Contractor O&P |
| \$ 4,372 | 25% Engineering |
| \$27,108 | Total |

APPENDIX H

Solar Thermal Domestic Hot Water Plant





Cautions for Interpreting the Results

The monthly and yearly energy production are modeled using the PV system parameters you selected and weather data that are typical or representative of long-term averages. For reference, or comparison with local information, the solar radiation values modeled for the PV array are included in the performance results.

Because weather patterns vary from year-to-year, the values in the tables are better indicators of long-term performance than performance for a particular month or year. PV performance is largely proportional to the amount of solar radiation received, which may vary from the long-term average by $\pm 30\%$ for monthly values and $\pm 10\%$ for yearly values. How the solar radiation might vary for your location may be evaluated by examining the tables in the *Solar Radiation Data Manual for Flat-Plate and Concentrating Collectors* (http://rredc.nrel.gov/solar/old_data/nsrdb/redbook/).

For these variations and the uncertainties associated with the weather data and the model used to model the PV performance, future months and years may be encountered where the actual PV performance is less than or greater than the values shown in the table. The variations may be as much as 40% for individual months and up to 20% for individual years. Compared to long-term performance over many years, the values in the table are accurate to within 10% to 12%.

If the default overall DC to AC derate factor is used, the energy values in the table will overestimate the actual energy production if nearby buildings, objects, or other PV modules and array structure shade the PV modules; if tracking mechanisms for one- and two-axis tracking systems do not keep the PV arrays at the optimum orientation with respect to the sun's position; if soiling or snow cover related losses exceed 5%; or if the system performance has degraded from new. (PV performance typically degrades 1% per year.) If any of these situations exist, an overall DC to AC derate factor should be used with PVWATTS that was calculated using system specific component derate factors for *shading, sun-tracking, soiling, and age*.

The PV system size is the nameplate DC power rating. The energy production values in the table are valid only for crystalline silicon PV systems.

The cost savings are determined as the product of the number of kilowatt hours (kWh) and the cost of electricity per kWh. These cost savings occur if the owner uses all the electricity produced by the PV system, or if the owner has a net-metering agreement with the utility. With net-metering, the utility bills the owner for the net electricity consumed. When electricity flows from the utility to the owner, the meter spins forward. When electricity flows from the PV system to the utility, the meter spins backwards.

If net-metering isn't available and the PV system sends surplus electricity to the utility grid, the utility generally buys the electricity from the owner at a lower price than the owner pays the utility for electricity. In this case, the cost savings shown in the table should be reduced.

Besides the cost savings shown in the table, other benefits of PV systems include greater energy independence and a reduction in fossil fuel usage and air pollution. For commercial customers, additional cost savings may come from reducing demand charges. Homeowners can often include the cost of the PV system in their home mortgage as a way of accommodating the PV system's initial cost.

To accelerate the use of PV systems, many state and local governments offer financial incentives and programs. Go to <http://www.nrel.gov/stateandlocal> for more information.

Please send questions and comments to Webmaster

Disclaimer and copyright notice.



Return to RReDC Home Page (<http://rredc.nrel.gov/>)



AC Energy
&
Cost Savings



Municipal Building, Linwood, NJ

| Station Identification | |
|--------------------------|---------------|
| City: | Atlantic_City |
| State: | New_Jersey |
| Latitude: | 39.45° N |
| Longitude: | 74.57° W |
| Elevation: | 20 m |
| PV System Specifications | |
| DC Rating: | 10.0 kW |
| DC to AC Derate Factor: | 0.770 |
| AC Rating: | 7.7 kW |
| Array Type: | Fixed Tilt |
| Array Tilt: | 39.5° |
| Array Azimuth: | 180.0° |
| Energy Specifications | |
| Cost of Electricity: | 14.6 ¢/kWh |

| Results | | | |
|---------|---|-----------------|-------------------|
| Month | Solar Radiation (kWh/m ² /day) | AC Energy (kWh) | Energy Value (\$) |
| 1 | 3.61 | 895 | 130.58 |
| 2 | 4.20 | 932 | 135.98 |
| 3 | 4.78 | 1124 | 163.99 |
| 4 | 5.23 | 1155 | 168.51 |
| 5 | 5.44 | 1211 | 176.68 |
| 6 | 5.48 | 1133 | 165.30 |
| 7 | 5.55 | 1171 | 170.85 |
| 8 | 5.41 | 1155 | 168.51 |
| 9 | 5.23 | 1106 | 161.37 |
| 10 | 4.60 | 1034 | 150.86 |
| 11 | 3.59 | 821 | 119.78 |
| 12 | 3.17 | 766 | 111.76 |
| Year | 4.69 | 12503 | 1824.19 |

[Output Hourly Performance Data](#)

[Output Results as Text](#)

*

About the Hourly Performance Data

Saving Text from a Browser

Run PVWATTS v.1 for another US location or an International location
Run PVWATTS v.2 (US only)

Please send questions and comments regarding PVWATTS to Webmaster

Disclaimer and copyright notice



Return to RReDC home page (<http://redc.nrel.gov>)

City of Linwood
City Hall

Cost of Electricity \$0.146 \$/kWh

Photovoltaic (PV) Rooftop Solar Power Generation-10kW System

| Budgetary | Annual Utility Savings | | | Estimated Maintenance Savings | Total Savings | New Jersey Renewable * Energy Incentive | New Jersey Renewable ** SREC | Payback (without incentive) | Payback (with incentive) |
|-----------|------------------------|--------|----|-------------------------------------|------------------|--|------------------------------------|-----------------------------------|--------------------------------|
| | kWh | therms | \$ | | | | | | |
| Cost | | | | | | | | | |
| \$ | kWh | therms | \$ | \$ | \$ | \$ | \$ | Years | Years |
| \$70,000 | 0.0 | 12,503 | 0 | \$1,800 | 0 | \$10,000 | \$6,100 | 38.9 | 7.6 |

*Incentive based on New Jersey renewable energy program for non-residential applications(PV)= \$0.75/W of installed PV system


** Estimated Solar Renewable Energy Certificate Program (SREC) for 15 Years= \$487/1000kwh

Estimated Solar Renewable Energy Certificate Program (SREC) payments for 15 Years from RRR Renewable Energy Consultants

| Year | SREC |
|------------|------------|
| 1 | 600 |
| 2 | 600 |
| 3 | 600 |
| 4 | 500 |
| 5 | 500 |
| 6 | 500 |
| 7 | 500 |
| 8 | 500 |
| 9 | 500 |
| 10 | 500 |
| 11 | 400 |
| 12 | 400 |
| 13 | 400 |
| 14 | 400 |
| 15 | 400 |
| AVG | 487 |

APPENDIX G

Photovoltaic (PV) Rooftop Solar Power Generation



City of Linwood, NJ
 CHA #22215
 City Hall

New Jersey Pay For Performance Incentive Program

Note: The following calculation is based on the New Jersey Pay For Performance Incentive Program per April, 2010. Building must have a minimum average electric demand of 200 kW. This minimum is waived for buildings owned by local governments or non-profit organizations. The incentive values represented below are applicable through December 31, 2010.

| | |
|--|--------|
| Total Building Area (Square Feet) | 13,000 |
| Is this audit funded by the NJ BPU (Y/N) | Yes |

Bureau of Public Utilities (BPU)

| Incentive #1 | | |
|----------------------------|--------|---------|
| Audit not funded by NJ BPU | \$0.10 | \$/sqft |
| Audit is funded by NJ BPU | \$0.05 | \$/sqft |

| | Annual Utilities | |
|-------------------------------|------------------|----------|
| | kWh | Therms |
| Existing Cost (from utility) | \$46,136 | \$16,815 |
| Existing Usage (from utility) | 294,280 | 14,022 |
| Proposed Savings | 2,187 | 5,813 |
| Existing Total MMBtus | 2,407 | |
| Proposed Savings MMBtus | 589 | |
| % Energy Reduction | 24.5% | |
| Proposed Annual Savings | \$8,455 | |

| | Min (Savings = 15%) | | Increase (Savings > 15%) | | Max Incentive | | Achieved Incentive | |
|--------------|---------------------|----------|--------------------------|----------|---------------|----------|--------------------|----------|
| | \$/kWh | \$/therm | \$/kWh | \$/therm | \$/kWh | \$/therm | \$/kWh | \$/therm |
| Incentive #2 | \$0.11 | \$1.10 | \$0.005 | \$0.05 | \$0.13 | \$1.45 | \$0.13 | \$1.45 |
| Incentive #3 | \$0.07 | \$0.70 | \$0.005 | \$0.05 | \$0.09 | \$1.05 | \$0.09 | \$1.05 |

| | Incentives \$ | | |
|-----------------------------|---------------|-----------------|-----------------|
| | Elec | Gas | Total |
| Incentive #1 | \$0 | \$0 | \$650 |
| Incentive #2 | \$284 | \$8,429 | \$8,713 |
| Incentive #3 | \$197 | \$6,104 | \$6,300 |
| Total All Incentives | \$481 | \$14,532 | \$15,663 |

| | |
|---------------------------|------------------|
| Total Project Cost | \$190,123 |
|---------------------------|------------------|

| | | Allowable Incentive |
|-------------------------------------|------|---------------------|
| % Incentives #1 of Utility Cost* | 1.0% | \$650 |
| % Incentives #2 of Project Cost** | 4.6% | \$8,713 |
| % Incentives #3 of Project Cost** | 3.3% | \$6,300 |
| Total Eligible Incentives*** | | \$15,663 |
| Project Cost w/ Incentives | | \$174,459 |

| Project Payback (years) | |
|-------------------------|---------------|
| w/o Incentives | w/ Incentives |
| 22.5 | 20.6 |

* Maximum allowable incentive is 50% of annual utility cost if not funded by NJ BPU, and %25 if it is.

** Maximum allowable amount of Incentive #2 is 30% of total project cost.

Maximum allowable amount of Incentive #3 is 20% of total project cost.

*** Maximum allowable amount of incentive #1 is \$50,000 if not funded by NJ BPU, and \$25,000 if it is.

Maximum allowable amount of Incentive #2 & #3 is \$1 million per gas account and \$1 million per electric account


APPENDIX F

New Jersey Pay For Performance Incentive Program



APPENDIX E

ECM-4 Lighting Replacement



City of Linwood, NJ
 CHA #22215

Building: City Hall

ECM-3 Night Setback

| Multipliers | |
|-------------|------|
| Material: | 0.98 |
| Labor: | 1.21 |
| Equipment: | 1.09 |

| Description | QTY | UNIT | UNIT COSTS | | | SUBTOTAL COSTS | | | TOTAL COST | REMARKS |
|----------------------|-----|------|------------|-------|--------|----------------|--------|--------|------------|---------|
| | | | MAT. | LABOR | EQUIP. | MAT. | LABOR | EQUIP. | | |
| | | | | | | | | | | |
| Reprogram DDC system | 8 | hrs | \$ - | \$ 80 | \$ - | \$ - | \$ 774 | \$ - | \$ 774 | |
| | | | | | | | | | | |
| | | | | | | | | | | |
| | | | | | | | | | | |
| | | | | | | | | | | |
| | | | | | | | | | | |
| | | | | | | | | | | |
| | | | | | | | | | | |
| | | | | | | | | | | |
| | | | | | | | | | | |
| | | | | | | | | | | |
| | | | | | | | | | | |

| | |
|---------------|----------------------------|
| \$ 774 | Subtotal |
| \$ 77.44 | 10% Contingency Contractor |
| \$ 85.18 | 10% O&P |
| \$ - | 0% Engineering |
| \$ 937 | Total |

City of Linwood, NJ
CHA #22215
Building: City Hall

Municipal Section

ECM-3 Night setback
Building Footprint 9,944 SF
Heating Efficiency 85%
Cooling Efficiency 85%
Building Balance Temp. 60 F
Internal Gains 60.87 Btu/hr/F
Unoc Internal Gain Factor 0.03
Ave Occ Internal Gain Factor 0.6

Ex Occupied Chg Temp. 65 F
Ex Unoccupied Chg Temp. 65 F
Prop Occupied Htg Temp. 65 F
Prop Unoccupied Htg Temp. 65 F
Unoccupied Cooling UA 14.63 Btu/hr/F
Cooling Occ: Enthalpy Sigmoid
Cooling Unoc: Enthalpy Sigmoid

Ex Occupied Htg Temp. 72 F
Ex Unoccupied Htg Temp. 72 F
Prop Occupied Htg Temp. 72 F
Prop Unoccupied Htg Temp. 72 F
Unoccupied Heating UA 11.06 Btu/hr/F

Heating Energy Savings 2,868 therms
Cooling Energy Savings 3,960 kWh

Heating end cooling energy are unrelated in this model. If the building being analyzed is not cooled, disregard cooling energy calculations

| Avg Outdoor Air Temp. Btu/F | Avg Outdoor Air Enthalpy | Equipment Bin Hours | Occupied | | | Unoccupied | | | Occupied | | | Unoccupied | | | Proposed Cooling Energy kWh | Existing Heating Energy therms | Proposed Heating Energy therms |
|-----------------------------|--------------------------|---------------------|--------------------------------|------------------------------|--------------------------------|--------------------|-----------------------|--------------------|--------------------|-----------------------|--------------------|--------------------|-----------------------|--------------------|-----------------------------|--------------------------------|--------------------------------|
| | | | Exhausting Equipment Bin Hours | Occupied Equipment Bin Hours | Unoccupied Equipment Bin Hours | Envelope Load BTUH | Ventilation Load BTUH | Internal Gain BTUH | Envelope Load BTUH | Ventilation Load BTUH | Internal Gain BTUH | Envelope Load BTUH | Ventilation Load BTUH | Internal Gain BTUH | | | |
| 102.5 | 48.1 | 0 | 0 | 0 | 0 | -134,459 | -253,545 | -1,829 | -134,459 | -394,950 | -36,587 | -60,453 | -253,545 | -1,829 | 0 | 0 | 0 |
| 97.5 | 42.5 | 3 | 9 | 3 | 6 | -116,531 | -277,897 | -1,829 | -116,531 | -277,897 | -36,587 | -48,116 | -176,672 | -1,829 | 271 | 0 | 0 |
| 92.5 | 36.5 | 23 | 69 | 23 | 44 | -98,633 | -224,965 | -1,829 | -98,633 | -224,965 | -36,587 | -35,779 | -144,640 | -1,829 | 1,696 | 0 | 0 |
| 87.5 | 30.5 | 34 | 132 | 47 | 85 | -80,676 | -173,796 | -1,829 | -80,676 | -173,796 | -36,587 | -28,441 | -111,741 | -1,829 | 2,807 | 0 | 0 |
| 82.5 | 24.5 | 34 | 344 | 128 | 221 | -62,748 | -127,921 | -1,829 | -62,748 | -127,921 | -36,587 | -11,104 | -82,246 | -1,829 | 5,806 | 0 | 0 |
| 77.5 | 18.5 | 31.5 | 566 | 202 | 394 | -44,820 | -85,575 | -1,829 | -44,820 | -85,575 | -36,587 | 0 | 0 | -1,829 | 6,966 | 0 | 0 |
| 72.5 | 12.5 | 28.2 | 755 | 270 | 485 | -28,892 | -43,228 | -1,829 | -28,892 | -43,228 | -36,587 | 0 | 0 | -1,829 | 5,213 | 0 | 0 |
| 67.5 | 6.5 | 27 | 760 | 279 | 501 | -8,954 | -4,411 | -1,829 | -8,954 | -4,411 | -36,587 | 0 | 0 | -1,829 | 2,966 | 0 | 0 |
| 62.5 | 0.5 | 24.5 | 889 | 318 | 572 | 13,954 | 46,229 | -1,829 | 13,954 | 40,229 | -36,587 | 0 | 0 | -1,829 | 1,464 | 0 | 0 |
| 57.5 | -5.5 | 21.4 | 742 | 285 | 477 | 21,298 | 61,402 | -1,829 | 21,298 | 61,402 | -36,587 | 2,754 | 6,897 | -1,829 | 0 | 372 | 67 |
| 52.5 | -11.5 | 18.7 | 827 | 224 | 403 | 28,642 | 82,575 | -1,829 | 28,642 | 82,575 | -36,587 | 6,262 | 20,220 | -1,829 | 0 | 496 | 234 |
| 47.5 | -17.5 | 16.2 | 725 | 259 | 466 | 35,986 | 103,748 | -1,829 | 35,986 | 103,748 | -36,587 | 13,770 | 34,033 | -1,829 | 0 | 672 | 708 |
| 42.5 | -23.5 | 14.4 | 795 | 284 | 511 | 43,331 | 124,921 | -1,829 | 43,331 | 124,921 | -36,587 | 19,278 | 47,846 | -1,829 | 0 | 1,394 | 1,098 |
| 37.5 | -29.5 | 12.5 | 862 | 244 | 438 | 50,675 | 146,095 | -1,829 | 50,675 | 146,095 | -36,587 | 24,787 | 61,259 | -1,829 | 0 | 1,824 | 1,342 |
| 32.5 | -35.5 | 10.7 | 925 | 225 | 395 | 58,019 | 167,268 | -1,829 | 58,019 | 167,268 | -36,587 | 30,295 | 74,872 | -1,829 | 0 | 943 | 793 |
| 27.5 | -41.5 | 8.8 | 988 | 188 | 342 | 65,363 | 188,441 | -1,829 | 65,363 | 188,441 | -36,587 | 35,803 | 86,465 | -1,829 | 0 | 701 | 602 |
| 22.5 | -47.5 | 6.8 | 1051 | 142 | 289 | 72,707 | 209,614 | -1,829 | 72,707 | 209,614 | -36,587 | 41,311 | 102,688 | -1,829 | 0 | 841 | 559 |
| 17.5 | -53.5 | 4.1 | 1114 | 88 | 236 | 80,051 | 230,787 | -1,829 | 80,051 | 230,787 | -36,587 | 46,819 | 115,712 | -1,829 | 0 | 261 | 230 |
| 12.5 | -59.5 | 2.6 | 1177 | 35 | 183 | 87,395 | 251,960 | -1,829 | 87,395 | 251,960 | -36,587 | 52,323 | 128,323 | -1,829 | 0 | 81 | 72 |
| 7.5 | -65.5 | 0.8 | 1240 | 0 | 130 | 94,740 | 273,133 | -1,829 | 94,740 | 273,133 | -36,587 | 57,835 | 142,938 | -1,829 | 0 | 35 | 32 |
| 2.5 | -71.5 | 0 | 1303 | 0 | 77 | 102,084 | 294,307 | -1,829 | 102,084 | 294,307 | -36,587 | 63,343 | 156,351 | -1,829 | 0 | 0 | 0 |
| -2.5 | -77.5 | 0 | 1366 | 0 | 24 | 109,428 | 315,480 | -1,829 | 109,428 | 315,480 | -36,587 | 68,851 | 170,164 | -1,829 | 0 | 0 | 0 |
| -7.5 | -83.5 | -1.5 | 1429 | 0 | 0 | 116,772 | 336,653 | -1,829 | 116,772 | 336,653 | -36,587 | 74,360 | 183,777 | -1,829 | 0 | 0 | 0 |
| TOTALS | | | 8,760 | 3,129 | 5,631 | | | | | | | 24,955 | 17,200 | | 9,935 | 7,387 | |

Existing Building Ventilation & Infiltration (eov) 3,921 cfm
Overheat Ventilation Factor 1.00
Additional ventilation to offset overheat 0 cfm
Existing Building Ventilation & Infiltration (unec) 2,821 cfm

APPENDIX D

ECM-3 Night Setback



City of Linwood, NJ
 CHA #22215
 Building: City Hall

ECM-2 Replace Boilers

| Multipliers | |
|-------------|------|
| Material: | 0.98 |
| Labor: | 1.21 |
| Equipment: | 1.09 |

| Description | QTY | UNIT | UNIT COSTS | | | SUBTOTAL COSTS | | | TOTAL COST | REMARKS |
|--|-----|------|------------|-----------|--------|----------------|-----------|--------|------------|---|
| | | | MAT. | LABOR | EQUIP. | MAT. | LABOR | EQUIP. | | |
| Weil McClain for Municipa(350 MBTU each) | 2 | ea | \$ 20,000 | \$ 15,000 | | \$ 39,200 | \$ 36,300 | \$ - | \$ 75,500 | Includes removal of old boilers and startup |
| Weil McClain for Police(175MBTU) | 1 | ea | \$ 10,000 | \$ 10,000 | | \$ 9,800 | \$ 12,100 | \$ - | \$ 21,900 | |
| Piping | 1 | | \$ 3,000 | \$ 3,000 | | \$ 2,940 | \$ 3,630 | \$ - | \$ 6,570 | |
| Electrical | 1 | | \$ 1,000 | \$ 1,000 | | \$ 980 | \$ 1,210 | \$ - | \$ 2,190 | |
| Flue | 3 | | \$ 1,250 | \$ 1,250 | | \$ 3,675 | \$ 4,538 | \$ - | \$ 8,213 | |
| | | | | | | \$ - | \$ - | \$ - | \$ - | |
| | | | | | | \$ - | \$ - | \$ - | \$ - | |
| | | | | | | \$ - | \$ - | \$ - | \$ - | |
| | | | | | | \$ - | \$ - | \$ - | \$ - | |
| | | | | | | \$ - | \$ - | \$ - | \$ - | |

| | |
|--------------|-----------------|
| \$ 114,373 | Subtotal |
| \$ 17,155.88 | 15% Contingency |
| \$ 13,152.84 | Contractor |
| \$ 36,170 | 10% O&P |
| \$ 180,852 | 25% Engineering |
| \$ 180,852 | Total |

City of Linwood, NJ
 CHA #22215
 Building: City Hall

ECM-2 Replace Boilers

replace boilers in Municipal Section and Police Section

| | | |
|---------------|----------|---|
| Existing Fuel | Nat. Gas | ▼ |
| Proposed Fuel | Nat. Gas | ▼ |

| Item | Value | Units | Formula/Comments |
|----------------------------------|-----------|---------|--|
| Baseline Fuel Cost | \$ 1.20 | | |
| Proposed Fuel Cost | \$ 1.20 | | |
| Baseline Fuel Use | 11,316 | Therms | Based on historical utility data |
| Existing Boiler Plant Efficiency | 68% | | Estimated |
| Baseline Boiler Load | 769,488 | Mbtu/yr | Baseline Fuel Use x Existing Efficiency x 100 Mbtu/Therms |
| Baseline Fuel Cost | \$ 13,570 | | |
| Proposed Boiler Plant Efficiency | 92% | | New Boiler Efficiency |
| Proposed Fuel Use | 8,364 | Therms | Baseline Boiler Load / Proposed Efficiency / 100 Mbtu/Therms |
| Proposed Fuel Cost | \$ 10,030 | | |
| Annual Savings | 2,952 | Therms | |
| Annual Savings | \$ 3,540 | /yr | |

*Note to engineer: Link savings back to summary sheet in appropriate column.

APPENDIX C

ECM-2 Replace Boilers

10/1/2010

*

City of Linwood, NJ
 CHA #22215
 Building: City Hall

ECM-1 Increase Ceiling Insulation

| | |
|-------------|------|
| Multipliers | |
| Material: | 0.98 |
| Labor: | 1.21 |
| Equipment: | 1.09 |

| Description | QTY | UNIT | UNIT COSTS | | | SUBTOTAL COSTS | | | TOTAL COST | REMARKS |
|----------------------------|------|------|------------|---------|--------|----------------|----------|--------|------------|---------|
| | | | MAT. | LABOR | EQUIP. | MAT. | LABOR | EQUIP. | | |
| Install 6" batt insulation | 4180 | sqft | \$ 0.48 | \$ 0.55 | | \$ 1,966 | \$ 2,782 | \$ - | \$ 4,748 | |
| | | | | | | \$ - | \$ - | \$ - | \$ - | |
| | | | | | | \$ - | \$ - | \$ - | \$ - | |
| | | | | | | \$ - | \$ - | \$ - | \$ - | |
| | | | | | | \$ - | \$ - | \$ - | \$ - | |
| | | | | | | \$ - | \$ - | \$ - | \$ - | |
| | | | | | | \$ - | \$ - | \$ - | \$ - | |
| | | | | | | \$ - | \$ - | \$ - | \$ - | |
| | | | | | | \$ - | \$ - | \$ - | \$ - | |
| | | | | | | \$ - | \$ - | \$ - | \$ - | |
| | | | | | | \$ - | \$ - | \$ - | \$ - | |
| | | | | | | \$ - | \$ - | \$ - | \$ - | |
| | | | | | | \$ - | \$ - | \$ - | \$ - | |
| | | | | | | \$ - | \$ - | \$ - | \$ - | |
| | | | | | | \$ - | \$ - | \$ - | \$ - | |
| | | | | | | \$ - | \$ - | \$ - | \$ - | |
| | | | | | | \$ - | \$ - | \$ - | \$ - | |
| | | | | | | \$ - | \$ - | \$ - | \$ - | |

| | |
|-----------|----------------|
| \$ 4,748 | Subtotal |
| \$ 237.40 | 5% Contingency |
| \$ 498.55 | Contractor |
| \$ - | 10% O&P |
| \$ 5,484 | Total |
| | Engineering |

APPENDIX B

ECM-1 Increase Ceiling Insulation

GAS MARKETERS LIST

The following is a listing of marketers/suppliers/brokers that have been licensed by the NJ Board of Public Utilities to sell natural gas to residential, small commercial and industrial customers served by the Public Service Electric and Gas Company distribution system. **This listing is provided for informational purposes only and PSE&G makes no representations or warranties as to the competencies of the entities listed herein or to the completeness of this listing.**

Gateway Energy Services
44 Whispering Pines Lane
Lakewood, NJ 08701
(800) 805-8586
www.gesc.com

Metro Energy Group, LLC
14 Washington Place
Hackensack, NJ 07601
www.metroenergy.com

RPL Holdings, Inc
601 Carlson Pkwy
Minnetonka, MN 55305

Great Eastern Energy
3044 Coney Island Ave. PH
Brooklyn, NY 11235
888-651-4121
www.greasterngas.com

Metromedia Energy, Inc.
6 Industrial Way
Eatontown, NJ 07724
(800) 828-9427
www.metromediaenergy.com

South Jersey Energy Company
One South Jersey Plaza, Rte 54
Folsom, NJ 08037
(800) 756-3749
www.sjindustries.com/sje.htm

Hess Corporation
1 Hess Plaza
Woodbridge, NJ 07095
(800) 437-7872
www.hess.com

Mitchell- Supreme Fuel
(NATGASCO)
532 Freeman Street
Orange, NJ 07050
(800) 840-4GAS
www.mitchellsupreme.com

Sprague Energy Corp.
Two International Drive, Ste 200
Portsmouth, NH 03801
800-225-1560
www.spragueenergy.com

Hudson Energy Services, LLC
545 Route 17 South
Ridgewood, NJ 07450
(201) 251-2400
www.hudsonenergyservices.com

MxEnergy Inc.
P.O. Box 177
Annapolis Junction, MD 20701
800-375-1277
www.mxenergy.com

Stuyvesant Energy LLC
642 Southern Boulevard
Bronx, NY 10455
(718) 665-5700
www.stuyfuel.com

Intelligent Energy
7001 SW 24th Avenue
Gainesville, FL 32607
Sales: 1 877 I've Got Gas
(1 877 483-4684)
Customer Service:
1 800 927-9794
www.intelligentenergy.org

Pepco Energy Services, Inc.
23 S Kinderkamack Rd, Suite D
Montvale, NJ 07645
(800) 363-7499
www.pepco-services.com

Tiger Natural Gas, Inc.
1422 E. 71st Street, Suite J.
Tulsa, OK 74136
1-888-875-6122
www.tigernaturalgas.com

Systrum Energy
877-SYSTRUM
(877-797-8786)
www.systrumenergy.com

Plymouth Rock Energy, LLC
165 Remsen Street
Brooklyn, NJ 11201
866-539-6450
www.plymouthrockenergy.com

UGI Energy Services, Inc.
d/b/a GASMARK
704 E. Main Street, Suite I
Moorestown, NJ 08057
856-273-9995
www.ugienergyservices.com

Macquarie Cook Energy, LLC
10100 Santa Monica Blvd, 18th
Fl
Los Angeles, CA 90067

PPL EnergyPlus, LLC
Energy Marketing Center
Two North Ninth Street
Allentown, PA 18101
1-866-505-8825
www.pplenergplus.com/natural+gas/

Woodruff Energy
73 Water Street
P.O. Box 777
Bridgeton, NJ 08302
(856) 455-1111
www.woodruffenergy.com

ELECTRIC MARKETERS LIST

The following is a listing of marketers/suppliers/brokers that have been licensed by the NJ Board of Public Utilities to sell electricity to residential, small commercial and industrial customers served by the Public Service Electric and Gas Company distribution system. **This listing is provided for informational purposes only and PSE&G makes no representations or warranties as to the competencies of the entities listed herein or to the completeness of this listing.**

American Powernet Management
867 Berkshire Blvd, Suite 101
Wyomissing, PA 19610
www.americanpowernet.com

Gerdau Ameristeel Energy Co.
North Crossman Road
Sayreville, NJ 08872

PPL EnergyPlus, LLC
Energy Marketing Center
Two North Ninth Street
Allentown, PA 18101
1-866-505-8825
<http://www.pplenergyplus.com/>

BOC Energy Services
575 Mountain Avenue
Murray Hill, NJ 07974
www.boc-gases.com

Gexa Energy LLC New Jersey
20 Greenway Plaza, Suite 600
Houston, TX 77046
(866) 304-GEXA
Beth.miller@gexaenergy.com

Sempra Energy Solutions
The Mac-Cali Building
581 Main Street, 8th Floor
Woodbridge, NJ 07095
(877) 273-6772
www.SempraSolutions.com

Commerce Energy Inc.
535 Route 38, Suite 138
Cherry Hill, NJ 08002
(888) 817-8572 or
(858) 910-8099
www.commerceenergy.com

Glacial Energy of New Jersey
2602 McKinney Avenue, Suite 220
Dallas, TX 75204
www.glacialenergy.com

South Jersey Energy Company
1 South Jersey Plaza, Route 54
Folsom, NJ 08037
(800) 756-3749
www.sjindustries.com

ConEdison Solutions
701 Westchester Avenue
Suite 201 West
White Plains, NY 10604
(800) 316-8011
www.ConEdSolutions.com

Hess Corporation
1 Hess Plaza
Woodbridge, NJ 07095
www.hess.com

Strategic Energy, LLC
6 East Main Street, Suite 6E
Ramsey, NJ 07446
(888) 925-9115
www.sel.com

Constellation NewEnergy, Inc.
1199 Route 22 East
Mountainside, NJ 07092
908 228-5100
www.newenergy.com

Integrus Energy Services, Inc
99 Wood Avenue, Suite 802
Iselin, NJ 08830
www.integrusenergy.com

Suez Energy Resources NA
333 Thornall Street FL6
Edison, NJ 08818
866.999.8374(toll free)
www.suezenergyresources.com

Credit Suisse (USA), Inc.
700 College Road East
Princeton, NJ 08450
www.creditsuisse.com

Liberty Power Delaware, LLC
1901 W Cypress Road, Suite 600
Fort Lauderdale, FL 33309
(866) Power-99
(866) 769-3799
www.libertypowercorp.com

UGI Energy Services, Inc.
d/b/a POWERMARK
1 Meridian Blvd. Suite 2C01
Wyomissing, PA 19610
(800) 427-8545
www.ugienergyservices.com


Direct Energy Services, LLC
One Gateway Center, Suite 2600
Newark, NJ 07102
(973) 799-8568
www.directenergy.com

Liberty Power Holdings, LLC
1901 W Cypress Creek Road, Suite 600
Fort Lauderdale, FL 33309
(866) Power-99
(866) 769-3799
www.libertypowercorp.com

FirstEnergy Solutions
395 Ghent Road Suite 407
Akron, OH 44333
(800) 977-0500
www.fcs.com

Pepco Energy Services, Inc.
d/b/a Power Choice
23 S. Kinderkamack Rd Ste D
Montvale, NJ 07645
(800) 363-7499
www.pepco-services.com

Natural Gas Usage - City Hall




City of Linwood
 CHA Project Number: 22215
 City Hall

400 Poplar Ave
 Account Number: 1 16 37 0042 0 8

Meter Number: 0232070

| Month | Therms | Total Charges | (\$/therm) |
|----------------|-----------|---------------|------------|
| June-09 | 401 \$ | 641.16 \$ | 1.60 |
| July-09 | 236 \$ | 384.35 \$ | 1.63 |
| August-09 | 203 \$ | 332.23 \$ | 1.64 |
| September-09 | 500 \$ | 550.00 \$ | 1.10 |
| October-09 | 807 \$ | 1,083.29 \$ | 1.34 |
| November-09 | 1102 \$ | 1,472.67 \$ | 1.34 |
| December-09 | 2414 \$ | 2,545.87 \$ | 1.05 |
| January-10 | 2348 \$ | 3,009.97 \$ | 1.28 |
| February-10 | 2713 \$ | 3,224.50 \$ | 1.19 |
| March-10 | 1555 \$ | 1,758.56 \$ | 1.13 |
| April-10 | 975 \$ | 987.93 \$ | 1.01 |
| May-10 | 768 \$ | 824.03 \$ | 1.07 |
| June-10 | 344 \$ | 364.06 \$ | 1.06 |
| July-10 | 273 \$ | 300.30 \$ | 1.10 |
| August-10 | 349 \$ | 383.90 \$ | 1.10 |
| September-10 | 500 \$ | 550.00 \$ | 1.10 |
| Most Recent Yr | 14,022 \$ | 16,815 \$ | 1.20 |

Electric Usage - City Hall - Oak & Poplar Ave



City of Linwood, NJ
CHA #22215
Building: City Hall

Reconcile Thermal Model

Building Footprint 13,285 SF
Heating Efficiency 88%
Cooling Efficiency 120% kW/ton
Internal Gains 61,304 btuh
Unoc Internal Gain factor 0.03
Ave Occ Internal Gain Factor 0.5
Economizer available (Y/N) No

Ex Occupied Chg Temp. 65 °F
Ex Unoccupied Chg Temp. 65 °F
Unoccupied Cooling UA (4,781) btuh/°F
Cooling Occ Enthalpy Seipoint (3,290) btuh/°F
Cooling Unocc Enthalpy Seipoint 26.75 Btu/lb
26.75 Btu/lb

Ex Occupied Htg Temp. 72 °F
Ex Unoccupied Htg Temp. 72 °F
Occupied Heating UA 1,958 btuh/°F
Unoccupied Heating UA 1,958 btuh/°F

Heating and cooling energy are unrelated in this model. If the building being analyzed is not cooled, disregard cooling energy calculations

| Avg Outdoor Air Temp. Bins. °F | Total Hours | Occupied | | | | Unoccupied | | | | Available Economizer Cooling KWh | Necessary Cooling Energy KWh | Existing Cooling Energy MWh | Existing Heating Energy MWh | | | |
|--------------------------------|--------------|---------------|---------------|------------|------------|--------------------|-----------------------|--------------------|-----------------------|----------------------------------|------------------------------|-----------------------------|-----------------------------|--------------------|-----------------------|--------------------|
| | | Equipment Bin | | Unoccupied | | Envelope | | Ventilation | | | | | | Internal Gain BTUH | Ventilation Load BTUH | Internal Gain BTUH |
| | | Hours | Equipment Bin | Hours | Unoccupied | Envelope Load BTUH | Ventilation Load BTUH | Internal Gain BTUH | Ventilation Load BTUH | | | | | | | |
| A | B | C | D | E | F | G | H | I | J | K | L | M | N | | | |
| 102.5 | 0 | 0 | 0 | -179,279 | -394,350 | -48,782 | -123,374 | -253,545 | -2,439 | 0 | 0 | 0 | 0 | | | |
| 97.5 | 9 | 3 | 6 | -155,375 | -277,987 | -48,782 | -109,925 | -178,672 | -2,439 | 322 | 322 | 0 | 0 | | | |
| 92.5 | 69 | 25 | 44 | -131,471 | -224,985 | -48,782 | -90,475 | -144,640 | -2,439 | 2,052 | 2,052 | 0 | 0 | | | |
| 87.5 | 366 | 47 | 85 | -107,567 | -173,796 | -48,782 | -74,025 | -111,741 | -2,439 | 3,153 | 3,153 | 0 | 0 | | | |
| 82.5 | 344 | 123 | 221 | -83,664 | -127,921 | -48,782 | -57,575 | -82,246 | -2,439 | 6,345 | 6,345 | 0 | 0 | | | |
| 77.5 | 566 | 202 | 384 | -59,760 | -85,575 | -48,782 | -41,123 | -55,020 | -2,439 | 7,511 | 7,511 | 0 | 0 | | | |
| 72.5 | 292 | 270 | 485 | -35,866 | -43,228 | -48,782 | -24,675 | -27,793 | -2,439 | 6,113 | 6,113 | 0 | 0 | | | |
| 67.5 | 270 | 279 | 501 | -11,962 | -4,411 | -48,782 | -8,225 | -2,836 | -2,439 | 2,492 | 2,492 | 0 | 0 | | | |
| 62.5 | 245 | 318 | 572 | 18,605 | 40,229 | -48,782 | 18,605 | 25,865 | -2,439 | 0 | 0 | 400 | 619 | | | |
| 57.5 | 214 | 477 | 742 | 28,397 | 61,402 | -48,782 | 28,397 | 39,478 | -2,439 | 0 | 0 | 0 | 764 | | | |
| 52.5 | 187 | 224 | 403 | 38,190 | 82,575 | -48,782 | 38,190 | 53,091 | -2,439 | 0 | 0 | 0 | 1,161 | | | |
| 47.5 | 162 | 259 | 466 | 47,982 | 103,748 | -48,782 | 47,982 | 66,704 | -2,439 | 0 | 0 | 0 | 1,579 | | | |
| 42.5 | 144 | 284 | 511 | 57,774 | 124,921 | -48,782 | 57,774 | 80,317 | -2,439 | 0 | 0 | 0 | 1,658 | | | |
| 37.5 | 126 | 280 | 504 | 77,358 | 146,095 | -48,782 | 77,358 | 93,931 | -2,439 | 0 | 0 | 0 | 1,878 | | | |
| 32.5 | 107 | 244 | 438 | 87,151 | 168,441 | -48,782 | 87,151 | 107,544 | -2,439 | 0 | 0 | 0 | 1,882 | | | |
| 27.5 | 86 | 123 | 222 | 96,943 | 209,614 | -48,782 | 96,943 | 121,157 | -2,439 | 0 | 0 | 0 | 806 | | | |
| 22.5 | 68 | 82 | 147 | 106,795 | 230,787 | -48,782 | 106,795 | 134,770 | -2,439 | 0 | 0 | 0 | 738 | | | |
| 17.5 | 55 | 68 | 122 | 116,527 | 251,960 | -48,782 | 116,527 | 148,893 | -2,439 | 0 | 0 | 0 | 300 | | | |
| 12.5 | 41 | 25 | 45 | 126,319 | 273,133 | -48,782 | 126,319 | 161,996 | -2,439 | 0 | 0 | 0 | 93 | | | |
| 7.5 | 26 | 7 | 13 | 136,112 | 294,307 | -48,782 | 136,112 | 189,223 | -2,439 | 0 | 0 | 0 | 40 | | | |
| 2.5 | 8 | 3 | 5 | 145,904 | 315,480 | -48,782 | 145,904 | 202,836 | -2,439 | 0 | 0 | 0 | 0 | | | |
| -2.5 | 0 | 0 | 0 | 155,896 | 336,653 | -48,782 | 155,896 | 216,449 | -2,439 | 0 | 0 | 0 | 0 | | | |
| -7.5 | 0 | 0 | 0 | 155,896 | 336,653 | -48,782 | 155,896 | 216,449 | -2,439 | 0 | 0 | 0 | 0 | | | |
| TOTALS | 8,760 | 3,129 | 5,631 | | | | | | | 27,988 | 27,988 | | 11,320 | | | |

Existing Building Ventilation & Infiltration (occ) 3,921 cfm
Overheat Ventilation Factor 1.00
Additional Ventilation to offset overheat 0 cfm
Existing Building Ventilation & Infiltration (unocc) 2,521 cfm
Economizer Ventilation (from AHU's) cfm

Energy Use Indices (calculated)

| | |
|-----------|--------|
| Base Case | 11,320 |
| Heating | 11,316 |
| Target -> | 100.0% |

| | |
|-----------|--------|
| Base Case | 27,988 |
| Cooling | 27,933 |
| Target -> | 100.2% |

