

**CITY OF LINWOOD  
EMERGENCY MEDICAL SERVICE BUILDING  
ENERGY ASSESSMENT**

**for**

**NEW JERSEY  
BOARD OF PUBLIC UTILITIES**

**CHA PROJECT NO. 22215**

January 2011

Prepared by:

**CLOUGH HARBOUR & ASSOCIATES LLP**

6 Campus Drive  
Parsippany, NJ 07054

(973) 538-2120

---

## TABLE OF CONTENTS

	<u>Page</u>
<b>1.0 INTRODUCTION &amp; BACKGROUND.....</b>	<b>1</b>
<b>2.0 EXECUTIVE SUMMARY.....</b>	<b>2</b>
<b>3.0 EXISTING CONDITIONS.....</b>	<b>3</b>
3.1 Building General	
3.2 Utility Usage	
3.3 HVAC Systems	
3.4 Lighting/Electrical Systems	
3.5 Control Systems	
3.6 Plumbing Systems	
<b>4.0 ENERGY CONSERVATION MEASURES.....</b>	<b>5</b>
4.1 ECM-1 Lighting Replacement	
4.2 ECM-2 Install Storm Windows	
4.3 ECM-3 Replace Unit Heaters with Infrared Heaters	
4.4 ECM-4 Increase Wall Insulation – Garage Area	
4.5 ECM-5 Furnace Replacement	
<b>5.0 INCENTIVES OVERVIEW.....</b>	<b>9</b>
5.1 Incentives Overview	
5.2 Building Incentives	
<b>6.0 ALTERNATIVE ENERGY EVALUATION.....</b>	<b>13</b>
6.1 Geothermal	
6.2 Solar	
6.3 Wind	
6.4 Combined Heat and Power Generation (CHP)	
6.5 Biomass Power Generation	
6.6 Demand Response Curtailment	
<b>7.0 EPA PORTFOLIO MANAGER.....</b>	<b>17</b>
<b>8.0 CONCLUSIONS &amp; RECOMMENDATIONS.....</b>	<b>18</b>

---

## APPENDICES

- A Utility Usage Analysis
  - B ECM-1 Lighting Replacement
  - C ECM-2 Install Storm Windows
  - D ECM-3 Replace Unit Heaters with Infrared Heaters
  - E ECM-4 Increase Wall Insulation
  - F ECM-5 Furnace Replacement
  - G New Jersey Pay For Performance Incentive Program
  - H Wind
  - I EPA Portfolio Manager
  - J Block Load Models & Equipment Inventory
-

## **1.0 INTRODUCTION AND BACKGROUND**

Emergency Medical Services is a 3,000 SF building built in 1989, and is currently rented to a private firm that provides ambulance dispatch. It is a single story structure with an attached garage. The garage has parking for two vehicles and two overhead doors. There is a kitchen, breakroom, one sleeping area, and a restroom. Two to three people occupy the building at any time.

New Jersey's Clean Energy Program, funded by the New Jersey Board of Public Utilities, supports energy efficiency and sustainability for Municipal and Local Government Energy Audits. Through the support of a utility trust fund, New Jersey is able to assist state and local authorities in reducing energy consumption while increasing comfort.

## 2.0 EXECUTIVE SUMMARY

This report details the results of the Emergency Medical Services building in Linwood, New Jersey. The 3,000 SF building constructed in 1989, is currently rented to a private firm that provides ambulance dispatch services. The single story structure includes a kitchen, breakroom, sleeping area, and restroom. An attached garage provides parking for two vehicles. The following areas were evaluated for energy conservation measures:

- Lighting replacement
- Furnace replacement
- Insulation upgrade
- Storm window installation
- Unit heater replacement

Various potential Energy Conservation Measures (ECMs) were identified for the above categories. Potential annual savings of \$1,100 for the recommended ECMs may be realized with a payback of 5.2 years.

The ECMs identified in this report will allow for the building to reduce its energy usage and if pursued has the opportunity to qualify for the New Jersey SmartStart Buildings Program. A summary of the costs, savings, and paybacks for the recommended ECMs follows:

### ECM-1 Lighting Replacement

Budgetary Cost	Annual Utility Savings				ROI	Potential Incentive*	Payback (without incentive)	Payback (with incentive)
	Electricity		Natural Gas	Total				
	kW	kWh	Therms	\$				
\$						\$	Years	Years
3,200	0	4,060	0	700	1.8	400	4.6	4.0

\* Incentive available through the New Jersey Smart Start program for this ECM. See section 5.0 for other incentive opportunities.

### ECM-2 Install Storm Windows

Budgetary Cost	Annual Utility Savings				ROI	Potential Incentive*	Payback (without incentive)	Payback (with incentive)
	Electricity		Natural Gas	Total				
	kW	kWh	Therms	\$				
\$						\$	Years	Years
2,900	0	210	350	400	2.6	NA	7.3	NA

\* There is no incentive available through the New Jersey Smart Start program for this ECM. See section 5.0 for other incentive opportunities.

In addition, the following measures are recommended if they qualify for funding through the Direct Install Program (see section 5.2.4). Under this program, incentives can be potentially awarded for up to 60% of a project's budgetary cost with a maximum incentive of \$50,000, when the work is performed by a participating Direct Install contractor.

- ECM-2 Boiler Replacement
- ECM-5 Replace Furnace

### **3.0 EXISTING CONDITIONS**

#### **3.1 Building – General**

The Emergency Medical Services Building, 3,000 SF, constructed in 1989, is currently rented to a company which provides ambulance dispatch. The single story structure has an attached garage with parking for two vehicles and has two overhead doors. The facility includes a kitchen, breakroom, sleeping area, and unisex restroom. The facility is consistently occupied by two to three individuals.

The building's exterior walls consist of brick face with insulation and finished walls with sheetrock. There are single pane glass with wooden frames windows around the perimeter of the building. The front entrance is a glass door with a vestibule. The roof is pitched with asphalt shingles. There is batt insulation between the joists in the attic.

#### **3.2 Utility Usage**

Utilities include electricity, natural gas, and potable water. Electricity is purchased from Atlantic City Electric with supply provided by Constellation New Energy. Natural gas is purchased from South Jersey Gas Company; potable water is provided by New Jersey American Water.

From October 2009 through September 2010, electric usage was approximately 38,000 kWh at a cost of about \$6,200. Analyzing electricity bills during this period showed that the building was charged at a blended unit cost of \$0.16 per kWh. Electricity usage was generally higher in the summer months due to air conditioning. During the same timeframe, the building heat produced by natural gas-fired equipment required about 2,640 therms. Based on the annual cost of about \$2,900, the blended price for natural gas was \$1.11 per therm. Natural gas consumption was highest in the winter months when the building is in heating mode.

Review of potable water utility bills from September 2009 through August 2010 determined the facility used a total of 144,000 gallons of water over the course of a year. At a total cost of about \$900, the unit cost for water was found to be \$6.47 per kGal. Utility data can be found in Appendix A.

Electricity is purchased from Atlantic City Electric with supply provided by Constellation New Energy. Natural gas commodity supply and delivery is presently purchased from South Jersey Gas. The delivery components will always be the responsibility of the utility that connects the facility to the gas line; however, the supply can be purchased from a third party. The natural gas commodity supply entity will require submission of one to three years of past energy bills. Contract terms can vary among suppliers. A list of approved natural gas energy commodity suppliers can be found in Appendix A. According to the U.S. Energy Information Administration, the average commercial unit costs of electricity and natural gas in New Jersey during July 2010 was \$0.152 per kWh and \$1.09 per therm. The building is currently paying about the state average for electricity and natural gas; therefore, it is recommended that a third party supplier not be pursued at this time.

#### **3.3 HVAC Systems**

The building is heated and cooled by a furnace and cooling coil located in the attic. The Lennox gas fired furnace has input of 140 MBH and existing efficiency of approximately 80%. The cooling coil is also manufactured by Lennox. The three ton condensing unit located outside on grade is about four years' old.

The building had an exhaust fan in the restroom controlled by the light switch.

The garage area has two unit heaters of approximately 100 MBH each. One unit is a newer Reznor; the other unit was older and did not contain a nameplate. The heaters are controlled by local thermostats and are approximately 72% efficient.

### **3.4 Lighting/Electrical Systems**

#### **3.4.1 Interior Lighting**

The lighting throughout the building utilizes older technology T-12 fluorescent fixtures and magnetic ballasts. The fixtures are four feet long and use two lamps per fixture.

#### **3.4.2 Exterior Lighting**

Wall mounted lights for the entrance vestibule were 150 W incandescent lamps.

### **3.5 Control Systems**

#### **3.5.1 HVAC Controls**

The HVAC controls in the building consist of a wall mounted programmable thermostat. Temperature setpoints are on average 68°F for heating and 73°F for cooling. The setpoints cannot vary significantly because the building is always occupied.

The two unit heaters for the garage were controlled by two mechanical thermostats mounted on the wall and were usually set at 60°F.

#### **3.5.2 Lighting/Electrical Controls**

Lighting controls within the building are manual switches located within each space. All outside lighting is manually operated. Lights are typically turned off when a space is unoccupied.

### **3.6 Plumbing Systems**

Domestic hot water is generated by a 40 gallon, AO Smith gas-fired water heater with an input of 40 MBH. It is in fair condition and is located in the attic space. It has an existing efficiency of about 80%. The sink and toilet in the restroom are standard flow type; the kitchen sink was also standard flow.

## 4.0 ENERGY CONSERVATION MEASURES

### 4.1 ECM-1 Lighting Replacements

During the site visit, a comprehensive fixture survey was conducted of the entire building. Each switch and circuit was identified, as well as the number of fixtures, locations, approximate operating times, and existing wattage consumption.

This measure addressed the expected energy savings of replacing the existing T-12 fluorescent fixtures with high efficiency T-8 fluorescent lamps and electronic ballasts. There were approximately 30 fixtures inside the building which used two lamp T-12 bulbs. All fixtures would be retrofitted with T-8 lamps and electronic ballasts.

Energy savings for this measure were calculated by applying the existing and proposed fixture wattages to the estimated time of operation to determine annual electricity consumptions. Supporting calculations, including all assumptions for lighting hours and the annual energy usage for each fixture is provided in Appendix B.

Lighting has an expected life of 15 years, according to the manufacturer, and total energy savings over the life of the project are estimated at 60,900 kWh, totaling \$10,500.

The implementation cost and savings related to this ECM are presented in Appendix B and summarized below:

#### ECM-1 Lighting Replacement

Budgetary Cost	Annual Utility Savings			ROI	Potential Incentive*	Payback (without incentive)	Payback (with incentive)	
	Electricity		Natural Gas					Total
\$	kW	kWh	Therms	\$	\$	Years	Years	
3,200	0	4,060	0	700	1.8	400	4.6	4.0

\* Incentive available through the New Jersey Smart Start program for this ECM. See section 5.0 for other incentive opportunities.

This measure is recommended.

### 4.2 ECM-2 Install Storm Windows

Windows are single pane glass with wooden frames and exterior screens. Due to age, construction type, and condition, the windows incur excess air infiltration and offer little thermal resistance to heat transfer. Installing exterior storm windows to decrease heating and cooling energy losses was evaluated.

Per the building energy audit and engineering knowledge, it was estimated that the existing windows have a U-value of 1.05 and infiltration rate of about 0.50 CFM/LF. To calculate the savings for this measure, the baseline energy loss was found by applying these values to the total square footage and perimeter length of the existing windows in conjunction with weather bin data. The proposed energy loss was then determined using the expected U-value of 0.50 and infiltration rate of 0.20 CFM/LF, with exterior storm windows installed. The difference in heating and cooling losses through the windows resulted in an annual savings of about 210 therms and 350 kWh.



Storm windows have an expected life of 25 years, according to the manufacturer, and total energy savings over the life of the project are estimated at 8,750 therms and 5,250 kWh, totaling \$10,000.

The implementation cost and savings related to this ECM are presented in Appendix C and summarized below:

**ECM-2 Install Storm Windows**

Budgetary Cost	Annual Utility Savings				ROI	Potential Incentive*	Payback (without incentive)	Payback (with incentive)
	Electricity		Natural Gas	Total				
\$	kW	kWh	Therms	\$		\$	Years	Years
2,900	0	210	350	400	2.6	NA	7.3	NA

\* There is no incentive available through the New Jersey Smart Start program for this ECM. See section 5.0 for other incentive opportunities.

This measure is recommended.

**4.3 ECM-3 Replace Unit Heaters with Infrared Heaters**

The garage area is heated by two gas fired unit heaters hung from the ceiling with an existing efficiency of around 72%. The ECM assessed replacing the unit heaters with two gas fired infrared (IR) heaters. IR heaters are effective in garage spaces and have higher burning efficiencies than standard unit heaters.

To calculate the savings associated with implementing infrared heaters, the efficiencies of the existing unit heaters were compared with the proposed efficiencies of the IR heaters. Additionally, the heating effectiveness between the two types of heaters was also compared to determine savings. Heating effectiveness is a ratio between the amount of heat being produced, compared to the amount of heat that actually reaches the floor space. IR heaters have an effectiveness ratio close to 100% because they use infrared wavelengths to distribute heat. The existing unit heaters must rely on a circulating fan to distribute heat which can cause certain areas of the space to be overheated or under heated.

The higher efficiencies and better effectiveness of the infrared heaters will save the EMS building about 300 therms of natural gas used for heating. The implementation costs were based on two low intensity infrared heaters; however, exact sizing requirements for the building should be assessed before this ECM is implemented.

Infrared heaters have a life expectancy of about 20 years according to ASHRAE. The savings over the life of the project would be about 6,600 therms and \$14,000.

The implementation cost and savings related to this ECM are presented in Appendix D and summarized as follows:

### ECM-3 Replace Unit Heaters with Infrared Heaters

Budgetary Cost	Annual Utility Savings				ROI	Potential Incentive*	Payback (without incentive)	Payback (with incentive)
	Electricity		Therms	Total				
\$	kW	kWh	Natural Gas	\$		\$	Years	Years
9,800	0	1,800	330	700	0.4	NA	14	NA

\* Incentive shown is per the New Jersey Smart Start Program, Gas Heating Application. Also, this measure is potentially eligible for Direct Install funding. See section 5.0 for other incentive opportunities.

This measure is not recommended.

### 4.4 ECM-4 Increase Wall Insulation – Garage Area

The exterior walls of the garage area are constructed of only CMU block which has a low existing R-value of 4. This ECM addressed adding 6” batt insulation to the interior side of the CMU block walls to minimize heat energy losses and increase the R value to 24. It is intended to install framing on the inside of the wall and install insulation between the new studs.

To calculate the savings, the heat losses through the exterior walls of garage were found using the existing walls’ R-value and bin weather data for Atlantic City, NJ, the closest city for which data is available. The values were then totaled to determine the existing annual heat losses. The heat loss values were then determined with a thermal resistance which included the additional 6” batt insulation. The annual energy savings of adding insulation to the exterior block walls is expected to be about 200 therms.

Batt insulation has an expected life of 25 years, according to ASHRAE, and total energy savings over the life of the project are estimated at 4,000 therms and \$5,000.

The implementation cost and savings related to this ECM are presented in Appendix E and summarized below:

### ECM-4 Increase Wall Insulation – Garage Area

Budgetary Cost	Annual Utility Savings				ROI	Potential Incentive*	Payback (without incentive)	Payback (with incentive)
	Electricity		Therms	Total				
\$	kW	kWh	Natural Gas	\$		\$	Years	Years
3,400	0	0	160	200	0.3	NA	17	NA

\* There is no incentive available through the New Jersey Smart Start program for this ECM. See section 5.0 for other incentive opportunities.

This measure is not recommended.

### 4.5 ECM-5 Furnace Replacement

The furnace is located in the attic space and provides heating to the building. It is over 10 years’ old and has a thermal efficiency of about 80%. By replacing this unit with a direct vent condensing furnace, it will be possible to achieve a thermal efficiency of 92%, saving heating energy.

Utilizing historical utility data for the building, the savings for this measure were found by adjusting the heating efficiency to reflect the proposed equipment, and comparing the overall utility requirements to the original usage. The resulting annual energy reductions attributed to heating and cooling efficiency improvements were approximately 330 therms.

Condensing gas-fired furnaces have an expected life of 18 years, according to ASHRAE, and total energy savings over the life of the project are estimated at 5,940 therms and \$7,200.

The implementation cost and savings related to this ECM are presented in Appendix F and summarized below:

**ECM-5 Replace Furnace**

Budgetary Cost	Annual Utility Savings					Estimated Maintenance Savings	Total Savings	ROI	Potential Incentive*	Payback (without Incentive)	Payback (with Incentive)
	Electricity		Natural Gas	Water	Total						
\$	kW	kWh	Therms	kGals	\$	\$	\$		\$	Years	Years
6,600	0	0	330	0	400	0	400	(0.2)	300	16.5	15.8

\* Incentive shown is per the New Jersey Smart Start Program, Gas Heating Application. Also, this measure is potentially eligible for Direct Install funding. See section 5.0 for other incentive opportunities.

This measure is not recommended.

## **5.0 PROJECT INCENTIVES**

### **5.1 Incentives Overview**

#### **5.1.1 New Jersey Pay For Performance Program**

The building will be eligible for incentives from the New Jersey Office of Clean Energy. The most significant incentives will be from the New Jersey Pay for Performance (P4P) Program. The P4P program is designed for qualified energy conservation projects in facilities whose demand in any of the preceding 12 months exceeds 200 kW. However, the 200 kW/month average minimum has been waived for buildings owned by local governments or municipalities and non-profit organizations. Facilities that meet this criterion must also achieve a minimum performance target of 15% energy reduction by using the EPA Portfolio Manager benchmarking tool before and after implementation of the measure(s). If the participant is a municipal electric company customer, and a customer of a regulated gas New Jersey Utility, only gas measures will be eligible under the Program. American Recovery and Reinvestment Act (ARRA) funding, when available, may allow oil, propane and municipal electric customers to be eligible for the P4P Program. Available incentives are as follows:

**Incentive #1: Energy Reduction Plan** – This incentive is designed to offset the cost of services associated with the development of the Energy Reduction Plan (ERP). The standard incentive pays \$0.10 per square foot, up to a maximum of \$50,000, not to exceed 50% of facility annual energy cost, paid after approval of application. For building audits funded by the New Jersey Board of Public Utilities, which receive an initial 75% incentive toward performance of the energy audit, facilities are only eligible for an additional \$0.05 per square foot, up to a maximum of \$25,000, rather than the standard incentive noted above.

**Incentive #2: Installation of Recommended Measures** – This incentive is based on projected energy saving and designed to pay approximately 60% of the total performance-based incentive. Base incentives deliver \$0.11/kWh and \$1.10/therm not to exceed 30% of total project cost.

**Incentive #3: Post-Construction Benchmarking Report** – This incentive is paid after acceptance of a report proving energy savings over one year utilizing the Environmental Protection Agency (EPA) Portfolio Manager benchmarking tool. Incentive #3 base incentives deliver \$0.07/kWh and \$0.70/therm not to exceed 20% of total project cost.

Combining incentives #2 and #3 will provide a total of \$0.18/ kWh and \$1.8/therm not to exceed 50% of total project cost. Additional incentives for #2 and #3 are increased by \$0.005/kWh and \$0.05/therm for each percentage increase above the 15% minimum target to 20%, calculated with the EPA Portfolio Manager benchmarking tool, not to exceed 50% of total project cost.

#### **5.1.2 New Jersey Smart Start Program**

For this program, specific incentives for energy conservation measures are calculated on an individual basis utilizing the 2010 New Jersey Smart Start incentive program. This program provides incentives dependent upon mechanical and electrical equipment. If applicable, incentives from this program are reflected in the ECM summaries and attached appendices.

If the building qualifies and enters into the New Jersey Pay for Performance Program, all energy savings will be included in the total building energy reduction, and savings will be applied towards the Pay for Performance incentive. A project is not applicable for both New Jersey incentive programs.

### 5.1.3 Energy Efficient and Conservation Block Grant

Following is a brief summary of the Energy Efficient and Conservation Block Grant (EECBG) program. The Energy Efficiency and Conservation Block Grant Complete Program Application Package should be consulted for rules and regulations.

Additional funding is available to local government entities through the EECBG, a part of New Jersey's Clean Energy program (NJCEP). The grant is for local government entities only, and can offset the cost of energy reduction implementation to a maximum of \$20,000 per building.

This program is provided in conjunction with NJCEP funding and any utility incentive programs; the total amount of the three incentives combined cannot exceed 100% of project cost. Funds shall first be provided by NJCEP, followed by the EECBG and any utility incentives available to the customer. The total amount of the incentive shall be determined TRC Solutions, a third party technical consulting firm for the NJCEP.

In order to receive EECBG incentives, local governments must not have received a Direct Block Grant from the US Department of Energy. A list of the 512 qualifying municipalities and counties is provided on the NJCEP website. Qualifying municipalities must participate in at least one eligible Commercial & Industrial component of the NJCEP, utility incentive programs, or install building shell measures recommended by the Local Government Energy Audit Program. Eligible conservation programs through NJCEP include:

- Direct Install
- Pay for Performance
- NJ SmartStart Buildings for measures recommended by a Local Government Energy Audit (LGEA) or an equivalent audit completed within the last 12 months
- Applicants may propose to independently install building shell measures recommended by a LGEA or an equivalent audit. The audit must have been completed within the past 12 months.
- Any eligible utility energy efficiency incentive program

Most facilities owned or leased by an eligible local government within the State of New Jersey are eligible for this grant. Ineligible facilities include casinos or other gambling establishments, aquariums, zoos, golf courses, swimming pools, and any building owned or leased by the United States Federal Government. New construction is also ineligible.

### 5.1.4 ARRA Initiative "Energy Efficiency Programs through the Clean Energy Program"

The American Recovery and Reinvestment Act (ARRA) Initiative is available to New Jersey oil, propane, cooperative and municipal electric customers who do not pay the Societal Benefits Charge. This charge can be seen on any electric bill as the line item "SBC Charge." Applicants can participate in this program in conjunction with other New Jersey Clean Energy Program initiatives including Pay for Performance, Local Government Energy Audits, and Direct Install programs.

Funding for this program is dispersed on a first come, first serve basis until all funds are exhausted. The program does not limit the municipality to a minimum or maximum incentive, and the availability of

funding cannot be determined prior to application. If the municipality meets all qualifications, the application must be submitted to TRC Energy Solutions for review. TRC will then determine the amount of the incentive based on projected energy savings of the project. It is important to note that all applications for this incentive must be submitted before implementation of energy conservation measures.

Additional information is available on New Jersey's Clean Energy Program website.

#### 5.1.5 Direct Install Program

The Direct Install Program targets small and medium sized facilities where the peak electrical demand does not exceed 200 kW in any of the previous 12 months. Buildings must be located in New Jersey and served by one of the state's public, regulated electric or natural gas utility companies. On a case-by-case basis, the program manager may accept a project for a customer that is within 10% of the 200 kW peak demand threshold.

The 200 kW peak demand threshold has been waived for local government entities that receive and utilize their Energy Efficiency and Conservation Block Grant as discussed in section 5.1.3 in conjunction with Direct Install.

Direct Install is funded through New Jersey's Clean Energy Program and is designed to provide capital for building energy upgrade projects to fast track implementation. The program will pay up to 60% of the costs for lighting, HVAC, motors, natural gas, refrigeration, and other equipment upgrades with higher efficiency alternatives. If a building is eligible for this funding, the Direct Install Program can significantly reduce the implementation cost of energy conservation projects.

The program pays a maximum amount of \$50,000 per building, and up to \$250,000 per customer per year. Installations must be completed by a Direct Install participating contractor, a list of which can be found on the New Jersey Clean Energy Website at <http://www.njcleanenergy.com>. Contractors will coordinate with the applicant to arrange installation of recommended measures identified in a previous energy assessment, such as this document.

## 5.2 Building Incentives

### 5.2.1 New Jersey Pay For Performance Program

Under incentive #1 of the New Jersey Pay for Performance Program, the 3,000 square foot building is eligible for about \$150 for development of an Energy Reduction Plan. When calculating the total amount under Incentives #2 and #3, all energy conservation measures are applicable as the amount received is based on building wide energy improvements. Since the overall energy reduction for the building is estimated to exceed the 15% minimum, the building is eligible to receive monies based on Incentives #2 and #3 as discussed in section 5.1.1. In total, incentives through the NJ P4P program are expected to total about \$4,400, reducing the total project payback from 11.2 years to 9.3 years. See Appendix G for calculations.

### 5.2.2 New Jersey Smart Start Program

The Emergency Medical Services building is eligible for several incentives available under New Jersey Smart Start Programs. The total amount of all qualified incentives is about \$700 and includes upgrades to the lighting systems and heating systems.

### 5.2.3 Energy Efficient and Conservation Block Grant

The EMS building is owned by local government, and is, therefore, eligible for this incentive. The incentive amount is determined by TRC Solutions and is not calculable at this time. Further information about this incentive, including the application, can be found at:

<http://www.njcleanenergy.com/commercial-industrial/programs/energy-efficiency-and-conservation-block-grants>

### 5.2.4 Direct Install Program

The building is potentially eligible to receive funding from the Direct Install Program. This money will be in conjunction with the Energy Efficiency and Conservation Block Grant. The total implementation cost for all ECMs potentially eligible for Direct Install funding is about \$19,500 and includes lighting, infrared heaters, and furnace replacement. This program would pay 60%, or about \$11,700 of these initial costs. This funding has the potential to significantly affect the payback periods of ECMs. For the EMS building, the Direct Install Program brings the simple payback from about 11.5 years, to approximately 4.6 years.

## **6.0 ALTERNATIVE ENERGY SCREENING EVALUATION**

### **6.1 Geothermal**

Geothermal heat pumps (GHP) transfer heat between the constant temperature of the earth and the building to maintain the building's interior space conditions. Below the surface of the earth throughout New Jersey the temperature remains in the low 50°F range throughout the year. This stable temperature provides a source for heat in the winter and a means to reject excess heat in the summer. With GHP systems, water is circulated between the building and the piping buried in the ground. The ground heat exchanger in a GHP system is made up of a closed or open loop pipe system. Most common is the closed loop in which high density polyethylene pipe is buried horizontally at 4-6 feet deep or vertically at 100 to 400 feet deep. These pipes are filled with an environmentally friendly antifreeze/water solution that acts as a heat exchanger. In the summer, the water picks up heat from the building and moves it to the ground. In the winter the system reverses and fluid picks up heat from the ground and moves it to the building. Heat pumps make collection and transfer of this heat to and from the building possible.

The building uses a gas-fired furnace with direct expansion cooling to meet the HVAC requirements. Significant upgrades would need to be implemented in order to convert to a geothermal system.

This measure is not recommended.

### **6.2 Solar**

#### **6.2.1 Photovoltaic Rooftop Solar Power Generation**

The facility was evaluated for the potential to install rooftop photovoltaic (PV) solar panels for power generation. Present technology incorporates the use of solar cell arrays that produce direct current (DC) electricity. This DC current is converted to alternating current (AC) with the use of an electrical device known as an inverter.

The building's roof has minimal room to install a solar cell array and this measure is not recommended at this time.

#### **6.2.2 Solar Thermal Hot Water Plant**

Active solar thermal systems use solar collectors to gather the sun's energy to heat water, another fluid, or air. An absorber in the collector converts the sun's energy into heat. The heat is then transferred by circulating water, antifreeze, or sometimes air to another location for immediate use or storage for later utilization. Applications for active solar thermal energy include providing hot water, heating swimming pools, space heating, and preheating air in residential and commercial buildings.

A standard solar hot water system is typically composed of solar collectors, heat storage vessel, piping, circulators, and controls. Systems are typically integrated to work alongside a conventional heating system that provides heat when solar resources are not sufficient. The solar collectors are usually placed on the roof of the building, oriented south, and tilted around the site's latitude, to maximize the amount of radiation collected on a yearly basis.

Several options exist for using active solar thermal systems for space heating. The most common method involves using glazed collectors to heat a liquid held in a storage tank (similar to an active solar hot water



system). The most practical system would transfer the heat from the panels to thermal storage tanks and transfer solar produced thermal energy to use for domestic hot water production.

Due to the lack of available roof area, this measure is not recommended.

### **6.3 Wind**

Small wind turbines use a horizontal axis propeller, or rotor, to capture the kinetic energy of the wind and convert it into rotary motion to drive a generator which usually is designed specifically for the wind turbine. The rotor consists of two or three blades, usually made from wood or fiberglass. These materials give the turbine the needed strength and flexibility, and have the added advantage of not interfering with television signals. The structural backbone of the wind turbine is the mainframe, and includes the slip-rings that connect the wind turbine, which rotates as it points into changing wind directions, and the fixed tower wiring. The tail aligns the rotor into the wind.

To avoid turbulence and capture greater wind energy, turbines are mounted on towers. Turbines should be mounted at least 30 feet above any structure or natural feature within 300 feet of the installation. Smaller turbines can utilize shorter towers. For example, a 250-watt turbine may be mounted on a 30-50 foot tower, while a 10 kW turbine will usually need a tower of 80-120 feet. Tower designs include tubular or latticed, guyed or self-supporting. Wind turbine manufacturers also provide towers.

The New Jersey Clean Energy Program for small wind installations has designated numerous pre-approved wind turbines for installation in the State of New Jersey. Incentives for wind turbine installations are based on kilowatt hours saved in the first year. Systems sized under 16,000 kWh per year of production will receive a \$3.20 per kWh incentive. Systems producing over 16,000 kWh will receive \$51,200 for the first 16,000 kWh of production with an additional \$0.50 per kWh up to a maximum cap of 750,000 kWh per year. Federal tax credits are also available for renewable energy projects up to 30% of installation cost for systems less than 100 kW. However, as noted previously, municipalities do not pay federal taxes and is, therefore, not eligible for the tax credit incentive.

The most important part of any small wind generation project is the mean annual wind speed at the height of which the turbine will be installed. The EMS building is located adjacent to the DPW building and may have sufficient land to install a wind turbine. Further study should be conducted for this measure. A wind speed map is included in Appendix H.

### **6.4 Combined Heat and Power Generation (CHP)**

Combined heat and power, cogeneration, is self-production of electricity on-site with beneficial recovery of the heat byproduct from the electrical generator. Common CHP equipment includes reciprocating engine-driven, micro turbines, steam turbines, and fuel cells. Typical CHP customers include industrial, commercial, institutional, educational institutions, and multifamily residential facilities. CHP systems that are commercially viable at the present time are sized approximately 50 kW and above, with numerous options in blocks grouped around 300 kW, 800 kW, 1,200 kW and larger. Typically, CHP systems are used to produce a portion of the electricity needed by a facility some or all of the time, with the balance of electric needs satisfied by purchase from the grid.

Any proposed CHP project will need to consider many factors, such as existing system load, use of thermal energy produced, system size, natural gas fuel availability, and proposed plant location. This

measure is not recommended since the EMS building cannot use the heat produced in the summer months.

## **6.5 Biomass Power Generation**

Biomass power generation is a process in which waste organic materials are used to produce electricity or thermal energy. These materials would otherwise be sent to the landfill or expelled to the atmosphere. To participate in NJCEP's Customer On-Site Renewable Energy program, participants must install an on-site sustainable biomass or fuel cell energy generation system. Incentives for bio-power installations are available to support up to 1MW-dc of rated capacity.

\*Class I organic residues are eligible for funding through the NJCEP CORE program. Class I wastes include the following renewable supply of organic material:

- Wood wastes not adulterated with chemicals, glues or adhesives
- Agricultural residues (corn stover, rice hulls or nut shells, manures, poultry litter, horse manure, etc) and/or methane gases from landfills
- Food wastes
- Municipal tree trimming and grass clipping wastes
- Paper and cardboard wastes
- Non adulterated construction wood wastes, pallets

The NJDEP evaluates biomass resources not identified in the RPS.

Examples of eligible facilities for a CORE incentive include:

- Digestion of sewage sludge
- Landfill gas facilities
- Combustion of wood wastes to steam turbine
- Gasification of wood wastes to reciprocating engine
- Gasification or pyrolysis of bio-solid wastes to generation equipment

\* from NJOCE Website

This measure is not recommended due to of noise issues and because the building does not have a steady waste stream to fuel the power generation system. Additionally, purchasing this system and performing modifications to the existing HVAC and electrical systems would greatly outweigh the savings over the life of the equipment.

## **6.6 Demand Response Curtailment**

Presently, electricity is delivered by Atlantic City Electric, which receives the electricity from regional power grid. PJM Interconnection is the regional transmission organization (RTO) that coordinates the movement of wholesale electricity in all or parts of 13 states and the District of Columbia including the State of New Jersey.

Utility Curtailment is an agreement with the PJM Interconnection regional transmission organization and an approved Curtailment Service Provider (CSP) to shed electrical load by either turning major equipment off or energizing all or part of a facility utilizing an emergency generator; therefore, reducing the

electrical demand on the utility grid. Enrolling in the program will require program participants to drop electrical load or turn on emergency generators during high electrical demand conditions or during emergencies. Part of the program also will require that program participants reduce their required load or run emergency generators with notice to test the system.

A pre-approved CSP will require a minimum of 100 kW of load reduction to participate in any curtailment program. The EMS building had an estimated maximum electricity demand of 14 kW in 2009.

This measure is not recommended because the facility does not have adequate load to meet the required minimum load reduction.

## **7.0 EPA PORTFOLIO MANAGER**

The United States Environmental Protection Agency (EPA) is a federal agency in charge of regulating environment waste and policy in the United States. The EPA has released the EPA Portfolio Manager for public use. The program is designed to allow property owners and managers to share, compare and improve upon their facility's energy consumption. Inputting such parameters as electricity, heating fuel, building characteristics and location into the website based program generates a naturalized energy rating score out of 100. Once an account is registered, monthly utility data can be entered to track the savings progress and retrieve an updated energy rating score on a monthly basis.

The EMS building has a Site Energy Usage Index (EUI) of 110 kBtu/ft<sup>2</sup>/year. The EUI can be improved by implementing the noted energy savings measures. By implementing the measures discussed in this report, it is expected that the EUI can be reduced to approximately 62 kBtu/ft<sup>2</sup>/year. The EPA Portfolio Manager did not generate an energy rating score for this building because more than 50% of the building type is not eligible for an energy star rating.

A full EPA Energy Star Portfolio Manager Report is located in Appendix I.

The user name and password for the building's EPA Portfolio Manager Account has been provided to Hank Kolakowski.

## 8.0 RECOMMENDATIONS & CONCLUSIONS

The energy audit conducted by CHA at Emergency Medical Services building in Linwood, New Jersey identified potential ECMs for lighting replacement and storm window installation. Potential annual savings of \$1,100 may be realized for the recommended ECMs, with a summary of the costs, savings, and paybacks as follows:

### ECM-1 Lighting Replacement

Budgetary Cost	Annual Utility Savings				ROI	Potential Incentive*	Payback (without incentive)	Payback (with incentive)
	Electricity		Natural Gas	Total				
	kW	kWh	Therms	\$				
\$						\$	Years	Years
3,200	0	4,060	0	700	1.8	400	4.6	4.0

\* Incentive available through the New Jersey Smart Start program for this ECM. See section 5.0 for other incentive opportunities.

### ECM-2 Install Storm Windows

Budgetary Cost	Annual Utility Savings				ROI	Potential Incentive*	Payback (without incentive)	Payback (with incentive)
	Electricity		Natural Gas	Total				
	kW	kWh	Therms	\$				
\$						\$	Years	Years
2,900	0	210	350	400	2.6	NA	7.3	NA

\* There is no incentive available through the New Jersey Smart Start program for this ECM. See section 5.0 for other incentive opportunities.

## **APPENDIX A**

### **Utility Usage Analysis**


---

City of Linwood  
 CHA Project Number: 22215  
 Emergency Medical Service Building

515 W Patceng Ave  
 Account Number: 0680 4269 9998  
 Meter Number: 105737906

Month	Consumption		Charges				Unit Costs			
	(kWh)	Demand (kW)	Total (\$)	Supply (\$)	Delivery (\$)	Demand (\$)	Consumption (\$)	Blended Rate (\$/kWh)	Consumption (\$/kWh)	Demand (\$/kW)
October-09	2,087	8.8	\$352.34	\$245.18	\$107.16	\$23.51	\$328.83	0.1688	0.1576	2.66
November-09	3,218	8.5	\$506.95	\$364.48	\$142.47	\$20.90	\$486.05	0.1575	0.1510	2.47
December-09	2,236	9.9	\$385.91	\$266.69	\$119.22	\$29.72	\$356.19	0.1726	0.1593	3.01
January-10	2,287	6.9	\$360.01	\$257.67	\$102.34	\$13.34	\$346.67	0.1574	0.1516	1.94
February-10	2,809	7.8	\$443.95	\$317.58	\$126.37	\$18.24	\$425.71	0.1580	0.1516	2.34
March-10	2,197	6.4	\$345.97	\$246.81	\$99.16	\$12.49	\$333.48	0.1575	0.1518	1.96
April-10	2,046	7.8	\$338.81	\$236.76	\$102.05	\$19.46	\$319.35	0.1656	0.1561	2.50
May-10	2,911	9.4	\$477.69	\$340.29	\$137.40	\$24.80	\$452.89	0.1641	0.1556	2.63
June-10	4,270	13.9	\$694.72	\$465.47	\$229.25	\$52.89	\$641.83	0.1627	0.1503	3.80
July-10	6,005	14.5	\$977.00	\$670.50	\$306.50	\$61.58	\$915.42	0.1627	0.1524	4.24
August-10	4,301	12.6	\$699.76	\$472.77	\$226.99	\$48.19	\$651.57	0.1627	0.1515	3.82
September-10	3,665	9.8	\$596.29	\$407.82	\$188.47	\$36.53	\$559.76	0.1627	0.1527	3.73
Total	38,032	14.5	\$6,179.40	\$4,292.02	\$1,887.38	\$361.65	\$5,817.75	0.1625	0.1530	3.11
Most Recent Yr	38,032	14.5	\$6,179.40	\$4,292.02	\$1,887.38	\$361.65	\$5,817.75	0.1625	0.1530	3.11

### Electric Usage - EMS - 515 W Patcong Ave






City of Linwood  
 CHA Project Number: 22215  
 Emergency Medical Service Building

515 W Patcong Ave  
 Account Number: 1 16 35 0028 0 8  
 Meter Number: 337415

Month	Therms	Total Charges	(\$/therm)
September-09	74	\$ 32.44	0.44
October-09	126	\$ 116.36	0.92
November-09	374	\$ 186.08	0.50
December-09	479	\$ 512.38	1.07
January-10	610	\$ 658.43	1.08
February-10	626	\$ 831.47	1.33
March-10	231	\$ 325.41	1.41
April-10	64	\$ 103.96	1.62
May-10	24	\$ 51.96	2.17
June-10	10	\$ 31.46	3.05
July-10	10	\$ 25.28	2.46
August-10	9	\$ 21.69	2.35
September-10	74	\$ 76.00	1.03
Most Recent Yr	2,638	\$ 2,940	\$ 1.11

# Natural Gas Usage - Emergency Medical Service Building



**City of Linwood**  
**CHA Project Number: 22215**  
**Emergency Medical Service Building**  
**New Jersey American Water**

**515 W Patcong Ave**  
**Account Number: 18-1109083-4**  
**Meter Number: 86466394**

Month	Gallons	Total Charges	(\$/Gal.)
August-09	21000	130.44 \$	6.21
September-09	18000	\$ 113.23 \$	6.29
October-09	15000	\$ 95.86 \$	6.39
November-09	5000	\$ 37.95 \$	7.59
December-09	4000	\$ 32.16 \$	8.04
January-10	4000	\$ 32.19 \$	8.05
February-10	5000	\$ 37.95 \$	7.59
March-10	5000	\$ 37.95 \$	7.59
April-10	10000	\$ 66.91 \$	6.69
May-10	24000	\$ 147.97 \$	6.17
June-10	23000	\$ 142.18 \$	6.18
July-10	20000	\$ 124.78 \$	6.24
August-10	26000	\$ 159.46 \$	6.13
September-10	18000	\$ 112.00 \$	6.22
<b>Total</b>			
	198,000	\$ 1,271 \$	6.42
<b>Most Recent Yr</b>			
	159,000	\$ 1,027 \$	6.46

## ELECTRIC MARKETERS LIST

The following is a listing of marketers/suppliers/brokers that have been licensed by the NJ Board of Public Utilities to sell electricity to residential, small commercial and industrial customers served by the Public Service Electric and Gas Company distribution system. **This listing is provided for informational purposes only and PSE&G makes no representations or warranties as to the competencies of the entities listed herein or to the completeness of this listing.**

American Powernet Management  
867 Berkshire Blvd, Suite 101  
Wyomissing, PA 19610  
[www.americanpowernet.com](http://www.americanpowernet.com)

Gerdau Ameristeel Energy Co.  
North Crossman Road  
Sayreville, NJ 08872

PPL EnergyPlus, LLC  
Energy Marketing Center  
Two North Ninth Street  
Allentown, PA 18101  
1-866-505-8825  
<http://www.pplenergyplus.com/>

BOC Energy Services  
575 Mountain Avenue  
Murray Hill, NJ 07974  
[www.boc-gases.com](http://www.boc-gases.com)

Gexa Energy LLC New Jersey  
20 Greenway Plaza, Suite 600  
Houston, TX 77046  
(866) 304-GEXA  
[Beth.miller@gexaenergy.com](mailto:Beth.miller@gexaenergy.com)

Sempra Energy Solutions  
The Mac-Cali Building  
581 Main Street, 8<sup>th</sup> Floor  
Woodbridge, NJ 07095  
(877) 273-6772  
[www.SempraSolutions.com](http://www.SempraSolutions.com)

Commerce Energy Inc.  
535 Route 38, Suite 138  
Cherry Hill, NJ 08002  
(888) 817-8572 or  
(858) 910-8099  
[www.commerceenergy.com](http://www.commerceenergy.com)

Glacial Energy of New Jersey  
2602 McKinney Avenue, Suite 220  
Dallas, TX 75204  
[www.glacialenergy.com](http://www.glacialenergy.com)

South Jersey Energy Company  
1 South Jersey Plaza, Route 54  
Folsom, NJ 08037  
(800) 756-3749  
[www.sjindustries.com](http://www.sjindustries.com)

ConEdison Solutions  
701 Westchester Avenue  
Suite 201 West  
White Plains, NY 10604  
(800) 316-8011  
[www.ConEdSolutions.com](http://www.ConEdSolutions.com)

Hess Corporation  
1 Hess Plaza  
Woodbridge, NJ 07095  
[www.hess.com](http://www.hess.com)

Strategic Energy, LLC  
6 East Main Street, Suite 6E  
Ramsey, NJ 07446  
(888) 925-9115  
[www.sel.com](http://www.sel.com)

Constellation NewEnergy, Inc.  
1199 Route 22 East  
Mountainside, NJ 07092  
908 228-5100  
[www.newenergy.com](http://www.newenergy.com)

Integrus Energy Services, Inc  
99 Wood Avenue, Suite 802  
Iselin, NJ 08830  
[www.integrusenergy.com](http://www.integrusenergy.com)

Suez Energy Resources NA  
333 Thornall Street FL6  
Edison, NJ 08818  
866.999.8374(toll free)  
[www.suezenergyresources.com](http://www.suezenergyresources.com)

Credit Suisse (USA), Inc.  
700 College Road East  
Princeton, NJ 08450  
[www.creditsuisse.com](http://www.creditsuisse.com)

Liberty Power Delaware, LLC  
1901 W Cypress Road, Suite 600  
Fort Lauderdale, FL 33309  
(866) Power-99  
(866) 769-3799  
[www.libertypowercorp.com](http://www.libertypowercorp.com)

UGI Energy Services, Inc.  
d/b/a POWERMARK  
1 Meridian Blvd. Suite 2C01  
Wyomissing, PA 19610  
(800) 427-8545  
[www.ugienergyservices.com](http://www.ugienergyservices.com)

Direct Energy Services, LLC  
One Gateway Center, Suite 2600  
Newark, NJ 07102  
(973) 799-8568  
[www.dirctenergy.com](http://www.dirctenergy.com)

Liberty Power Holdings, LLC  
1901 W Cypress Creek Road, Suite 600  
Fort Lauderdale, FL 33309  
(866) Power-99  
(866) 769-3799  
[www.libertypowercorp.com](http://www.libertypowercorp.com)

FirstEnergy Solutions  
395 Ghent Road Suite 407  
Akron, OH 44333  
(800) 977-0500  
[www.fes.com](http://www.fes.com)

Pepco Energy Services, Inc.  
d/b/a Power Choice  
23 S. Kinderkamack Rd Ste D  
Montvale, NJ 07645  
(800) 363-7499  
[www.pepco-services.com](http://www.pepco-services.com)

## GAS MARKETERS LIST

The following is a listing of marketers/suppliers/brokers that have been licensed by the NJ Board of Public Utilities to sell natural gas to residential, small commercial and industrial customers served by the Public Service Electric and Gas Company distribution system. **This listing is provided for informational purposes only and PSE&G makes no representations or warranties as to the competencies of the entities listed herein or to the completeness of this listing.**

Gateway Energy Services  
44 Whispering Pines Lane  
Lakewood, NJ 08701  
(800) 805-8586  
[www.gesc.com](http://www.gesc.com)

Metro Energy Group, LLC  
14 Washington Place  
Hackensack, NJ 07601  
[www.metroenergy.com](http://www.metroenergy.com)

RPL Holdings, Inc  
601 Carlson Pkwy  
Minnetonka, MN 55305

Great Eastern Energy  
3044 Coney Island Ave. PH  
Brooklyn, NY 11235  
888-651-4121  
[www.greasterngas.com](http://www.greasterngas.com)

Metromedia Energy, Inc.  
6 Industrial Way  
Eatontown, NJ 07724  
(800) 828-9427  
[www.metromediaenergy.com](http://www.metromediaenergy.com)

South Jersey Energy Company  
One South Jersey Plaza, Rte 54  
Folsom, NJ 08037  
(800) 756-3749  
[www.sjindustries.com/sje.htm](http://www.sjindustries.com/sje.htm)

Hess Corporation  
1 Hess Plaza  
Woodbridge, NJ 07095  
(800) 437-7872  
[www.hess.com](http://www.hess.com)

Mitchell- Supreme Fuel  
(NATGASCO)  
532 Freeman Street  
Orange, NJ 07050  
(800) 840-4GAS  
[www.mitchellsupreme.com](http://www.mitchellsupreme.com)

Sprague Energy Corp.  
Two International Drive, Ste 200  
Portsmouth, NH 03801  
800-225-1560  
[www.spragueenergy.com](http://www.spragueenergy.com)

Hudson Energy Services, LLC  
545 Route 17 South  
Ridgewood, NJ 07450  
(201) 251-2400  
[www.hudsonenergyservices.com](http://www.hudsonenergyservices.com)

MxEnergy Inc.  
P.O. Box 177  
Annapolis Junction, MD 20701  
800-375-1277  
[www.mxenergy.com](http://www.mxenergy.com)

Stuyvesant Energy LLC  
642 Southern Boulevard  
Bronx, NY 10455  
(718) 665-5700  
[www.stuyfuel.com](http://www.stuyfuel.com)

Intelligent Energy  
7001 SW 24<sup>th</sup> Avenue  
Gainesville, FL 32607  
Sales: 1 877 I've Got Gas  
(1 877 483-4684)  
Customer Service:  
1 800 927-9794  
[www.intelligentenergy.org](http://www.intelligentenergy.org)

Pepco Energy Services, Inc.  
23 S Kinderkamack Rd, Suite D  
Montvale, NJ 07645  
(800) 363-7499  
[www.pepco-services.com](http://www.pepco-services.com)

Tiger Natural Gas, Inc.  
1422 E. 71st Street, Suite J.  
Tulsa, OK 74136  
1-888-875-6122  
[www.tigernaturalgas.com](http://www.tigernaturalgas.com)

Systrum Energy  
877-SYSTRUM  
(877-797-8786)  
[www.systrumenergy.com](http://www.systrumenergy.com)

Plymouth Rock Energy, LLC  
165 Remsen Street  
Brooklyn, NJ 11201  
866-539-6450  
[www.plymouthrockenergy.com](http://www.plymouthrockenergy.com)

UGI Energy Services, Inc.  
d/b/a GASMARK  
704 E. Main Street, Suite I  
Moorestown, NJ 08057  
856-273-9995  
[www.ugienergyservices.com](http://www.ugienergyservices.com)

Macquarie Cook Energy, LLC  
10100 Santa Monica Blvd, 18<sup>th</sup>  
Fl  
Los Angeles, CA 90067

PPL EnergyPlus, LLC  
Energy Marketing Center  
Two North Ninth Street  
Allentown, PA 18101  
1-866-505-8825  
[www.pplenergyplus.com/natural+gas/](http://www.pplenergyplus.com/natural+gas/)

Woodruff Energy  
73 Water Street  
P.O. Box 777  
Bridgeton, NJ 08302  
(856) 455-1111  
[www.woodruffenergy.com](http://www.woodruffenergy.com)

## **APPENDIX B**

### **ECM-1 Lighting Replacement**



City of Lincoln, NJ  
 CHA #2225  
 Emergency Medical Service Building  
 ECLM1 Lighting Rehabilitation  
 Non-T4 lamps with electronic ballasts

Building Schedule:  
 Existing conditions (master switch):  
 Supply Electric Rate:  
 Demand Rate

Area Description	Number of Lamps	EXISTING CONDITIONS										RETROFIT CONDITIONS										COST ANALYSIS				
		Number of Fixtures	Fixture Type	Lamp Type	Watts per Fixture	Number of Operational Fixtures	Watts per Non-Operational Fixtures	Number of Operational Fixtures	kW/Space	Exist. Control	Daily Hours	Annual Hours	Annual kWh	Number of Fixtures	Watts per Fixture	New Lamp Type	kW/Space	Retrofit Control	Daily Hours	Annual Hours	Annual kWh	kW Saved	Annual kWh Saved	Annual \$ Saved	Retrofit Cost	Simple Payback
Room 1	2	7	222	1-12	82	0	0	0	0.574	switch	1	365	209.51	7	33	1-8	0.291	switch	1	365	84	0.24	185	32	560	17.5
Hallway	2	3	124	1-12	89	0	0	0	0.259	switch	24	8760	2260.08	3	58	1-8	0.177	switch	24	8760	1,951	0.09	710	112	240	2.2
Men's	1	1	123	1-12	57	0	0	0.037	switch	3	1095	40.515	1	26	1-8	0.028	switch	3	1095	28	0.01	12	2	80	35.5	
Women	1	1	124	1-12	57	0	0	0.037	switch	3	1095	40.515	1	26	1-8	0.028	switch	3	1095	28	0.01	12	2	80	35.5	
Main Entrance	2	14	222	1-12	82	0	0	1.204	switch	16	5840	7331.58	14	59	1-8	0.828	switch	16	5840	4,820	0.36	2,302	352	800	8.0	
Supervisor	2	2	222	1-12	82	0	0	0.184	switch	3	1095	179.58	2	33	1-8	0.058	switch	3	1095	72	0.10	107	3	150	6.0	
Hall	2	1	124	1-12	86	0	0	0.088	switch	8	2820	251.12	1	59	1-8	0.059	switch	8	2,920	172	0.03	78	13	80	6.1	
Office	2	1	224	1-12	86	0	0	0.088	switch	8	2820	251.12	1	59	1-8	0.059	switch	8	1,625	105	0.03	49	3	80	9.4	
Storage	2	1	224	1-12	86	0	0	0.088	switch	8	2820	251.12	1	59	1-8	0.059	switch	8	1,625	105	0.03	49	3	80	9.4	
Truck Bay	2	5	128	1-12	173	0	0	1.537	switch	3	1095	179.58	9	38	1-8	0.882	switch	3	1,095	866	0.68	749	138	720	5.2	
<b>TOTALS -</b>		<b>40</b>				<b>6</b>		<b>4.1</b>				<b>11,908</b>	<b>40</b>				<b>2.4</b>					<b>1.7</b>	<b>4,051</b>	<b>892</b>	<b>3,200</b>	<b>4.7</b>

**APPENDIX C**

**ECM-2 Replace Install Storm Windows**





City of Linwood, NJ  
 CHA #22215  
 Building: Emergency Medical Service Building

ECM-2 Install Storm Windows

\*Change U-value and air Infiltration rates based on new windows or storm windows  
 See block load spreadsheet for U-values

**Given**  
 Occupied Cooling Hours per Week  
 Occupied Heating Hours per Week  
 Heating Energy Cost  
 Cooling Cost  
 Occupied Cooling Setpoint Temperature  
 Occupied Heating Setpoint Temperature  
 Unoccupied Cooling Setpoint Temperature  
 Unoccupied Heating Setpoint Temperature  
 Window Factor  
 Proposed U Factor  
 Proposed Air Infiltration  
 Cooling Conversion  
 Heating Btu Conversion

168 Hours  
 168 Hours  
 \$7.11/therm  
 \$0.124 \$/Wh  
 72.0 Degrees F  
 28.0 bu/h air  
 72.0 Degrees F  
 72.0 Degrees F  
 152 sq.ft.  
 0.50 Btu/h sqft deg  
 0.20 cfm/ft  
 12.00 Btu/ton  
 1000.000 Btu/MMBtu  
 0.50 Btu/h sqft deg  
 0.50 cfm/ft  
 12.00 kW/ton

(Assumption)  
 (Assumption)  
 (Assumption)  
 (Assumption)  
 (From window survey)  
 (From window survey)  
 (From window survey)  
 (From window survey)

**Assumptions**

(From ASHRAE Fundamentals)  
 (From ASHRAE Fundamentals)

**Formula**

Cooling Energy Conduction = (Existing U x Area x (OA Temp - RA Temp) x Op Hours)  
 Heating Energy Conduction = (Existing U x Area x (RA Temp - OA Temp) x Op Hours)  
 Cooling Energy Infiltration = (4.5 x Leakage x Perimeter x (OA Enthalpy - RA Enthalpy) x Op Hours)  
 Heating Energy Infiltration = 1.08 x Leakage x Perimeter x (RA Temp - OA Temp) x Op Hours  
 Load = (Conduction) + (Infiltration)  
 Cooling Energy = (Cooling Load) / (12,000 Btu/Ton) x (kw/Ton)  
 Heating Energy = (Heating Load) / (1,000,000 Btu/MMBtu) / (Boiler Efficiency)  
 Energy Cost = (Energy) x (Cost/Unit)

Existing Operation	OA Enthalpy	OA Temp	Total Hours	Cooling Occupied Hours	Heating Occupied Hours	Heating Unoccupied Hours	Cooling Unoccupied Conduction	Heating Unoccupied Conduction	Heating Occupied Conduction	Cooling Occupied Conduction	Heating Unoccupied Infiltration	Heating Occupied Infiltration	Cooling Occupied Infiltration	Heating Unoccupied Infiltration
Cooling	38.3	82.5	78	78.0	0.0	0.0	302.211	0	0	215.444	0	0	0	0
Cooling	38.6	87.5	132	132.0	0.0	0.0	398.694	0	0	297.690	0	0	0	0
Cooling	33.5	84.0	344	344.0	0.0	0.0	682.668	0	0	450.755	0	0	0	0
Cooling	31.6	77.5	566	566.0	0.0	0.0	598.357	0	0	437.085	0	0	0	0
Heating	30.3	72.5	755	755.0	0.0	0.0	71.348	0	0	281.506	0	0	0	0
Heating	27.9	67.5	780	780.0	0.0	0.0	0	663.960	0	0	0	260.193	0	0
Heating	24.6	62.5	889	889.0	0.0	0.0	0	1,598.200	0	0	0	631.695	0	0
Heating	21.5	57.5	742	742.0	0.0	0.0	0	2,033.451	0	0	0	769.892	0	0
Heating	18.7	52.5	627	627.0	0.0	0.0	0	2,310.469	0	0	0	871.595	0	0
Heating	16.2	47.5	725	725.0	0.0	0.0	0	3,357.113	0	0	0	1,285.111	0	0
Heating	14.3	42.5	785	785.0	0.0	0.0	0	4,432.523	0	0	0	1,671.694	0	0
Heating	12.4	37.5	784	784.0	0.0	0.0	0	5,112.072	0	0	0	1,927.981	0	0
Heating	10.4	32.5	682	682.0	0.0	0.0	0	6,091.471	0	0	0	2,242.410	0	0
Heating	9.7	27.5	345	345.0	0.0	0.0	0	2,801.623	0	0	0	1,084.326	0	0
Heating	7	22.5	229	229.0	0.0	0.0	0	2,142.410	0	0	0	807.694	0	0
Heating	5.4	17.5	189	189.0	0.0	0.0	0	1,646.765	0	0	0	734.220	0	0
Heating	3.9	12.5	70	70.0	0.0	0.0	0	787.165	0	0	0	299.681	0	0
Heating	2.9	7.5	20	20.0	0.0	0.0	0	243.910	0	0	0	81.951	0	0
Heating	1.2	2.5	8	8.0	0.0	0.0	0	105.084	0	0	0	39.682	0	0
Heating	-0.2	-2.5	0	0.0	0.0	0.0	0	0	0	0	0	0	0	0
Heating	-1.4	-7.5	0	0.0	0.0	0.0	0	0	0	0	0	0	0	0
Subtotal =			8,760	1,876	6,885	0	3,031,276	32,723,833	0	1,701,721	0	12,341,657	0	0

Cooling Load =	2031278	+	1701721	=	3,732,999	btu
Cooling Energy =	3732999	/	12000	=	311.083	kWh
Cooling Energy Cost =	311.083	×	\$0.162	=	\$50.40	
Heating Energy Cost =	32723833	×	\$0.162	=	\$5,299,261	

Heating Load =	$(32723593) \times (12341897) =$	45,065,650 BTU
Heating Energy =	$45065650 \times (72\% / 100000) =$	625 Therms
Heating Energy Cost =	$625.81 \times (\$1.115) =$	\$ 698

Operation	OA Enthalpy	OA Temp	Total Hours	Heating Hours	Heating Occupied Hours	Heating Unoccupied Hours	Cooling Hours	Cooling Occupied Hours	Cooling Unoccupied Hours	Heating Occupied Conduction	Heating Unoccupied Conduction	Cooling Occupied Infiltration	Cooling Unoccupied Infiltration	Heating Occupied Infiltration	Heating Unoccupied Infiltration
Cooling	36.3	82.5	78	78.0	0.0	0.0	0.0	0.0	0.0	0	0	0	0	0	0
Cooling	36.8	87.5	132	132.0	0.0	0.0	0.0	0.0	0.0	0	0	0	0	0	0
Cooling	33.5	82.5	344	344.0	0.0	0.0	0.0	0.0	0.0	0	0	0	0	0	0
Cooling	31.8	77.5	568	568.0	0.0	0.0	0.0	0.0	0.0	0	0	0	0	0	0
Cooling	30.3	72.5	755	755.0	0.0	0.0	0.0	0.0	0.0	0	0	0	0	0	0
Heating	27.9	67.5	790	790.0	790.0	0.0	0.0	0.0	0.0	315,800	0	0	0	100,077	0
Heating	24.8	62.5	889	889.0	889.0	0.0	0.0	0.0	0.0	760,095	0	0	0	240,798	0
Heating	21.6	57.5	742	742.0	742.0	0.0	0.0	0.0	0.0	968,310	0	0	0	306,701	0
Heating	18.7	52.5	627	627.0	627.0	0.0	0.0	0.0	0.0	1,100,385	0	0	0	348,502	0
Heating	16.2	47.5	785	785.0	785.0	0.0	0.0	0.0	0.0	1,598,625	0	0	0	506,444	0
Heating	14.3	42.5	784	784.0	784.0	0.0	0.0	0.0	0.0	2,110,725	0	0	0	771,193	0
Heating	12.4	37.5	682	682.0	682.0	0.0	0.0	0.0	0.0	2,434,320	0	0	0	868,678	0
Heating	10.4	32.5	682	682.0	682.0	0.0	0.0	0.0	0.0	2,434,320	0	0	0	868,678	0
Heating	8.7	27.5	345	345.0	345.0	0.0	0.0	0.0	0.0	1,361,725	0	0	0	437,730	0
Heating	7	22.5	228	228.0	228.0	0.0	0.0	0.0	0.0	1,020,195	0	0	0	323,196	0
Heating	5.4	17.5	189	189.0	189.0	0.0	0.0	0.0	0.0	927,045	0	0	0	253,688	0
Heating	3.9	12.5	70	70.0	70.0	0.0	0.0	0.0	0.0	374,850	0	0	0	118,752	0
Heating	2.5	7.5	8	8.0	8.0	0.0	0.0	0.0	0.0	116,100	0	0	0	38,760	0
Heating	1.2	2.5	8	8.0	8.0	0.0	0.0	0.0	0.0	50,940	0	0	0	15,653	0
Heating	-0.2	-2.5	0	0.0	0.0	0.0	0.0	0.0	0.0	0	0	0	0	0	0
Heating	-1.4	-7.5	0	0.0	0.0	0.0	0.0	0.0	0.0	0	0	0	0	0	0
Subtotal =			5,780	1,875	6,855	0	0	967,275	15,582,825	0	0	0	0	4,938,639	0

Conduction	$967275 \times (1.20) =$	1,160,730
Infiltration	$680088 \times (1.20) =$	816,106
Cooling Load	$1647983 \times (1.20) =$	197,758
Cooling Energy	$197758 \times (72\% / 100000) =$	285 Therms
Cooling Energy Cost	$285 \times (\$1.115) =$	\$ 318

EXISTING COOLING ENERGY	373.30 kWh	\$ 60.65
EXISTING HEATING ENERGY	625.91 therms	\$ 697.77
EXISTING ENERGY COST		\$ 758.42
PROPOSED COOLING ENERGY	164.80 kWh	\$ 26.26
PROPOSED HEATING ENERGY	284.89 therms	\$ 317.71
PROPOSED ENERGY COST		\$ 343.97
COOLING ENERGY SAVINGS	208.50 kWh	\$ 33.89
HEATING ENERGY SAVINGS	340.92 therms	\$ 380.06
ENERGY COST SAVINGS		\$ 413.94

55.0% of existing  
54.6% of existing  
54.0% of existing

Summary

Comments



## **APPENDIX D**

### **ECM-3 Replace Unit Heaters with Infrared Heaters**

City of Linwood, NJ  
 CHA #22215  
 Building: Emergency Medical Service Building

ECM-S: Replace Unit Heaters with Infrared Heaters

Building Footprint: 600 SF  
 Natural Gas Heat Content: 100,000 Btu/Therm  
 Building Balance Temp: 60 F  
 Internal Gains: 1,000 Btu/hr  
 Unocc Internal Gain factor: 0.0  
 Ave Occ Internal Gain Factor: 0.0

Ex Occupied Htg Temp: 68 F  
 Ex Unoccupied Htg Temp: 60 F  
 Occupied Heating UA: 218 Btu/hr/F  
 Unoccupied Heating UA: 218 Btu/hr/F

Heating Energy Savings: 221 Therms/yr  
 Electric Energy Savings: 1783 kWh/yr

Existing Burner Efficiency: 72.5% Existing unit heater burner efficiency  
 Existing Heat Distribution Effectiveness: 85.0% Heat Distribution Factor per ASHRAE Handbook - Fundamentals for Unit Heaters  
 Proposed Burner Efficiency: 85.0% Based on Reznor Infrared Tube Heaters  
 Proposed Heat Distribution Effectiveness: 100% Heat Distribution Factor per ASHRAE Handbook - Fundamentals for Infrared Heaters

Avg Outdoor Air Temp, Bin A	Existing Equipment Bin Hours B	Occupied Equipment Bin Hours C	Unoccupied Equipment Bin Hours D	Occupied				Unoccupied				PROPOSED LOADS				Internal Gain BTUH P	Existing Heating Therms M	Proposed Heating Therms N	Hrs of Operation
				Envelope Load BTUH E	Ventilation Load BTUH F	Internal Gain BTUH G	Unoccupied Envelope Load BTUH H	Unoccupied Ventilation Load BTUH I	Internal Gain BTUH J	Envelope Load BTUH K	Ventilation Load BTUH L	Internal Gain BTUH M	Unoccupied Envelope Load BTUH O	Unoccupied Ventilation Load BTUH Q	Internal Gain BTUH R				
102.5	43.5	0	0	0	0	-1,474	0	0	0	0	-1,474	0	0	0	0	0	0	0	0
97.5	36.5	0	0	0	0	-1,474	0	0	0	0	-1,474	0	0	0	0	0	0	0	0
92.5	30.5	0	0	0	0	-1,474	0	0	0	0	-1,474	0	0	0	0	0	0	0	0
87.5	24.5	0	0	0	0	-1,474	0	0	0	0	-1,474	0	0	0	0	0	0	0	0
82.5	18.5	0	0	0	0	-1,474	0	0	0	0	-1,474	0	0	0	0	0	0	0	0
77.5	12.5	0	0	0	0	-1,474	0	0	0	0	-1,474	0	0	0	0	0	0	0	0
72.5	6.5	0	0	0	0	-1,474	0	0	0	0	-1,474	0	0	0	0	0	0	0	0
67.5	0.5	0	0	0	0	-1,474	0	0	0	0	-1,474	0	0	0	0	0	0	0	0
62.5	0	0	0	0	0	-1,474	0	0	0	0	-1,474	0	0	0	0	0	0	0	0
57.5	0	0	0	0	0	-1,474	0	0	0	0	-1,474	0	0	0	0	0	0	0	0
52.5	0	0	0	0	0	-1,474	0	0	0	0	-1,474	0	0	0	0	0	0	0	0
47.5	0	0	0	0	0	-1,474	0	0	0	0	-1,474	0	0	0	0	0	0	0	0
42.5	0	0	0	0	0	-1,474	0	0	0	0	-1,474	0	0	0	0	0	0	0	0
37.5	0	0	0	0	0	-1,474	0	0	0	0	-1,474	0	0	0	0	0	0	0	0
32.5	0	0	0	0	0	-1,474	0	0	0	0	-1,474	0	0	0	0	0	0	0	0
27.5	0	0	0	0	0	-1,474	0	0	0	0	-1,474	0	0	0	0	0	0	0	0
22.5	0	0	0	0	0	-1,474	0	0	0	0	-1,474	0	0	0	0	0	0	0	0
17.5	0	0	0	0	0	-1,474	0	0	0	0	-1,474	0	0	0	0	0	0	0	0
12.5	0	0	0	0	0	-1,474	0	0	0	0	-1,474	0	0	0	0	0	0	0	0
7.5	0	0	0	0	0	-1,474	0	0	0	0	-1,474	0	0	0	0	0	0	0	0
2.5	0	0	0	0	0	-1,474	0	0	0	0	-1,474	0	0	0	0	0	0	0	0
-2.5	0	0	0	0	0	-1,474	0	0	0	0	-1,474	0	0	0	0	0	0	0	0
-7.5	0	0	0	0	0	-1,474	0	0	0	0	-1,474	0	0	0	0	0	0	0	0
TOTALS	8,760	8,760	0	0	0	-1,474	0	0	0	0	-1,474	0	0	0	0	0	0	0	0

Existing Building Ventilation & Infiltration (occ): 378 cfm  
 Additional ventilation to offset overhead: 216 cfm  
 Existing Building Ventilation & Infiltration (unocc): 95 cfm  
 Due to opening of overhead doors: 378 cfm

Electrical Requirements for Heating Equipment

Unit	Htg Hrs	Amps	Volts	Phase	Power Factor	Annual kWh
UH-1	2,119	5.7	115	1	0.8	1111
UH-2	2,119	5.7	115	1	0.8	1111
Total						2223

Proposed Equipment

Unit	Htg Hrs	Amps	Volts	Phase	Power Factor	Annual kWh
Infrared Ht	2,119	1.1	115	1	0.8	214
Infrared Ht	2,119	1.1	115	1	0.8	214
Total						428

Electrical data based on Reznor VFS Series Infrared Heaters

Avg OA Temp	Heating Hrs	Assumed % Time of Operation	Hrs of Operation
102.5	0	0%	0
97.5	0	0%	0
92.5	0	0%	0
87.5	0	0%	0
82.5	0	0%	0
77.5	0	0%	0
72.5	0	0%	0
67.5	0	0%	0
62.5	0	0%	0
57.5	0	0%	0
52.5	0	0%	0
47.5	0	0%	0
42.5	0	0%	0
37.5	0	0%	0
32.5	0	0%	0
27.5	0	0%	0
22.5	0	0%	0
17.5	0	0%	0
12.5	0	0%	0
7.5	0	0%	0
2.5	0	0%	0
-2.5	0	0%	0
-7.5	0	0%	0
	5,216	41%	2,139

City of Linwood, NJ  
CHA #22215

Building: Emergency Medical Service Building

ECM-3: Replace Unit Heaters with Infrared Heaters

Multipliers	
Material:	0.98
Labor:	1.21
Equipment:	1.09

Description	QTY	UNIT	UNIT COSTS			SUBTOTAL COSTS			TOTAL COST	REMARKS
			MAT.	LABOR	EQUIP.	MAT.	LABOR	EQUIP.		
Unit Heater Removal	2	EA		\$ 450		\$ -	\$ -	\$ -		
20" NG Infrared Tube Heater 75 MBH	2	EA	\$ 1,200	\$ 325		\$ 2,352	\$ 787	\$ 3,139	Includes Controls	
Miscellaneous Gas Piping, Valves, etc.	2	EA	\$ 200	\$ 250		\$ 392	\$ 605	\$ 997		
4" Class B Vent Piping	75	LF	\$ 6.70	\$ 10		\$ 492	\$ 908	\$ 1,400	Use Common Vents	
4" Chimney Cap	2	EA	\$ 11	\$ 10		\$ 22	\$ 24	\$ 46	Use Common Vents	
Roof Flashing	2	EA	\$ 28	\$ 10		\$ 55	\$ 24	\$ 79	Use Common Vents	
Miscellaneous electrical	1	LS		\$ 500		\$ -	\$ 605	\$ 605		
						\$ -	\$ -	\$ -		

Note: Unit selections and budgetary pricing are per Reznor VR series infrared tube heaters.

\$7,354	Subtotal
\$1,103	15% Contingency
\$1,269	15% Contractor O&P
\$0	0% Engineering
<b>\$9,726</b>	<b>Total</b>

## **APPENDIX E**

### **ECM-4 Increase Wall Insulation**

---

City of Linwood, NJ  
CHA #22215  
Building: Emergency Medical Service Building

**ECM-4 Increase Wall Insulation**

	Garage Area
Total Existing Wall Area	500 sf
Existing U-value	0.25 Btu/hr/(sf°F)
Existing R-value	4.00
Proposed U-value	0.04 Btu/hr/(sf°F)
Proposed R-value	24.12
Heating Efficiency	72%
Cooling Efficiency	0.00 kW/ton

**Existing Cooling**

Max. North Wall Cooling Load	0 Btu/hr
Max. East Wall Cooling Load	2,456 Btu/hr
Max. South Wall Cooling Load	1,485 Btu/hr
Max. West Wall Cooling Load	1,375 Btu/hr

**Proposed Cooling**

Max. North Wall Cooling Load	0 Btu/hr
Max. East Wall Cooling Load	414 Btu/hr
Max. South Wall Cooling Load	246 Btu/hr
Max. West Wall Cooling Load	223 Btu/hr

**Occupied Cooling Setpoint**

Unoccupied Cooling Setpoint	60 F
Occupied Cooling Setpoint	60 F

**Existing Cooling Total**

Proposed Cooling Total	3,828,375 Btu/yr
Savings	2,290,065 Btu/yr
Input	1,538,310 Btu/yr
	0.88 therms

**Existing Heating**

Existing Heating Load Temp Diff.	48 F
Existing Max. Wall Heating Load	8,640 Btu/hr
Heating On Point	60 F

**Proposed Heating**

Proposed Max. Heating Load	1,433 Btu/hr
----------------------------	--------------

**Occupied Heating Setpoint**

Unoccupied Heating Setpoint	62 F
Occupied Heating Setpoint	62 F

**Existing Heating Total**

Proposed Heating Total	3,828,375 Btu/yr
Savings	2,290,065 Btu/yr
Input	1,538,310 Btu/yr
	0.88 therms

Avg Outdoor Air Temp. Bins °F	Existing Equipment Bins Hours	Occupied Equipment Bins Hours	Unoccupied Equipment Bins Hours	Occupied				Unoccupied				Existing Heating Load (Btu/yr)	Existing Cooling Load (KW/yr)	Proposed Heating Load (Btu/yr)	Proposed Cooling Load (KW/yr)	
				Existing Heat Gain (Btu/hr)	Proposed Heat Gain (Btu/hr)	Existing Heat Loss (Btu/hr)	Proposed Heat Loss (Btu/hr)	Existing Heat Gain (Btu/hr)	Proposed Heat Gain (Btu/hr)	Existing Heat Loss (Btu/hr)	Proposed Heat Loss (Btu/hr)					
87.5	9	9	0	5,238	879	-	-	5,238	879	-	-	-	-	-	-	-
82.5	69	69	0	4,591	761	-	-	4,591	761	-	-	-	-	-	-	-
87.5	132	132	0	3,885	644	-	-	3,885	644	-	-	-	-	-	-	-
82.5	344	344	0	3,179	527	-	-	3,179	527	-	-	-	-	-	-	-
77.5	566	566	0	2,472	410	-	-	2,472	410	-	-	-	-	-	-	-
72.5	755	755	0	1,766	293	-	-	1,766	293	-	-	-	-	-	-	-
67.5	780	780	0	938	176	-	-	1,080	176	-	-	-	-	-	-	-
62.5	889	889	0	313	59	-	-	353	59	-	-	-	-	-	-	-
57.5	742	742	0	-	-	568	92	-	-	568	92	-	-	563	93	-
52.5	627	627	0	-	-	1,188	197	-	-	1,188	197	-	-	1,188	197	-
47.5	725	725	0	-	-	1,813	301	-	-	1,813	301	-	-	1,813	301	-
42.5	795	795	0	-	-	2,438	404	-	-	2,438	404	-	-	2,438	404	-
37.5	784	784	0	-	-	3,063	508	-	-	3,063	508	-	-	3,063	508	-
32.5	682	682	0	-	-	3,688	612	-	-	3,688	612	-	-	3,688	612	-
27.5	345	345	0	-	-	4,313	715	-	-	4,313	715	-	-	4,313	715	-
22.5	229	229	0	-	-	4,938	819	-	-	4,938	819	-	-	4,938	819	-
17.5	189	189	0	-	-	5,563	922	-	-	5,563	922	-	-	5,563	922	-
12.5	70	70	0	-	-	6,188	1,026	-	-	6,188	1,026	-	-	6,188	1,026	-
7.5	20	20	0	-	-	6,813	1,130	-	-	6,813	1,130	-	-	6,813	1,130	-
2.5	8	8	0	-	-	7,438	1,233	-	-	7,438	1,233	-	-	7,438	1,233	-
-2.5	0	0	0	-	-	8,063	1,337	-	-	8,063	1,337	-	-	8,063	1,337	-
-7.5	0	0	0	-	-	8,688	1,441	-	-	8,688	1,441	-	-	8,688	1,441	-
<b>TOTALS</b>	<b>8,760</b>	<b>8,760</b>	<b>0</b>											<b>13,826,375</b>		<b>2,260,065</b>



City of Linwood, NJ  
 CHA #22215  
 Building: Emergency Medical Service Building  
 ECM-4 Increase Wall Insulation

Multipliers	
Material:	0.98
Labor:	1.21
Equipment:	1.09

Description	QTY	UNIT	UNIT COSTS			SUBTOTAL COSTS			TOTAL COST	REMARKS
			MAT.	LABOR	EQUIP.	MAT.	LABOR	EQUIP.		
Batt Insulation	500	SF	\$ 0.84	\$ 0.36		\$ 412	\$ 218	\$ -	\$ 629	
2 layers 5/8" sheet rock	500	SF	\$ 0.85	\$ 1.68		\$ 417	\$ 1,014	\$ -	\$ 1,431	
10' High Metal Stud wall	50	LF	\$ 12	\$ 7		\$ 588	\$ 424	\$ -	\$ 1,012	
						\$ -	\$ -	\$ -	\$ -	
						\$ -	\$ -	\$ -	\$ -	
						\$ -	\$ -	\$ -	\$ -	
						\$ -	\$ -	\$ -	\$ -	
						\$ -	\$ -	\$ -	\$ -	
						\$ -	\$ -	\$ -	\$ -	
						\$ -	\$ -	\$ -	\$ -	
						\$ -	\$ -	\$ -	\$ -	
						\$ -	\$ -	\$ -	\$ -	
						\$ -	\$ -	\$ -	\$ -	

\$ 3,072	Subtotal
\$ 153.59	5% Contingency
\$ 161.27	Contractor
\$ 3,387	5% O&P
	Total

**APPENDIX F**

**ECM-5 Furnace Replacement**

City of Linwood, NJ  
CHA #22215

Emergency Medical Service Building

ECM-5 Furnace Replacement

Existing Fuel	Nat. Gas	▼
Proposed Fuel	Nat. Gas	▼

Item	Value	Units	Formula/Comments
Baseline Fuel Cost	\$ 1.11		
Proposed Fuel Cost	\$ 1.11		
Baseline Fuel Use	2,518	Therms	Based on historical utility data
Existing Boiler Plant Efficiency	80%		Estimated
Baseline Boiler Load	207,429	Mbtu/yr	Baseline Fuel Use x Existing Efficiency x 100 Mbtu/Therms
Baseline Fuel Cost	\$ 2,807		
Proposed Boiler Plant Efficiency	92%		New Condensing Furnace
Proposed Fuel Use	2,189	Therms	Baseline Boiler Load / Proposed Efficiency / 100 Mbtu/Therms
Proposed Fuel Cost	\$ 2,441		
Annual Savings	328	Therms	
Annual Savings	\$ 366	/yr	

\*Note to engineer: Link savings back to summary sheet in appropriate column.

City of Linwood, NJ

CHA #22215

Building: Emergency Medical Service Building

ECM-5 Furnace Replacement

Multipliers	
Material:	0.98
Labor:	1.21
Equipment:	1.09

Description	QTY	UNIT	UNIT COSTS			SUBTOTAL COSTS			TOTAL COST	REMARKS
			MAT.	LABOR	EQUIP.	MAT.	LABOR	EQUIP.		
New Lennox Furnace										
G-51 direct vent	1	EA	\$2,000.00	\$1,500.00		\$ -	\$ -	\$ -	\$ -	
new direct vent	1	LS	\$ 150	\$ 100		\$ 1,960	\$ 1,815	\$ -	\$ 3,775	
gas re-connection	1	LS	\$ 100	\$ 75		\$ 147	\$ 121	\$ -	\$ 268	
electrical +thermostat	1	LS	\$ 400	\$ 400		\$ 98	\$ 91	\$ -	\$ 189	
Ductwork reconnection	1	LS	\$ 400	\$ 400		\$ 392	\$ 484	\$ -	\$ 876	
			\$ 400	\$ 400		\$ 392	\$ 484	\$ -	\$ 876	
						\$ -	\$ -	\$ -	\$ -	
						\$ -	\$ -	\$ -	\$ -	
						\$ -	\$ -	\$ -	\$ -	
						\$ -	\$ -	\$ -	\$ -	
						\$ -	\$ -	\$ -	\$ -	
						\$ -	\$ -	\$ -	\$ -	

\$ 5,984	Subtotal
\$ 299.19	5% Contingency
\$ 314.15	Contractor
	5% O&P
<b>\$ 6,597</b>	<b>Total</b>

**APPENDIX G**

**New Jersey Pay For Performance  
Incentive Program**

*[Faint, illegible text, likely bleed-through from the reverse side of the page]*

**City of Linwood, NJ  
CHA #22215  
Emergency Medical Service Building**

**New Jersey Pay For Performance Incentive Program**

**Note:** The following calculation is based on the New Jersey Pay For Performance Incentive Program per April, 2010. Building must have a minimum average electric demand of 200 kW. This minimum is waived for buildings owned by local governments or non-profit organizations. The incentive values represented below are applicable through December 31, 2010.

Total Building Area (Square Feet)	3,000
Is this audit funded by the NJ BPU (Y/N)	Yes

Bureau of Public Utilities (BPU)

Incentive #1		
Audit not funded by NJ BPU	\$0.10	\$/sqft
Audit is funded by NJ BPU	\$0.05	\$/sqft

	Annual Utilities	
	kWh	Therms
Existing Cost (from utility)	\$4,163	\$2,940
Existing Usage (from utility)	38,032	2,638
Proposed Savings	6,053	1,151
Existing Total MMBtus	394	
Proposed Savings MMBtus	136	
% Energy Reduction	34.5%	
Proposed Annual Savings	\$2,291	

	Min (Savings = 15%)		Increase (Savings > 15%)		Max Incentive		Achieved Incentive	
	\$/kWh	\$/therm	\$/kWh	\$/therm	\$/kWh	\$/therm	\$/kWh	\$/therm
Incentive #2	\$0.11	\$1.10	\$0.005	\$0.05	\$0.13	\$1.45	\$0.13	\$1.45
Incentive #3	\$0.07	\$0.70	\$0.005	\$0.05	\$0.09	\$1.05	\$0.09	\$1.05

	Incentives \$		
	Elec	Gas	Total
Incentive #1	\$0	\$0	\$150
Incentive #2	\$787	\$1,670	\$2,456
Incentive #3	\$545	\$1,209	\$1,754
Total All Incentives	\$1,332	\$2,879	\$4,360

Total Project Cost	\$25,775
--------------------	----------

		Allowable Incentive
% Incentives #1 of Utility Cost*	2.1%	\$150
% Incentives #2 of Project Cost**	9.5%	\$2,456
% Incentives #3 of Project Cost**	6.8%	\$1,754
Total Eligible Incentives***		\$4,360
Project Cost w/ Incentives		\$21,415

Project Payback (years)	
w/o Incentives	w/ Incentives
11.2	9.3

\* Maximum allowable incentive is 50% of annual utility cost if not funded by NJ BPU, and %25 if it is.

\*\* Maximum allowable amount of Incentive #2 is 30% of total project cost.

Maximum allowable amount of Incentive #3 is 20% of total project cost.


\*\*\* Maximum allowable amount of Incentive #1 is \$50,000 if not funded by NJ BPU, and \$25,000 if it is.

Maximum allowable amount of Incentive #2 & #3 is \$1 million per gas account and \$1 million per electric account


## APPENDIX H

### Wind





## Wind Resource of New Jersey Mean Annual Wind Speed at 30 Meters



**AWS Truewind**

Projection: Transverse Mercator,  
UTM Zone 17 WGS84

Spatial Resolution of Wind Resource Data: 200m  
This map was created by AWS Truewind using the MesoMap system and historical weather data. Although it is believed to represent an accurate overall picture of the wind energy resource, estimates at any location should be confirmed by measurement.

The transmission line information was obtained by AWS Truewind from the Global Energy Decisions Velocity Suite. AWS does not warrant the accuracy of the transmission line information.



## APPENDIX I

### EPA Portfolio Manager

[The content of this table is extremely faint and illegible. It appears to be a large table with multiple columns and rows, possibly containing data related to the EPA Portfolio Manager. The text is too light to transcribe accurately.]

Home > My Portfolio > EMS Building > Edit Other - Fire Station/Police Station Space

**Edit Other - Fire Station/Police Station Space: Main Space**

To edit a space attribute, please select the "Edit" link at the far right of each row

**REQUIRED**

Please select the Other space type category that best describes your facility. [More information about selecting space types](#)

Fire Station/Police Station

Space Name:

**Current Space Attribute Values**


Space Attribute	Space Attribute Value (Temporary values should only be used if an Annual value is not currently known) <small>(Weeks/Year)</small>	Use Default Value	Unit	Effective Date (When this Attribute Value was first true) (MM/DD/YYYY)	Last Updated	
Gross Floor Area (required for benchmarking)	3800	N/A	Sq Ft	01/01/1980	01/06/2011 by LHMWOOD550	<a href="#">Edit</a>
Number of PCs	1			01/01/1900	01/06/2011 by LHMWOOD550	<a href="#">Edit</a>
Weekly operating hours	168		Hours	01/01/1980	01/06/2011 by LHMWOOD550	<a href="#">Edit</a>
Workers on Main Shift	2			01/01/1980	01/06/2011 by LHMWOOD550	<a href="#">Edit</a>

**Space Revision History**

Space Attribute	Value	Use Default Value	Units	Effective Date (When this Attribute Value was first true) (MM/DD/YYYY)	Revised
No Revision History					

**APPENDIX J**

**Block Load Models & Equipment Inventory**



# HEAT GAIN/LOSS WORKSHEET

Project Name: City of Linwood, NJ  
 Location: Linwood, NJ  
 Building Name: Emergency Medical Service Building  
 Engineer: Frank Cuttitta

Project No.: CHA#P2215  
 Site Elevation: 17 Feet  
 Date: 12/01/10  
 Specific Volume: 14.00 CF/#

Building/Facility Designation: Emergency Medical Service Building

Outdoor Winter Design DB Temperature	<u>14</u> °F	Indoor Winter Design DB Temperature	<u>72</u> °F
Outdoor Summer Design DB Temperature	<u>91</u> °F	Indoor Summer Design DB Temperature	<u>72</u> °F
Outdoor Summer Design WB Temperature	<u>79</u> °F	Indoor Summer Design WB Temperature	<u>60</u> °F
Outdoor Summer Humidity Ratio	<u>0.0121</u> #/lb	Indoor Air (70°F) Humidity Ratio	<u>0.0079</u> #/lb

**ENVELOPE DESCRIPTIONS (Descriptions are from Interior to Exterior)**

**Walls (Select One - Type X)**

	R Value	Wall Type
<input type="checkbox"/> Steel Siding, 4" Insulation, Steel Siding	15.2	1
<input type="checkbox"/> Plaster or Gypsum, frame construction, 5" Insulation, 1" stucco	18.2	1
<input type="checkbox"/> 4" WH CMU, 1" Insulation, Finished Exterior	5.2	2
<input type="checkbox"/> Plaster or Gypsum, frame construction, 3" Insulation, 8" LW CMU	7.8	5
<input type="checkbox"/> 4" Face Brick, 2" Concrete, 1" Insulation, Exterior Finish	5.1	12
<input type="checkbox"/> 4" Face Brick, 4" Concrete, 1" Insulation, Exterior Finish	4.0	11
<input checked="" type="checkbox"/> Interior Finish, 2" Insulation, 8" CMU, 4" Face Brick	10.9	16
<input type="checkbox"/> Finished Surface, 8" LW CMU (filled), Air Space, 4" Face Brick	11.1	16
<input type="checkbox"/> Stucco or Gypsum, 2.5" Insul, Face Brick	14.3	10
<input type="checkbox"/> 4" Block, 1" Insulation, 8" Block	19.9	16
<input type="checkbox"/> U value calculator	<u>4.0</u>	

**Roofs (Select One)**

	R Value	Roof Type
<input type="checkbox"/> Tectum Deck, 3.3" Insul, BU Roof	13.0	1
<input type="checkbox"/> Steel Deck, 5" Insul, BU Roof	18.2	1
<input type="checkbox"/> Attic Roof with 8" Insul	25.0	4
<input type="checkbox"/> 4" HW Concrete Deck, BU Roof	2.7	2
<input type="checkbox"/> Ceiling, 3" Insulation, 4" Concrete Deck, BU Roof	14.9	4
<input type="checkbox"/> Ceiling, 4" Concrete Deck, 3" Insulation, BU Roof	18.5	13
<input type="checkbox"/> Ceiling, 4" Concrete Deck, 6" Insulation, BU Roof	21.7	14
<input checked="" type="checkbox"/> Ceiling, Wood Deck, 6" Insulation, Felt & Membrane	20.0	10
<input type="checkbox"/> Wood Deck, 6" Insulation, Felt & Membrane	18.0	
<input type="checkbox"/> U value calculator	<u>22.1</u>	

**Windows (Select One)**

	U Value
<input checked="" type="checkbox"/> Aluminum Frame, 1/8" SP Glazing	1.05
<input type="checkbox"/> Aluminum Frame, 1/4" DP Glazing	0.60
<input type="checkbox"/> Aluminum Frame, 3/16" DP Glazing	0.62
<input type="checkbox"/> Aluminum Frame, 1/2" DP Glazing	0.50
<input type="checkbox"/> Skylights	0.90
<input type="checkbox"/> Other	1.05

	No Storm
Flat Glass	1.05
Flat Glass (e=6)	1.00
Flat Glass (e=0.4)	0.90
Flat Glass (e=0.2)	0.77
Double Glaze (3/16 in air)	0.63
Double Glaze (1/4 in air)	0.60
Double Glaze (1/2 in air)	0.53
Double Glaze (e=6)	0.50
Double Glaze (e=0.4)	0.42
Double Glaze (e=0.2)	0.35
Triple Glaze (1/4 in air)	0.42
Triple Glaze (1/2 in air)	0.35

**BUILDING CHARACTERISTICS**

Roof Area: 2,400 SF  
 Occupied Area: 2,400 SF  
 Return Plenum?  n

	Gross Wall Length	Average Wall Height	Ceiling Height	Window Area	Door Area	Net Wall Area
North Exposure	<u>68</u> Ft	<u>10.0</u> Ft	<u>9.0</u> Ft	<u>30</u> SF	<u>56</u> SF	594 SF
East Exposure	<u>44</u> Ft	<u>10.0</u> Ft	<u>9.0</u> Ft	<u>0</u> SF	<u>0</u> SF	440 SF
South Exposure	<u>68</u> Ft	<u>10.0</u> Ft	<u>9.0</u> Ft	<u>30</u> SF	<u>15</u> SF	635 SF
West Exposure	<u>44</u> Ft	<u>10.0</u> Ft	<u>9.0</u> Ft	<u>120</u> SF	<u>0</u> SF	320 SF

Occupied Forced Ventilation: 0 cfm  
 Unoccupied Forced Ventilation: 0 cfm  
 #DIV/0! AC/hr  
 #DIV/0! AC/hr

# HEAT GAIN/LOSS WORKSHEET

Project Name: City of Linwood, NJ  
 Location: Linwood, NJ  
 Building Name: Emergency Medical Service Building  
 Engineer: Frank D'Alto

Project No.: GHA #22215  
 Site Elevation: 17 Feet  
 Date: 12/01/10

Specific Volume: 14.00 CF#

Building/Facility Designation: Emergency Medical Service Building

## COOLING HEAT GAINS TO THE ROOM - SENSIBLE

### SOLAR GAINS

WINDOWS	AREA (SF)	SHGF	Shade Coef	Cooling Load Factor	Glass Type	Solar Heat Gain
North Exposure	30	38 btu/h/sf	0.8	0.75	Glass Type C	684 Btu/hr
East Exposure	0	218 btu/h/sf	0.8	0.31	Glass Type C	0 Btu/hr
South Exposure	30	109 btu/h/sf	0.8	0.58	Glass Type C	1,517 Btu/hr
West Exposure	120	218 btu/h/sf	0.8	0.29	Glass Type C	6,013 Btu/hr
						<b>8,215 Btu/h</b>

### CONDUCTION

	NET AREA (SF)	U-VALUE	Cooling Load Temp. Dif.	Return Air Factor	Room Heat Gain	
North Exposure	528	0.09	20 °F	1.0	968 Btu/hr	
East Exposure	396	0.09	39 °F	1.0	1,421 Btu/hr	
South Exposure	567	0.09	27 °F	1.0	1,408 Btu/hr	
West Exposure	276	0.09	22 °F	1.0	559 Btu/hr	
Roof	2,400	0.05	73 °F	1.0	8,760 Btu/hr	
Fenestration	180	1.05	19 °F		3,591 Btu/hr	
Doors	71	0.14	27 °F		268 Btu/hr	
Ceiling	2,400	0.14	0 °F		0 Btu/hr	
Partition		0.05	0 °F		0 Btu/hr	
Floor	2,400	0.04	0 °F		0 Btu/hr	
						<b>16,974 Btu/h</b>

### INTERNAL HEAT GAINS (all loads below are based on Occupied Periods)

Lights	1.00 w/sf x 2,400 Occ Area =	2.4 kW x 3.4x	1.0 RAF =	8,191 Btu/h
Plug Load	0.25 w/sf x 2,400 Occ Area =	0.6 kW x 3.4x	1.0 RAF =	2,048 Btu/h
People	1 person x 255 btu/person x	50% time in space =		128 Btu/h
Computer Work Stations	1 Units x	100 W/Unit x 3414 =		341 Btu/h
Equipment	0.0 kW x 3,413 =			0 Btu/h
Misc.				0 Btu/h
<b>10,708 Btu/h</b>				

### VENTILATION AND INFILTRATION

	Infiltration Factor	Perimeter Ratio	Coef	Temp. Diff.	Room Heat Gain
Walls	0.15 CFM/SF		1.04	19 °F	5,671 Btu/h
Doors	0.30 CFM/LF	0.65 LF/SF	1.04	19 °F	296 Btu/h
Windows	0.50 CFM/LF	0.73 LF/SF	1.04	19 °F	1,414 Btu/h
Ventilation	0 cfm		1.04	19 °F	0 Btu/h
Infiltration	345 cfm	#DIV/0! AC/hr			<b>7,380 Btu/h</b>

## COOLING HEAT GAINS TO THE RA PLENUM - SENSIBLE

4,950

### CONDUCTION

	NET AREA (SF)	U-VALUE	Cooling Load Temp. Dif.	Return Air Factor	Room Heat Gain
North Exposure	68	0.09	20	1.0	125 Btu/hr
East Exposure	44	0.09	39	1.0	158 Btu/hr
South Exposure	68	0.09	27	1.0	169 Btu/hr
West Exposure	44	0.09	22	1.0	89 Btu/hr
Roof	2,400	0.05	73	0.0	0 Btu/hr
<b>541 Btu/h</b>					

### INTERNAL HEAT GAINS

Lights	1.00 w/sf x 2,400 Occ Area =	2.4 kW x 3413x	0.00 RAF =	0 Btu/h
Misc.				0 Btu/h
<b>0 Btu/h</b>				

### SENSIBLE HEAT GAINS - TEMP. DEPENDENT

Solar	8,215
Conduction to Room	16,974
Conduction to Plenum	541
Ventilation and Infiltration	7,380
Sub Total	<b>33,110</b>

### SENSIBLE HEAT GAINS - TEMP. INDEPENDENT

Internal Gains to Room	10,708
Internal Gains to Plenum	0
Sub Total	<b>10,708</b>

## HEAT GAIN/LOSS WORKSHEET

Project Name: City of Linwood, NJ      Project No.: CHA 922215  
 Location: Linwood, NJ      Site Elevation: 17 Feet      Specific Volume: 14.00 CF/#  
 Building Name: Emergency Medical Service Building      Date: 12/01/10  
 Engineer: Frank Clutza

Building/Facility Designation: Emergency Medical Service Building

### LATENT COOLING LOADS

Infiltration	Infiltration Factor	Air Density	Humidity Ratio Dif.	Room Heat Gain
Walls	2,624 SF	0.15 CFM/SF	4,629	7,730 Btu/h
Doors	71 SF	0.30 CFM/LF	4,629	271 Btu/h
Windows	180 SF	0.50 CFM/LF	4,629	1,296 Btu/h
Ventilation	0 cfm		4,629	0 Btu/h
People	1 people	0.50 time in space	250 Btu/hr/person	125 Btu/h
				<b>9,422 Btu/h</b>

### Cooling Load Summary

	Sensible	Latent	Total	SHR=
Temperature Dependent Gains	33,110	9,422	42,532	
Temperature Indep. Gains	10,708	0	10,708	0.82
<b>Total</b>	<b>43,818</b>	<b>9,422</b>	<b>53,240</b>	

Building Cooling Load: 4.4 Tons at 541 SF/Ton

Building Air Flow to Condition Space based on a 12°F Temp Rise is 3,455 CFM  
1.44 CFM/sf

### HEATING CALCULATION

#### CONDUCTION

	NET AREA (SF)	U-VALUE	Heating Load Temp. Dif.	Room Heat Gain
North Exposure	594	0.09	58	3,170 Btu/h
East Exposure	440	0.09	58	2,348 Btu/h
South Exposure	635	0.09	58	3,388 Btu/h
West Exposure	320	0.09	58	1,708 Btu/h
Fenestration	180	1.05	58	10,962 Btu/h
Roof	2,400	0.05	58	6,960 Btu/h
Doors	71	0.14	58	575 Btu/h
Ceiling	2,400	0.14	5	1,667 Btu/h
Partition	0	0.05	0	0 Btu/h
Floor	2,400	0.04	0	0 Btu/h

#### Ventilation and Infiltration

	Infiltration Factor	Coef	Temp. Difference	Air Flow	Room Heat Gain
Walls	1,989 SF	0.15 CFM/SF	58	296 cfm	18,062 Btu/h
Doors	71 SF	0.30 CFM/LF	58	14 cfm	835 Btu/h
Windows	180 SF	0.50 CFM/LF	58	66 cfm	3,996 Btu/h
Ventilation Load	0 cfm		58	0 cfm	0 Btu/h
<b>Total Ventilation &amp; Infiltration Load</b>				<b>378 cfm</b>	<b>22,894 Btu/h</b>

**Building Heating Load**      **53,671**      **btu/h**  
 22.4 btu/sf

City of Linwood, NJ  
 CHA #22215  
 Building: Emergency Medical Service Building

Doors

	Width (ft)	Height (ft)	Quantity	Area (SF)	Lineal Feet
North	8.0	7.0	1	56.0	30.0
				0.0	0.0
				0.0	0.0
				0.0	0.0
				0.0	0.0
				0.0	0.0
			Sub-total	56.0	30.0
East				0.0	0.0
				0.0	0.0
				0.0	0.0
				0.0	0.0
			Sub-total	0.0	0.0
South	3.0	5.0	1	15.0	16.0
				0.0	0.0
				0.0	0.0
				0.0	0.0
				0.0	0.0
				0.0	0.0
			Sub-total	15.0	16.0
West				0.0	0.0
				0.0	0.0
				0.0	0.0
				0.0	0.0
			Sub-total	0.0	0.0
			<b>Total</b>	<b>71.0</b>	<b>46.0</b>

LF/SF
0.65

**Walls**

	Width (ft)	Height (ft)	Quantity	Area (SF)	Lineal Feet	
North	68.0	10.0	1	680.0	156.0	All wall quantities must remain equal to 1
				0.0	0.0	
				0.0	0.0	
				0.0	0.0	
				0.0	0.0	
	68.0			680.0	156.0	Ave. height 10.0
						Average height wall automatically linked

East	44.0	10.0	1	440.0	108.0	
				0.0	0.0	
				0.0	0.0	
				0.0	0.0	
				0.0	0.0	
	44.0			440.0	108.0	Ave. height 10.0
						Average height wall automatically linked

South	68.0	10.0	1	680.0	156.0	
				0.0	0.0	
				0.0	0.0	
				0.0	0.0	
				0.0	0.0	
	68.0			680.0	156.0	Ave. height 10.0
						Average height wall automatically linked

West	44.0	10.0	1	440.0	108.0	
				0.0	0.0	
				0.0	0.0	
				0.0	0.0	
				0.0	0.0	
	44.0			440.0	108.0	Ave. height 10.0
						Average height auto linked to block load sheet

**Windows**

	Width (ft)	Height (ft)	Quantity	Area (SF)	Lineal Feet
North	5.0	6.0	1	30.0	22.0
				0.0	0.0
				0.0	0.0
				0.0	0.0
				0.0	0.0
			Sub-total	30.0	22.0

East				0.0	0.0
				0.0	0.0
				0.0	0.0
				0.0	0.0
				0.0	0.0
			Sub-total	0.0	0.0

South	6.0	5.0	1	30.0	22.0
				0.0	0.0
				0.0	0.0
				0.0	0.0
				0.0	0.0
			Sub-total	30.0	22.0

West	6.0	5.0	4	120.0	88.0
				0.0	0.0
				0.0	0.0
				0.0	0.0
				0.0	0.0
			Sub-total	120.0	88.0

				Total	180.0	132.0	LF/SF 0.73
--	--	--	--	-------	-------	-------	------------